

NANJING, China

WMO: 582380

Lat: 31.9316N

Lon: 118.8996E

Elev: 118

StdP: 14.63

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.4	26.4	6.7	7.8	35.6	11.8	10.1	36.7	17.8	37.5	15.8	40.0	2.8	250	0.406

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.2	96.8	80.3	94.7	79.8	92.0	79.2	83.0	91.4	82.0	89.9	81.0	88.8	8.3	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.9	161.1	87.4	80.2	157.3	86.8	79.0	151.0	85.9	47.2	91.7	46.1	90.4	45.1	88.7	88.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.8	14.7	13.0	19.2	99.9	3.5	2.3	16.7	101.6	14.6	102.9	12.6	104.2	10.1	105.8		
(5)			17.6	84.8	3.5	1.6	15.0	85.9	12.9	86.9	11.0	87.8	8.4	89.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	61.8	37.9	41.9	50.5	61.3	70.8	77.1	83.9	82.9	74.9	64.7	53.0	41.8	(6)
(7)		DBStd	16.85	5.68	6.68	7.11	6.58	5.31	4.64	5.01	4.97	4.95	5.41	6.85	5.94	(7)
(8)		HDD50	1006	378	239	81	4	0	0	0	0	0	0	45	259	(8)
(9)		HDD65	3251	841	647	450	147	11	0	0	1	72	364	718	(9)	
(10)		CDD50	5323	1	12	98	342	645	814	1051	1019	746	456	133	6	(10)
(11)		CDD65	2093	0	0	2	35	191	364	586	554	296	62	3	0	(11)
(12)		CDH74	20988	0	2	35	329	1497	3134	7149	6363	2139	321	19	0	(12)
(13)		CDH80	8788	0	0	5	80	494	1156	3507	2872	621	52	1	0	(13)
(14)	Wind	WSAvg	5.8	5.3	6.2	6.7	6.5	6.2	6.1	5.9	6.1	5.7	5.2	5.0	5.2	(14)
(15)	Precipitation	PrecAvg	45.0	2.0	2.3	3.3	3.2	3.6	7.6	8.6	6.0	2.8	2.1	2.1	1.3	(15)
(16)		PrecMax	72.8	4.8	5.1	7.9	6.5	6.7	23.6	18.4	11.1	8.7	11.8	4.6	4.1	(16)
(17)		PrecMin	26.3	0.5	0.6	0.6	0.6	0.9	0.9	1.9	2.9	0.1	0.0	0.0	0.0	(17)
(18)		PrecStd	11.5	1.3	1.4	2.1	1.5	1.6	4.8	5.3	2.2	2.0	2.2	1.5	1.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.8	68.7	78.5	87.4	93.4	95.2	100.3	100.3	93.2	85.6	76.9	63.7	(19)
MCWB			49.7	55.3	62.0	67.9	70.2	76.9	81.5	81.2	78.7	71.0	62.0	50.9	(20)	
2%		DB	54.6	61.8	72.3	82.1	89.0	91.8	97.2	96.4	89.1	80.5	71.6	58.2	(21)	
		MCWB	45.9	51.5	58.5	65.7	69.7	75.7	80.6	80.8	77.1	67.0	60.1	49.7	(22)	
5%		DB	50.3	57.0	67.7	77.4	85.6	89.4	95.3	93.6	86.1	77.3	67.8	55.1	(23)	
		MCWB	44.2	48.6	56.4	63.7	68.5	74.5	80.3	80.6	75.3	64.8	58.1	48.1	(24)	
10%		DB	47.3	52.7	63.0	73.5	82.2	86.4	93.2	91.4	83.6	74.8	64.3	51.9	(25)	
		MCWB	42.3	46.1	53.2	61.4	67.2	74.1	80.5	79.8	73.6	63.7	56.6	46.2	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.4	58.2	65.5	72.2	76.8	81.6	84.6	84.4	81.7	73.9	66.8	55.9	(27)
MCDWB			56.8	64.9	73.6	80.5	86.6	89.7	93.4	93.7	88.8	80.0	71.3	58.3	(28)	
2%		WB	48.0	53.1	61.1	69.3	74.2	79.6	83.4	82.8	79.7	70.9	63.0	52.1	(29)	
		MCDWB	52.1	59.7	68.8	77.1	82.0	87.0	92.0	91.0	85.7	76.5	67.4	55.7	(30)	
5%		WB	45.4	50.2	57.7	66.5	72.3	78.3	82.4	81.8	78.2	68.8	60.5	49.5	(31)	
		MCDWB	49.1	54.5	65.3	74.1	79.2	84.9	90.6	89.6	83.4	73.8	65.0	53.0	(32)	
10%		WB	43.0	47.1	54.9	63.7	70.5	76.7	81.5	80.9	76.3	66.8	57.9	47.2	(33)	
		MCDWB	46.5	51.5	61.5	70.9	77.3	82.6	89.6	88.5	81.4	71.7	63.1	50.8	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	14.1	14.6	16.7	17.5	17.1	14.0	13.2	12.9	14.0	16.2	16.9	15.5	(35)
MCDBR			21.8	24.0	25.4	24.8	23.8	19.1	16.7	16.3	16.1	20.8	22.6	21.6	(36)	
MCWBR			13.6	14.1	13.4	11.6	9.1	7.4	5.8	5.8	6.4	8.8	11.6	12.8	(37)	
5% WB		MCDWB	18.0	19.5	21.9	20.5	17.4	14.4	15.2	14.9	13.7	15.0	16.4	15.6	(38)	
		MCWBR	12.4	13.0	13.3	11.8	9.2	7.1	6.3	6.2	6.4	8.1	10.0	10.8	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.609	0.665	0.686	0.690	0.682	0.758	0.722	0.711	0.679	0.674	0.641	0.605	(40)	
taud		1.624	1.552	1.539	1.580	1.631	1.525	1.629	1.636	1.658	1.605	1.622	1.646	(41)		
Ebn at Noon		183	189	200	208	212	195	202	201	199	184	174	174	(42)		
Edh at Noon		68	80	86	86	82	91	82	80	75	74	67	63	(43)		
(44)	All-Sky Solar Radiation	RadAvg	710	816	1168	1396	1487	1370	1525	1427	1204	1026	783	688	(44)	
(45)		RadStd	96	162	105	155	152	173	184	204	136	155	100	106	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (7 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page