

NANJING, China

WMO: 582380

Lat: 31.9316N

Lon: 118.8996E

Elev: 36

StdP: 100.89

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.8	-3.1	-14.1	1.1	2.0	-11.2	1.4	2.6	7.9	3.1	7.0	4.4	1.3	250	0.406

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.3	36.0	26.8	34.8	26.5	33.3	26.2	28.3	33.0	27.8	32.2	27.2	31.6	3.7	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	23.0	30.8	26.8	22.5	30.5	26.1	21.6	29.9	92.0	33.2	89.4	32.4	87.0	31.5	31.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.5	6.6	5.8	-7.1	37.7	2.0	1.3	-8.5	38.6	-9.7	39.4	-10.8	40.1	-12.2	41.0		
			DB													
			WB	-8.0	29.3	2.0	0.9	-9.4	30.0	-10.6	30.5	-11.7	31.0	-13.1	31.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.6	3.3	5.5	10.3	16.3	21.6	25.1	28.8	28.3	23.8	18.2	11.6	5.5
	DBStd	9.36	3.15	3.71	3.95	3.65	2.95	2.58	2.78	2.76	2.75	3.00	3.81	3.30
	HDD10.0	559	210	133	45	2	0	0	0	0	0	0	25	144
	HDD18.3	1806	467	359	250	82	6	0	0	0	1	40	202	399
	CDD10.0	2957	1	7	54	190	358	452	584	566	414	253	74	3
	CDD18.3	1163	0	0	1	19	106	202	326	308	164	34	2	0
	CDH23.3	11660	0	1	19	183	832	1741	3972	3535	1188	178	11	0
	CDH26.7	4882	0	0	3	44	274	642	1948	1596	345	29	1	0
Wind	WSAvg	2.6	2.4	2.8	3.0	2.9	2.8	2.7	2.7	2.6	2.3	2.2	2.3	
Precipitation	PrecAvg	1143	50	59	85	81	91	192	219	152	72	54	54	34
	PrecMax	1850	121	130	200	166	169	599	468	283	220	300	116	105
	PrecMin	668	12	15	16	15	22	24	47	73	3	0	0	0
	PrecStd	291	33	35	53	39	41	122	134	57	50	57	38	27
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.0	20.4	25.8	30.8	34.1	35.1	38.0	37.9	34.0	29.8	24.9	17.6
		MCWB	9.8	13.0	16.7	20.0	21.2	25.0	27.5	27.4	26.0	21.7	16.7	10.5
	2%	DB	12.6	16.5	22.4	27.8	31.7	33.2	36.2	35.8	31.7	27.0	22.0	14.6
		MCWB	7.7	10.8	14.7	18.7	20.9	24.3	27.0	27.1	25.1	19.5	15.6	9.9
	5%	DB	10.2	13.9	19.8	25.2	29.8	31.9	35.2	34.2	30.1	25.2	19.9	12.8
		MCWB	6.8	9.2	13.6	17.6	20.3	23.6	26.8	27.0	24.1	18.2	14.5	9.0
	10%	DB	8.5	11.5	17.2	23.1	27.9	30.2	34.0	33.0	28.7	23.8	18.0	11.0
		MCWB	5.7	7.9	11.8	16.4	19.6	23.4	27.0	26.6	23.1	17.6	13.7	7.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.3	14.6	18.6	22.3	24.9	27.5	29.2	29.1	27.6	23.3	19.3	13.3
		MCDB	13.8	18.3	23.1	26.9	30.3	32.1	34.1	34.3	31.6	26.7	21.9	14.6
	2%	WB	8.9	11.7	16.2	20.7	23.4	26.5	28.6	28.2	26.5	21.6	17.2	11.1
		MCDB	11.2	15.4	20.5	25.1	27.8	30.6	33.3	32.8	29.8	24.7	19.7	13.2
	5%	WB	7.4	10.1	14.3	19.2	22.4	25.7	28.0	27.7	25.6	20.4	15.8	9.7
		MCDB	9.5	12.5	18.5	23.4	26.2	29.4	32.6	32.0	28.6	23.2	18.3	11.6
	10%	WB	6.1	8.4	12.7	17.6	21.4	24.8	27.5	27.1	24.6	19.3	14.4	8.4
		MCDB	8.0	10.8	16.4	21.6	25.2	28.1	32.0	31.4	27.4	22.1	17.3	10.4
Mean Daily Temperature Range	5% DB	MDBR	7.8	8.1	9.3	9.7	9.5	7.8	7.3	7.2	7.8	9.0	9.4	8.6
		MCDBR	12.1	13.3	14.1	13.8	13.2	10.6	9.3	9.0	9.0	11.5	12.6	12.0
		MCWBR	7.5	7.8	7.4	6.5	5.1	4.1	3.2	3.2	3.6	4.9	6.4	7.1
	5% WB	MCDBR	10.0	10.8	12.2	11.4	9.7	8.0	8.5	8.3	7.6	8.3	9.1	8.7
		MCWBR	6.9	7.2	7.4	6.6	5.1	3.9	3.5	3.4	3.6	4.5	5.5	6.0
Clear-Sky Solar Irradiance	taub	0.609	0.665	0.686	0.690	0.682	0.758	0.722	0.711	0.679	0.674	0.641	0.605	
	taud	1.624	1.552	1.539	1.580	1.631	1.525	1.629	1.636	1.658	1.605	1.622	1.646	
	Ebn at Noon	576	596	630	656	667	616	636	634	628	581	547	549	
	Edh at Noon	213	251	271	270	259	286	257	252	238	234	211	199	
All-Sky Solar Radiation	RadAvg	2.24	2.57	3.68	4.40	4.69	4.32	4.81	4.50	3.80	3.23	2.47	2.17	
	RadStd	0.30	0.51	0.33	0.49	0.48	0.55	0.58	0.64	0.43	0.49	0.31	0.34	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page