

HUOSHAN, China

WMO: 583140

Lat: 31.4009N

Lon: 116.3370E

Elev: 287

StdP: 14.54

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.9	25.7	11.0	9.8	38.2	15.7	12.3	36.9	12.4	47.5	10.4	46.1	1.5	180	0.351

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.6	97.4	80.1	95.0	79.5	92.4	78.5	83.1	92.1	81.9	90.5	80.8	88.8	6.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.9	162.3	87.7	79.8	156.1	86.4	78.8	150.9	85.1	47.4	92.5	46.1	90.9	44.9	89.1	88.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
12.1	10.0	8.6	DB	18.6	100.9	3.1	2.1	16.4	102.4	14.6	103.7	12.9	104.9	10.6	106.4
			WB	17.7	85.0	2.9	1.4	15.6	86.0	13.9	86.8	12.2	87.6	10.1	88.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.7	37.9	42.3	51.7	62.7	71.2	77.4	83.3	81.3	73.4	63.5	52.2	41.9	(6)
	DBStd	16.60	5.90	7.25	7.90	7.37	5.45	4.89	4.81	5.01	5.40	5.73	6.92	5.92	(7)
	HDD50	999	377	234	73	4	0	0	0	0	0	0	53	258	(8)
	HDD65	3234	840	636	420	127	11	0	0	0	3	95	386	716	(9)
	CDD50	5260	2	17	125	385	657	821	1033	972	702	420	119	7	(10)
	CDD65	2020	0	0	7	57	203	371	568	507	255	50	2	0	(11)
	CDH74	19900	0	4	95	618	1726	3392	6644	5244	1795	346	36	0	(12)
	CDH80	8352	0	1	20	190	632	1384	3217	2241	591	71	5	0	(13)
(14) Wind	WSAvg	3.3	2.7	3.2	3.8	4.0	3.8	3.5	3.6	3.4	3.0	2.8	2.7	2.8	(14)
(15) Precipitation	PrecAvg	52.7	1.6	2.6	3.7	4.8	5.7	6.7	7.7	7.0	5.0	3.7	2.8	1.4	(15)
	PrecMax	71.6	3.3	7.1	8.2	8.5	12.4	12.4	15.7	19.8	9.9	14.3	7.6	4.5	(16)
	PrecMin	28.8	0.0	0.0	0.7	1.3	1.5	0.5	1.0	1.4	0.4	0.0	0.0	0.0	(17)
	PrecStd	10.5	0.8	1.6	1.5	1.8	2.6	3.3	3.9	4.1	2.6	3.2	1.9	1.2	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.5	70.9	82.8	90.8	94.2	97.0	100.7	99.5	95.4	86.6	78.7	66.0	(19)
		MCWB	49.0	56.9	62.6	67.9	69.5	77.1	80.9	79.6	78.7	70.3	60.6	50.0	(20)
	2%	DB	55.9	64.2	75.9	85.3	90.4	93.6	98.3	96.2	90.0	81.5	72.7	59.8	(21)
		MCWB	45.3	52.3	59.4	65.6	69.9	76.6	80.4	81.0	76.3	66.8	58.4	47.6	(22)
	5%	DB	51.7	59.1	70.6	81.1	86.8	90.4	96.2	93.4	86.3	77.7	67.9	55.8	(23)
		MCWB	43.9	49.2	57.0	64.1	69.3	75.5	80.5	80.9	74.8	64.0	56.8	46.7	(24)
	10%	DB	48.0	54.2	65.9	76.8	83.3	87.8	93.4	90.5	82.9	74.4	63.7	52.1	(25)
		MCWB	42.1	47.2	54.5	62.3	68.5	75.1	80.4	79.9	72.0	63.3	55.1	45.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.2	59.7	66.9	73.1	77.4	81.9	85.1	84.5	81.7	74.2	65.2	53.4	(27)
		MCDB	60.1	68.2	75.3	82.0	85.4	89.3	93.9	93.4	90.9	80.8	71.8	56.8	(28)
	2%	WB	47.7	54.3	62.2	69.8	74.9	79.8	83.4	82.9	79.5	70.2	61.6	50.9	(29)
		MCDB	53.0	60.6	72.2	79.5	82.6	87.5	93.0	91.7	86.2	76.3	66.7	56.3	(30)
	5%	WB	45.1	50.8	58.8	67.5	73.0	78.5	82.2	81.8	77.6	67.9	59.3	48.2	(31)
		MCDB	50.5	56.6	67.4	75.6	80.0	85.7	91.3	90.2	82.7	73.1	65.1	53.6	(32)
	10%	WB	42.4	48.1	55.9	65.0	71.3	77.3	81.1	80.8	75.7	65.9	56.7	46.0	(33)
		MCDB	46.7	53.2	64.0	72.8	78.6	84.0	89.6	88.4	79.9	70.9	62.7	50.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	14.6	15.0	17.6	18.5	17.6	15.3	14.6	13.5	15.0	17.0	17.9	16.5	(35)
		MCDBR	24.1	26.1	27.6	27.0	25.5	21.3	19.6	18.6	19.8	24.5	27.1	25.3	(36)
	5% WB	MCWBR	13.8	13.9	12.8	11.1	9.3	7.4	5.8	6.1	7.3	9.7	12.7	13.5	(37)
		MCWBR	20.7	21.2	22.5	20.5	17.6	16.2	17.2	16.4	15.5	17.3	19.4	19.6	(38)
(40) Clear-Sky Solar Irradiance	taub		0.645	0.704	0.734	0.730	0.716	0.758	0.701	0.744	0.733	0.713	0.662	0.626	(40)
		taud	1.537	1.472	1.455	1.504	1.560	1.518	1.654	1.561	1.549	1.520	1.560	1.587	(41)
	Ebn at Noon		174	180	190	200	205	196	206	195	188	176	169	170	(42)
		Edh at Noon	74	87	94	93	88	92	80	86	84	81	72	68	(43)
(44) All-Sky Solar Radiation	RadAvg		681	774	1131	1352	1433	1374	1505	1346	1174	986	795	673	(44)
	RadStd		102	187	93	149	143	146	189	184	160	156	105	120	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page