

HUOSHAN, China

WMO: 583140

Lat: 31.4009N

Lon: 116.3370E

Elev: 88

StdP: 100.28

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -5.1	(c) -3.5	(d) -11.6	(e) 1.4	(f) 3.4	(g) -9.0	(h) 1.8	(i) 2.7	(j) 5.6	(k) 8.6	(l) 4.7	(m) 7.8	(n) 0.7	(o) 180	(p) 0.351

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.1	36.3	26.7	35.0	26.4	33.5	25.8	28.4	33.4	27.7	32.5	27.1	31.6	3.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	23.2	30.9	26.5	22.3	30.2	26.0	21.6	29.5	92.5	33.6	89.4	32.7	86.5	31.7	31.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 5.4	(b) 4.5	(c) 3.8	(e) -7.5	(f) 38.3	(g) 1.7	(h) 1.2	(i) -8.7	(j) 39.1	(k) -9.7	(l) 39.8	(m) -10.6	(n) 40.5	(o) -11.9	(p) 41.3		
(a) 5.4	(b) 4.5	(c) 3.8	(e) -8.0	(f) 29.5	(g) 1.6	(h) 0.8	(i) -9.1	(j) 30.0	(k) -10.1	(l) 30.5	(m) -11.0	(n) 30.9	(o) -12.2	(p) 31.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.5	3.3	5.7	10.9	17.0	21.8	25.2	28.5	27.4	23.0	17.5	11.2	5.5
	DBStd	9.22	3.28	4.03	4.39	4.09	3.03	2.72	2.67	2.78	3.00	3.18	3.85	3.29
	HDD10.0	555	209	130	41	2	0	0	0	0	0	0	29	143
	HDD18.3	1797	467	353	233	71	6	0	0	0	2	53	214	398
	CDD10.0	2922	1	9	69	214	365	456	574	540	390	233	66	4
	CDD18.3	1122	0	0	4	32	113	206	316	282	142	28	1	0
	CDH23.3	11056	0	2	53	343	959	1884	3691	2913	997	192	20	0
CDH26.7	4640	0	1	11	106	351	769	1787	1245	328	39	3	0	
Wind	WSAvg	1.5	1.2	1.4	1.7	1.8	1.7	1.6	1.6	1.5	1.4	1.2	1.2	1.2
Precipitation	PrecAvg	1339	41	65	94	122	145	170	196	179	128	93	72	35
	PrecMax	1818	84	181	208	215	314	315	399	503	252	364	194	115
	PrecMin	732	0	1	17	34	38	12	25	36	11	0	0	0
	PrecStd	266	21	40	38	45	65	85	99	104	67	81	48	30
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.0	21.6	28.2	32.6	34.6	36.1	38.2	37.5	35.2	30.3	26.0	18.9
		MCWB	9.4	13.8	17.0	20.0	20.8	25.0	27.2	26.5	25.9	21.3	15.9	10.0
	2%	DB	13.3	17.9	24.4	29.6	32.4	34.2	36.8	35.6	32.2	27.5	22.6	15.5
		MCWB	7.4	11.3	15.2	18.7	21.0	24.8	26.9	27.2	24.6	19.3	14.6	8.7
	5%	DB	10.9	15.1	21.5	27.3	30.5	32.5	35.7	34.1	30.2	25.4	20.0	13.2
		MCWB	6.6	9.6	13.9	17.8	20.7	24.2	26.9	27.2	23.8	17.8	13.8	8.2
	10%	DB	8.9	12.4	18.8	24.9	28.5	31.0	34.1	32.5	28.3	23.5	17.6	11.2
		MCWB	5.6	8.4	12.5	16.9	20.3	23.9	26.9	26.6	22.2	17.4	12.8	7.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.7	15.4	19.4	22.8	25.2	27.7	29.5	29.1	27.6	23.4	18.5	11.9
		MCDB	15.6	20.1	24.0	27.8	29.7	31.8	34.4	34.1	32.7	27.1	22.1	13.8
	2%	WB	8.7	12.4	16.8	21.0	23.8	26.5	28.6	28.3	26.4	21.2	16.5	10.5
		MCDB	11.7	15.9	22.3	26.4	28.1	30.8	33.9	33.2	30.1	24.6	19.3	13.5
	5%	WB	7.3	10.4	14.9	19.7	22.8	25.8	27.9	27.7	25.4	20.0	15.2	9.0
		MCDB	10.3	13.6	19.7	24.2	26.6	29.8	32.9	32.3	28.2	22.9	18.4	12.0
	10%	WB	5.8	9.0	13.3	18.3	21.8	25.2	27.3	27.1	24.3	18.9	13.7	7.8
		MCDB	8.2	11.8	17.8	22.7	25.9	28.9	32.0	31.3	26.6	21.6	17.1	10.5
Mean Daily Temperature Range	5% DB	MDBR	8.1	8.4	9.8	10.3	9.8	8.5	8.1	7.5	8.3	9.4	9.9	9.2
		MCDBR	13.4	14.5	15.3	15.0	14.2	11.8	10.9	10.3	11.0	13.6	15.1	14.0
		MCWBR	7.6	7.7	7.1	6.1	5.2	4.1	3.2	3.4	4.0	5.4	7.0	7.5
	5% WB	MCDBR	11.5	11.8	12.5	11.4	9.8	9.0	9.6	9.1	8.6	9.6	10.8	10.9
MCWBR		7.0	6.9	6.7	5.9	4.7	3.8	3.7	3.6	3.8	4.6	5.6	6.4	
Clear-Sky Solar Irradiance	taub	0.645	0.704	0.734	0.730	0.716	0.758	0.701	0.744	0.733	0.713	0.662	0.626	
	taud	1.537	1.472	1.455	1.504	1.560	1.518	1.654	1.561	1.549	1.520	1.560	1.587	
	Ebn at Noon	549	569	599	630	645	617	650	614	593	555	532	535	
	Edh at Noon	234	273	296	292	278	289	251	272	266	256	227	213	
All-Sky Solar Radiation	RadAvg	2.15	2.44	3.56	4.26	4.52	4.33	4.74	4.24	3.70	3.11	2.51	2.12	
	RadStd	0.32	0.59	0.29	0.47	0.45	0.46	0.59	0.58	0.50	0.49	0.33	0.38	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page