

HEFEI, China

WMO: 583210

Lat: 31.9555N

Lon: 117.0574E

Elev: 171

StdP: 14.61

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 24.5	(c) 26.8	(d) 8.3	(e) 8.5	(f) 34.9	(g) 12.6	(h) 10.5	(i) 35.0	(j) 17.6	(k) 38.3	(l) 15.6	(m) 40.5	(n) 4.1	(o) 290	(p) 0.409

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.7	96.6	82.1	94.5	81.3	92.0	80.2	84.2	92.7	83.0	91.1	81.9	89.5	7.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
82.2	168.8	89.5	80.8	161.2	88.1	80.1	157.0	87.3	48.6	92.5	47.3	91.8	46.1	90.3	89.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 16.2	(b) 14.0	(c) 12.1	(e) 19.2	(f) 100.0	(g) 3.8	(h) 2.3	(i) 16.5	(j) 101.6	(k) 14.2	(l) 103.0	(m) 12.1	(n) 104.3	(o) 9.3	(p) 105.9		
(a) 16.2	(b) 14.0	(c) 12.1	(e) 17.4	(f) 85.8	(g) 3.7	(h) 1.3	(i) 14.7	(j) 86.8	(k) 12.5	(l) 87.6	(m) 10.4	(n) 88.3	(o) 7.8	(p) 89.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	62.2	37.8	42.2	51.3	62.3	71.9	78.1	84.2	82.7	74.9	64.8	52.7	41.8
	DBStd	17.02	5.80	7.04	7.48	6.80	5.65	4.76	4.92	5.10	5.10	5.87	7.09	5.91
	HDD50	1000	380	234	74	3	0	0	0	0	0	0	49	260
	HDD65	3215	844	639	427	129	9	0	0	0	1	76	371	719
	CDD50	5438	2	15	115	371	678	843	1061	1013	746	457	131	6
	CDD65	2178	0	0	4	46	222	393	596	548	297	69	3	0
	CDH74	22246	0	1	41	382	1786	3692	7397	6315	2223	389	20	0
	CDH80	9379	0	0	6	85	590	1398	3655	2879	689	76	1	0
Wind	WSAvg	5.8	5.5	6.1	6.6	6.5	6.1	5.7	5.9	5.7	5.4	5.1	5.4	5.6
Precipitation	PrecAvg	41.7	1.8	2.2	3.3	3.4	3.7	6.5	7.0	5.4	2.8	2.0	2.2	1.3
	PrecMax	62.6	3.9	5.5	6.9	7.4	6.3	14.5	17.4	9.5	7.7	9.9	4.6	4.9
	PrecMin	26.1	0.5	0.5	0.5	0.4	0.4	1.8	1.3	2.3	0.1	0.1	0.0	0.0
	PrecStd	9.1	1.0	1.3	1.9	1.7	1.5	3.5	4.2	2.0	1.9	2.0	1.5	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.8	69.4	79.0	87.1	92.7	95.1	100.3	98.9	93.8	86.4	77.1	63.8
		MCWB	49.1	57.2	63.3	69.5	71.5	77.8	82.1	82.8	79.3	70.2	61.0	50.5
	2%	DB	54.0	62.1	72.6	82.4	89.4	92.0	97.1	95.5	89.8	81.9	71.6	58.2
		MCWB	45.3	51.3	59.5	67.3	71.2	77.4	82.4	82.1	77.3	67.3	58.7	48.5
	5%	DB	50.3	57.3	68.1	78.5	86.2	89.7	95.2	93.5	86.5	78.5	67.8	54.4
		MCWB	43.5	48.9	57.1	65.6	69.9	76.2	82.3	81.6	75.5	64.7	57.5	46.6
	10%	DB	47.1	53.4	64.1	74.9	82.8	87.5	93.1	91.3	84.0	75.2	64.3	51.5
		MCWB	41.6	46.5	54.3	63.1	68.8	75.4	82.0	81.0	73.2	64.0	56.1	45.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.3	59.3	67.5	73.0	78.0	83.1	85.9	85.4	81.9	73.8	65.7	54.4
		MCDB	56.1	66.9	75.0	80.8	85.4	90.7	94.0	93.7	89.8	81.1	70.6	58.2
	2%	WB	47.5	53.7	62.1	70.4	75.4	81.0	84.5	84.0	79.9	70.7	62.1	50.8
		MCDB	51.8	58.9	69.8	78.7	83.7	88.1	93.1	92.3	87.0	77.1	67.3	55.4
	5%	WB	44.5	50.3	58.7	67.7	73.4	79.4	83.5	82.9	78.2	68.4	59.6	48.4
		MCDB	49.0	55.2	65.7	75.3	80.8	85.7	92.0	90.6	84.0	74.1	64.8	52.9
	10%	WB	42.2	47.4	55.6	65.0	71.6	78.0	82.4	81.7	76.3	66.4	57.0	46.2
		MCDB	46.3	52.1	62.4	72.2	79.0	83.9	90.5	88.9	81.3	71.9	62.9	49.8
Mean Daily Temperature Range	5% DB	MDBR	13.1	13.7	15.8	16.7	16.3	13.4	12.7	12.6	14.1	15.5	15.9	14.5
		MCDBR	20.3	22.1	23.5	23.6	21.6	17.7	15.6	15.4	16.8	21.0	22.2	20.8
		MCWBR	12.8	13.3	12.7	11.7	9.0	7.4	6.2	6.1	6.6	8.7	11.1	12.2
	5% WB	MCDBR	17.9	18.7	20.5	20.4	17.0	13.9	15.0	14.7	13.9	15.9	16.3	16.7
		MCWBR	12.2	12.6	12.9	11.9	8.8	7.2	6.9	6.6	6.6	8.4	9.7	11.0
Clear-Sky Solar Irradiance	taub	0.614	0.671	0.689	0.688	0.688	0.750	0.704	0.719	0.702	0.691	0.645	0.606	
	taud	1.597	1.529	1.518	1.566	1.604	1.526	1.646	1.604	1.598	1.559	1.590	1.625	
	Ebn at Noon	181	187	199	208	210	197	206	200	194	180	172	174	
	Edh at Noon	69	81	88	87	84	91	80	82	80	78	69	64	
All-Sky Solar Radiation	RadAvg	692	795	1161	1390	1479	1408	1513	1374	1178	991	782	675	
	RadStd	97	177	101	153	146	157	188	189	162	153	103	111	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page