

WUHUXIAN, China

WMO: 583380

Lat: 31.1198N

Lon: 118.5946E

Elev: 136

StdP: 14.62

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 26.5	(c) 28.8	(d) 12.2	(e) 10.3	(f) 35.9	(g) 16.6	(h) 12.8	(i) 35.8	(j) 17.3	(k) 41.1	(l) 15.8	(m) 40.1	(n) 3.9	(o) 70	(p) 0.386

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 12.6	(c) 97.2	(d) 81.4	(e) 95.2	(f) 80.9	(g) 92.9	(h) 80.2	(i) 83.5	(j) 92.8	(k) 82.4	(l) 91.8	(m) 81.5	(n) 90.2	(o) 5.8	(p) 220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.2	162.8	88.8	80.1	156.8	87.7	79.1	151.9	86.6	47.8	92.7	46.5	92.0	45.5	90.6	89.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.3	14.0	12.2	22.0	99.9	3.5	2.0	19.5	101.3	17.4	102.5	15.4	103.6	12.9	105.1
			20.1	85.2	3.3	1.5	17.7	86.3	15.8	87.1	14.0	88.0	11.6	89.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	63.0	39.3	43.2	52.0	62.6	71.9	77.5	84.5	83.5	75.7	65.9	54.6	43.5
	DBStd	16.56	5.75	7.05	7.53	6.86	5.29	4.83	5.05	4.97	5.29	5.51	6.96	5.88
	HDD50	859	334	210	65	3	0	0	0	0	0	0	32	215
	HDD65	2984	796	610	407	122	7	0	0	0	0	56	319	667
	CDD50	5585	3	21	128	382	679	824	1069	1037	770	491	169	12
	CDD65	2236	0	0	5	51	221	374	604	572	320	83	6	0
	CDH74	22494	0	4	52	392	1620	3232	7613	6799	2414	343	25	0
	CDH80	9660	0	1	9	101	527	1173	3862	3176	752	58	1	0
Wind	WSAvg	5.6	5.4	6.2	6.6	6.2	5.8	5.6	5.4	5.7	5.5	5.2	5.0	5.1
Precipitation	PrecAvg	50.2	2.6	3.0	4.6	4.2	5.2	8.7	6.8	5.5	3.3	2.0	2.4	1.7
	PrecMax	85.9	5.0	7.5	12.0	10.7	10.0	30.3	16.4	13.8	12.3	8.6	5.4	4.8
	PrecMin	33.8	0.9	0.7	1.4	1.4	2.1	2.4	1.0	1.4	0.1	0.0	0.0	0.0
	PrecStd	11.2	1.3	1.7	2.5	2.0	2.2	5.8	4.1	3.2	2.5	1.7	1.7	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	61.2	70.5	79.5	88.1	92.8	95.4	99.8	100.8	94.5	85.7	77.7	64.1
		MCWB	51.2	58.2	63.8	68.0	71.7	78.4	82.2	81.7	80.1	71.5	62.8	51.2
	2%	DB	55.4	63.4	73.3	82.6	89.0	92.2	97.9	96.8	90.1	81.1	72.1	58.7
		MCWB	48.0	53.4	60.3	66.6	70.5	77.8	81.6	81.6	78.3	68.4	61.2	50.6
	5%	DB	51.1	58.3	68.4	78.4	85.7	89.5	96.1	94.6	87.2	77.5	68.4	55.3
		MCWB	45.3	50.4	57.4	64.7	69.6	76.2	81.4	81.1	77.0	66.5	59.2	49.4
	10%	DB	48.0	53.8	64.1	74.5	82.5	86.8	93.9	92.2	84.2	74.9	64.9	52.3
		MCWB	43.5	47.9	55.0	63.2	68.7	75.3	81.3	80.5	75.4	65.0	58.0	47.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.6	60.6	67.2	72.8	77.1	82.3	85.9	84.5	82.5	74.7	68.7	56.5
		MCDB	58.3	68.6	74.9	80.9	86.1	91.5	94.6	94.5	90.4	81.2	72.3	58.7
	2%	WB	49.3	55.3	62.7	70.1	74.9	80.3	84.1	83.0	80.6	71.9	64.2	53.0
		MCDB	52.7	60.8	70.9	77.2	82.9	88.4	93.2	92.8	87.1	78.3	68.3	55.8
	5%	WB	46.4	51.9	59.4	67.5	73.3	78.9	83.0	82.0	79.0	69.5	61.6	50.3
		MCDB	49.7	56.1	65.6	74.8	79.9	85.8	92.1	91.5	84.9	74.2	65.9	53.9
	10%	WB	43.9	49.0	56.7	65.2	71.7	77.5	81.9	81.2	77.4	67.7	58.9	47.9
		MCDB	47.5	53.3	62.9	72.3	78.0	83.4	90.9	89.8	82.7	72.2	64.1	51.5
Mean Daily Temperature Range	5% DB	MDBR	11.1	11.9	14.1	15.1	15.0	12.2	12.6	12.1	12.3	13.4	13.8	12.3
		MCDBR	18.7	21.0	22.6	22.8	21.3	17.5	16.3	15.9	15.3	18.0	19.7	18.2
		MCWBR	11.3	12.0	11.4	10.1	7.6	6.1	5.0	5.0	5.4	6.9	9.3	10.4
	5% WB	MCDBR	15.3	17.2	19.0	18.0	15.6	13.4	15.3	14.9	13.3	13.3	13.6	13.0
		MCWBR	10.2	11.2	10.9	10.1	7.4	5.9	5.9	5.3	5.3	6.5	7.6	8.6
Clear-Sky Solar Irradiance	taub	0.612	0.664	0.695	0.698	0.676	0.723	0.675	0.692	0.678	0.661	0.626	0.595	
	taud	1.620	1.553	1.526	1.568	1.645	1.592	1.718	1.666	1.656	1.620	1.638	1.655	
	Ebn at Noon	184	191	199	207	213	203	212	206	200	189	179	180	
	Edh at Noon	69	80	88	87	81	85	75	78	76	74	67	63	
All-Sky Solar Radiation	RadAvg	684	789	1120	1333	1439	1330	1571	1415	1182	1020	782	685	
	RadStd	106	178	99	156	158	171	194	196	129	160	109	118	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	+0.52	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page