

LIYANG, China

WMO: 583450

Lat: 31.4309N

Lon: 119.5000E

Elev: 8

StdP: 101.23

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -3.2	(c) -1.9	(d) -12.1	(e) 1.3	(f) 1.7	(g) -9.8	(h) 1.6	(i) 2.2	(j) 6.7	(k) 6.1	(l) 5.9	(m) 5.5	(n) 1.1	(o) 20	(p) 0.362

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 6.7	(c) 36.1	(d) 27.2	(e) 34.8	(f) 27.0	(g) 33.6	(h) 26.7	(i) 28.5	(j) 33.2	(k) 27.9	(l) 32.6	(m) 27.5	(n) 31.9	(o) 2.6	(p) 250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.3	23.2	31.1	26.8	22.4	30.6	26.3	21.7	30.2	92.4	33.3	89.7	32.6	87.5	32.1	31.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 6.2	(b) 5.3	(c) 4.6	(e) -5.2	(f) 37.7	(g) 1.4	(h) 1.0	(i) -6.2	(j) 38.5	(k) -7.0	(l) 39.1	(m) -7.7	(n) 39.7	(o) -8.7	(p) 40.4		
(a) 6.2	(b) 5.3	(c) 4.6	(e) -6.4	(f) 29.4	(g) 1.7	(h) 0.8	(i) -7.6	(j) 30.0	(k) -8.5	(l) 30.5	(m) -9.5	(n) 30.9	(o) -10.7	(p) 31.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.0	3.9	5.9	10.6	16.4	21.8	25.2	29.2	28.6	24.2	18.8	12.4	6.3
	DBStd	9.22	3.16	3.61	3.92	3.69	2.90	2.70	2.77	2.65	2.81	2.88	3.75	3.19
	HDD10.0	492	191	122	39	2	0	0	0	0	0	0	17	121
	HDD18.3	1703	448	348	241	79	5	0	0	0	0	29	179	373
	CDD10.0	3043	1	8	58	194	364	455	594	576	426	271	90	6
	CDD18.3	1213	0	0	2	21	111	205	336	318	176	42	3	0
	CDH23.3	12255	0	1	17	171	796	1749	4284	3808	1267	153	9	0
	CDH26.7	5206	0	0	3	44	251	617	2165	1741	364	21	1	0
Wind	WSAvg	2.0	1.9	2.2	2.4	2.2	2.1	2.0	1.9	2.1	1.9	1.7	1.7	1.8
Precipitation	PrecAvg	1144	39	60	87	111	108	173	158	126	118	73	60	33
	PrecMax	1542	99	119	162	203	243	391	456	443	282	248	178	111
	PrecMin	626	8	9	27	31	32	45	27	12	31	1	3	0
	PrecStd	206	22	32	37	49	50	74	117	97	69	64	44	29
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.3	19.7	25.4	31.0	33.9	35.2	37.6	37.8	34.5	29.0	24.7	17.2
		MCWB	10.0	13.0	16.3	19.8	21.4	26.6	27.3	27.3	26.5	22.1	17.4	11.3
	2%	DB	12.5	16.0	21.8	27.6	31.3	33.3	36.5	35.7	31.8	26.5	21.9	14.5
		MCWB	8.4	11.3	15.0	19.0	21.0	25.1	27.2	27.4	26.0	20.3	16.5	10.9
	5%	DB	10.3	13.6	19.4	25.0	29.4	31.7	35.4	34.4	30.2	24.9	19.9	12.7
		MCWB	7.3	9.4	13.7	17.8	20.5	24.3	27.2	27.3	25.1	19.2	15.5	9.5
	10%	DB	8.6	11.4	17.0	22.7	27.6	30.1	34.2	33.1	28.7	23.5	18.2	11.2
		MCWB	6.4	8.4	12.3	16.8	19.9	23.9	27.1	27.1	24.0	18.5	14.7	8.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.1	14.8	18.3	22.6	25.0	27.6	29.4	29.1	28.0	23.9	20.3	14.0
		MCDB	14.3	18.3	22.6	26.6	30.8	32.5	34.0	34.0	32.2	26.4	21.9	15.2
	2%	WB	9.4	12.1	16.2	20.8	23.6	26.7	28.7	28.4	27.0	22.2	18.0	11.8
		MCDB	11.1	15.2	20.3	25.1	27.5	31.4	33.4	33.1	30.4	24.9	20.2	13.4
	5%	WB	7.9	10.4	14.7	19.4	22.6	25.9	28.1	27.9	26.2	20.9	16.6	10.3
		MCDB	9.7	12.5	18.0	23.2	26.1	29.9	32.8	32.5	29.2	23.4	18.6	11.8
	10%	WB	6.6	8.8	13.1	18.0	21.6	25.1	27.6	27.4	25.2	19.8	15.1	9.0
		MCDB	8.4	10.9	16.1	21.7	25.0	28.4	32.3	31.7	27.9	22.2	17.6	10.8
Mean Daily Temperature Range	5% DB	MDBR	6.3	6.6	7.7	8.5	8.4	6.6	6.7	6.3	6.6	7.4	7.8	7.1
		MCDBR	10.3	11.6	12.4	12.9	12.1	9.4	8.5	8.3	7.9	9.5	10.7	10.1
		MCWBR	6.5	6.8	6.5	5.9	4.4	3.4	2.6	2.6	2.9	3.9	5.2	6.0
	5% WB	MCDBR	8.4	9.3	10.4	10.2	8.4	7.4	7.6	7.4	7.1	7.1	7.6	7.2
MCWBR		5.8	6.3	6.3	5.8	4.3	3.3	2.9	2.8	3.0	3.8	4.5	5.1	
Clear-Sky Solar Irradiance	taub	0.620	0.671	0.699	0.704	0.689	0.751	0.706	0.704	0.679	0.670	0.644	0.609	
	taud	1.611	1.541	1.520	1.559	1.623	1.546	1.659	1.647	1.662	1.613	1.621	1.643	
	Ebn at Noon	572	595	623	647	663	621	647	640	631	588	549	552	
	Edh at Noon	217	255	277	276	261	281	250	250	237	233	213	201	
All-Sky Solar Radiation	RadAvg	2.19	2.54	3.61	4.29	4.61	4.20	4.95	4.59	3.80	3.25	2.46	2.15	
	RadStd	0.31	0.51	0.31	0.49	0.49	0.58	0.59	0.63	0.40	0.49	0.33	0.34	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only		+0.32	N/A	N/A	N/A	N/A	-0.36	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		+0.31	N/A	N/A	+0.52	N/A	N/A	N/A	N/A	+85	N/A

Nomenclature: See separate page