

ANQING, China

WMO: 584240

Lat: 30.6231N

Lon: 116.9673E

Elev: 203

StdP: 14.59

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 28.2	(c) 30.3	(d) 11.0	(e) 9.7	(f) 36.2	(g) 15.3	(h) 12.0	(i) 37.0	(j) 19.4	(k) 39.1	(l) 17.8	(m) 38.8	(n) 6.5	(o) 40	(p) 0.402

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 10.6	(c) 96.2	(d) 81.1	(e) 94.3	(f) 80.9	(g) 92.4	(h) 80.3	(i) 83.4	(j) 91.7	(k) 82.5	(l) 90.7	(m) 81.7	(n) 89.6	(o) 8.7	(p) 220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.3	164.0	88.3	80.4	158.9	87.6	79.5	154.3	86.9	47.7	91.4	46.7	90.9	45.8	89.9	86.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 18.0	(b) 15.7	(c) 13.9	(e) 25.0	(f) 99.2	(g) 3.1	(h) 2.0	(i) 22.8	(j) 100.6	(k) 21.0	(l) 101.8	(m) 19.2	(n) 102.9	(o) 17.0	(p) 104.3		
(a) 18.0	(b) 15.7	(c) 13.9	(e) 22.1	(f) 84.4	(g) 2.8	(h) 1.3	(i) 20.0	(j) 85.4	(k) 18.4	(l) 86.1	(m) 16.8	(n) 86.8	(o) 14.7	(p) 87.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	63.9	40.3	44.6	53.1	64.0	73.1	78.6	85.1	83.8	76.5	66.8	55.4	44.4
	DBStd	16.44	5.75	7.33	7.54	6.76	5.24	4.73	4.99	4.93	5.37	5.71	7.04	5.76
	HDD50	755	303	182	52	2	0	0	0	0	0	0	28	188
	HDD65	2795	764	572	374	97	5	0	0	0	1	47	296	639
	CDD50	5834	4	30	150	421	715	858	1088	1048	796	521	189	14
	CDD65	2398	0	0	6	66	255	408	623	583	347	103	7	0
	CDH74	24310	0	2	38	361	1757	3749	8107	7121	2729	423	23	0
	CDH80	10389	0	0	4	65	502	1318	4194	3355	874	76	1	0
Wind	WSAvg	6.5	6.7	7.0	7.0	6.7	6.0	6.1	6.5	6.5	6.9	6.5	6.1	6.3
Precipitation	PrecAvg	51.0	1.8	2.4	3.7	4.8	5.5	8.3	8.7	6.4	3.3	2.2	2.3	1.3
	PrecMax	68.7	3.9	5.8	8.0	8.0	9.3	15.5	18.1	10.9	10.7	6.7	5.4	3.9
	PrecMin	36.5	0.4	0.8	1.5	1.4	1.8	3.9	3.7	2.6	0.1	0.2	0.0	0.1
	PrecStd	8.1	1.0	1.2	1.6	1.7	1.8	3.0	3.7	1.9	2.2	1.5	1.5	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	61.0	69.6	78.8	86.2	91.3	94.4	98.9	98.4	94.2	86.1	77.2	63.0
		MCWB	51.4	58.5	66.1	70.8	73.3	79.6	81.2	80.8	80.0	72.6	63.4	52.0
	2%	DB	55.8	63.5	72.9	81.5	88.4	91.7	96.8	95.9	90.7	81.9	72.3	58.7
		MCWB	47.4	53.4	61.5	68.2	72.1	78.5	81.2	81.4	78.4	68.9	60.5	50.0
	5%	DB	52.0	59.3	68.6	78.3	85.3	89.2	95.1	93.9	87.7	78.4	68.6	55.7
		MCWB	45.7	51.4	58.6	66.4	70.9	77.2	81.1	81.2	77.0	67.0	59.4	48.8
	10%	DB	49.2	55.5	64.9	74.8	82.5	86.9	93.2	91.9	84.9	75.6	65.4	52.9
		MCWB	43.7	49.1	56.3	64.3	69.9	76.5	80.9	80.6	75.8	65.1	58.2	46.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.9	60.5	69.5	74.3	78.5	82.3	84.6	84.6	82.5	75.5	67.6	56.0
		MCDB	57.7	66.6	77.2	80.4	86.1	90.4	93.3	92.4	90.3	81.0	72.1	59.2
	2%	WB	49.5	56.2	64.1	71.5	76.3	80.7	83.5	83.4	80.8	72.4	64.3	52.6
		MCDB	53.1	60.8	69.0	78.0	82.2	88.4	92.2	91.3	87.9	78.8	68.5	56.6
	5%	WB	46.6	52.8	60.7	69.0	74.3	79.6	82.7	82.5	79.3	69.9	61.6	50.0
		MCDB	50.9	57.3	67.2	75.1	80.5	86.4	91.2	90.5	85.6	75.6	66.5	54.3
	10%	WB	44.3	49.8	57.8	66.9	72.7	78.5	81.9	81.6	77.6	67.9	59.0	47.8
		MCDB	48.1	54.7	63.0	72.5	79.1	84.5	90.2	89.4	83.4	73.0	64.9	51.5
Mean Daily Temperature Range	5% DB	MDBR	9.5	10.2	12.1	12.9	12.6	10.6	10.6	10.6	10.9	11.6	11.6	10.6
		MCDBR	16.0	17.4	18.7	18.4	17.6	14.3	13.2	13.5	14.1	16.6	17.3	15.8
		MCWBR	9.3	9.6	9.5	8.4	6.3	4.9	4.2	4.5	4.7	6.0	7.6	8.6
	5% WB	MCDBR	13.0	14.3	15.7	15.1	12.6	11.8	12.6	12.6	12.1	12.9	13.2	12.7
	MCWBR	8.3	9.6	9.7	8.8	6.3	4.9	4.6	4.9	4.9	6.1	7.1	8.0	
Clear-Sky Solar Irradiance	taub	0.612	0.668	0.703	0.703	0.673	0.697	0.646	0.688	0.677	0.660	0.617	0.588	
	taud	1.612	1.546	1.514	1.565	1.657	1.646	1.779	1.671	1.662	1.621	1.649	1.667	
	Ebn at Noon	186	191	198	206	214	208	218	207	201	190	183	183	
	Edh at Noon	69	81	89	87	80	81	70	78	75	74	66	63	
All-Sky Solar Radiation	RadAvg	668	761	1077	1284	1401	1305	1562	1405	1214	1006	794	681	
	RadStd	107	195	87	143	142	149	191	178	129	141	110	124	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	-1.31	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page