

ANQING, China

WMO: 584240

Lat: 30.6231N

Lon: 116.9673E

Elev: 62

StdP: 100.58

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.1	-0.9	-11.6	1.4	2.3	-9.3	1.7	2.8	8.7	3.9	8.0	3.8	2.9	40	0.402

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.9	35.7	27.3	34.6	27.2	33.6	26.8	28.5	33.1	28.1	32.6	27.6	32.0	3.9	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.4	23.4	31.3	26.9	22.7	30.9	26.4	22.0	30.5	93.1	33.0	90.7	32.7	88.6	32.2	30.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.0	7.0	6.2	-3.9	37.3	1.7	1.1	-5.1	38.1	-6.1	38.8	-7.1	39.4	-8.3	40.2		
			-5.5	29.1	1.6	0.7	-6.7	29.6	-7.6	30.1	-8.5	30.5	-9.6	31.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.7	4.6	7.0	11.7	17.8	22.8	25.9	29.5	28.8	24.7	19.3	13.0	6.9
	DBStd	9.14	3.20	4.07	4.19	3.76	2.91	2.63	2.77	2.74	2.98	3.17	3.91	3.20
	HDD10.0	419	168	101	29	1	0	0	0	0	0	0	16	104
	HDD18.3	1553	424	318	208	54	3	0	0	0	1	26	164	355
	CDD10.0	3241	2	17	83	234	397	477	604	582	442	289	105	8
	CDD18.3	1332	0	0	3	37	142	227	346	324	193	57	4	0
	CDH23.3	13506	0	1	21	201	976	2083	4504	3956	1516	235	13	0
CDH26.7	5772	0	0	2	36	279	732	2330	1864	486	42	1	0	
Wind	WSAvg	2.9	3.0	3.1	3.1	3.0	2.7	2.7	2.9	2.9	3.1	2.9	2.7	2.8
Precipitation	PrecAvg	1295	45	62	95	123	140	212	221	163	84	56	59	34
	PrecMax	1744	99	148	203	203	236	394	461	276	272	169	137	99
	PrecMin	926	11	20	38	36	45	100	94	67	3	4	1	2
	PrecStd	205	25	30	41	42	45	77	93	48	55	37	38	25
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.1	20.9	26.0	30.1	33.0	34.7	37.2	36.9	34.6	30.1	25.1	17.2
		MCWB	10.8	14.7	19.0	21.5	23.0	26.5	27.4	27.1	26.7	22.5	17.4	11.1
	2%	DB	13.2	17.5	22.7	27.5	31.3	33.2	36.0	35.5	32.6	27.7	22.4	14.8
		MCWB	8.6	11.9	16.4	20.1	22.3	25.8	27.3	27.5	25.8	20.5	15.8	10.0
	5%	DB	11.1	15.2	20.3	25.7	29.6	31.8	35.1	34.4	31.0	25.8	20.4	13.2
		MCWB	7.6	10.8	14.8	19.1	21.6	25.1	27.3	27.3	25.0	19.4	15.2	9.3
	10%	DB	9.5	13.0	18.3	23.8	28.1	30.5	34.0	33.3	29.4	24.2	18.6	11.6
		MCWB	6.5	9.5	13.5	18.0	21.1	24.7	27.1	27.0	24.3	18.4	14.5	8.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.2	15.8	20.9	23.5	25.9	28.0	29.2	29.2	28.1	24.2	19.8	13.3
		MCDB	14.3	19.2	25.1	26.9	30.0	32.5	34.1	33.5	32.4	27.2	22.3	15.1
	2%	WB	9.7	13.5	17.8	22.0	24.6	27.1	28.6	28.6	27.1	22.4	17.9	11.5
		MCDB	11.7	16.0	20.6	25.5	27.9	31.3	33.5	32.9	31.1	26.0	20.3	13.6
	5%	WB	8.1	11.6	15.9	20.5	23.5	26.4	28.2	28.0	26.3	21.0	16.5	10.0
		MCDB	10.5	14.1	19.6	24.0	27.0	30.2	32.9	32.5	29.8	24.2	19.1	12.4
	10%	WB	6.8	9.9	14.4	19.4	22.6	25.8	27.7	27.6	25.3	19.9	15.0	8.8
		MCDB	8.9	12.6	17.2	22.5	26.1	29.2	32.3	31.9	28.5	22.8	18.3	10.8
Mean Daily Temperature Range	5% DB	MDBR	5.3	5.7	6.7	7.1	7.0	5.9	5.9	5.9	6.0	6.5	6.5	5.9
		MCDBR	8.9	9.6	10.4	10.2	9.8	7.9	7.3	7.5	7.8	9.2	9.6	8.8
		MCWBR	5.2	5.3	5.3	4.7	3.5	2.7	2.3	2.5	2.6	3.3	4.2	4.8
	5% WB	MCDBR	7.2	8.0	8.7	8.4	7.0	6.6	7.0	7.0	6.7	7.2	7.3	7.1
		MCWBR	4.6	5.3	5.4	4.9	3.5	2.7	2.6	2.7	2.7	3.4	3.9	4.4
Clear-Sky Solar Irradiance	taub	0.612	0.668	0.703	0.703	0.673	0.697	0.646	0.688	0.677	0.660	0.617	0.588	
	taud	1.612	1.546	1.514	1.565	1.657	1.646	1.779	1.671	1.662	1.621	1.649	1.667	
	Ebn at Noon	585	602	623	650	675	657	688	652	635	599	577	577	
	Edh at Noon	219	255	280	275	252	254	222	245	238	233	209	198	
All-Sky Solar Radiation	RadAvg	2.11	2.40	3.39	4.05	4.42	4.11	4.92	4.43	3.83	3.17	2.50	2.15	
	RadStd	0.34	0.61	0.28	0.45	0.45	0.47	0.60	0.56	0.41	0.45	0.35	0.39	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page