

SHENGSI, China

WMO: 584720

Lat: 30.7316N

Lon: 122.4493E

Elev: 197

StdP: 14.59

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	31.4	33.7	14.4	11.5	35.5	18.2	13.8	36.6	35.4	42.1	32.5	42.1	19.1	340	0.620

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.0	89.0	79.7	87.1	79.3	85.4	78.9	81.3	86.0	80.4	84.8	79.7	83.9	9.8	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.0	156.9	84.0	79.2	152.5	83.2	78.4	148.8	82.6	45.3	86.2	44.3	85.1	43.5	84.0	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
34.3	30.7	27.7	DB	28.8	92.8	3.7	2.5	26.1	94.6	23.9	96.1	21.8	97.5	19.1	99.3
			WB	24.3	82.7	3.3	1.3	21.9	83.6	19.9	84.4	18.0	85.2	15.6	86.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	62.4	43.0	44.3	49.8	57.9	66.4	72.8	80.4	81.2	76.1	68.5	59.3	48.4
	DBStd	14.12	5.81	5.57	5.40	5.11	3.93	4.10	3.67	2.81	3.68	4.05	5.89	6.46
	HDD50	590	229	174	70	4	0	0	0	0	0	7	106	
	HDD65	2700	683	580	472	221	30	0	0	0	15	185	514	
	CDD50	5129	11	14	63	240	508	684	943	968	782	574	285	57
	CDD65	1764	0	0	0	7	73	234	478	503	332	124	13	0
	CDH74	12744	0	0	1	16	88	898	4633	5087	1874	145	2	0
	CDH80	3008	0	0	0	1	4	152	1251	1334	261	5	0	0
Wind	WSAvg	14.5	15.4	14.9	15.0	14.6	13.7	12.2	14.4	14.1	14.9	14.5	15.3	
Precipitation	PrecAvg	38.9	1.8	2.5	3.4	4.2	4.2	5.1	3.0	3.3	5.0	2.6	2.2	1.6
	PrecMax	55.0	4.8	6.3	7.8	9.0	8.0	12.0	10.7	12.1	12.9	8.5	5.2	5.4
	PrecMin	23.7	0.2	0.7	0.6	1.5	1.5	0.9	0.0	0.1	0.6	0.0	0.0	0.0
	PrecStd	7.6	1.0	1.5	1.9	1.7	1.5	2.5	2.4	2.7	3.1	2.3	1.5	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	61.0	64.2	68.4	76.2	79.9	87.8	92.1	92.1	87.7	80.1	73.4	64.8
		MCWB	58.2	56.0	57.9	65.6	69.2	78.7	79.9	80.7	79.6	74.9	66.9	61.5
	2%	DB	56.9	58.6	63.1	70.8	76.4	84.0	89.5	88.8	84.8	77.4	70.8	61.9
		MCWB	53.6	54.9	56.4	63.2	67.4	77.0	79.6	80.1	78.3	72.5	66.5	57.9
	5%	DB	54.0	55.2	60.3	67.6	73.9	81.2	87.4	87.1	83.0	75.4	68.9	59.3
		MCWB	50.7	52.0	55.5	62.4	67.2	75.5	79.2	79.6	77.2	70.4	64.4	55.2
	10%	DB	50.9	52.0	57.5	65.1	72.0	78.7	85.6	85.5	81.0	73.8	66.9	57.0
		MCWB	47.2	48.4	53.5	60.7	66.3	74.2	78.7	79.2	76.2	68.5	62.6	53.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.0	58.9	61.5	68.2	72.7	79.4	82.6	82.6	80.9	77.0	69.2	63.1
		MCDB	61.3	62.7	64.3	72.0	76.2	85.5	88.5	87.9	85.7	79.1	71.4	64.1
	2%	WB	54.5	55.6	58.3	65.7	70.9	77.8	81.1	81.5	79.3	74.1	67.7	58.9
		MCDB	56.3	58.0	60.9	68.7	73.6	82.8	86.1	86.1	83.1	76.2	70.0	61.0
	5%	WB	50.9	52.3	56.2	63.6	69.6	76.3	80.2	80.7	78.3	71.7	65.6	56.2
		MCDB	53.2	54.7	59.3	66.4	72.1	80.1	84.8	85.0	81.7	74.4	67.8	58.7
	10%	WB	47.9	49.3	54.0	61.4	68.2	75.0	79.5	80.0	77.3	69.7	63.5	53.5
		MCDB	50.3	51.5	57.2	64.3	70.5	78.0	83.9	84.0	80.5	73.1	66.3	56.4
Mean Daily Temperature Range	5% DB	MDBR	6.6	7.3	7.8	8.4	7.9	6.6	7.4	7.0	6.1	6.1	6.5	6.7
		MCDBR	9.8	12.0	12.2	11.9	10.6	10.0	10.6	9.4	8.0	7.3	7.5	8.5
		MCWBR	8.4	9.5	8.3	7.7	6.7	5.1	4.6	4.0	4.1	5.1	5.5	7.8
	5% WB	MCDBR	9.2	11.3	10.9	10.3	8.6	9.1	9.0	8.3	7.3	6.7	6.6	7.7
		MCWBR	8.8	9.9	8.6	7.6	6.4	5.0	4.4	4.0	4.2	5.8	5.9	8.0
Clear-Sky Solar Irradiance	taub	0.554	0.594	0.634	0.640	0.621	0.663	0.620	0.594	0.558	0.536	0.552	0.538	
	taud	1.762	1.706	1.656	1.701	1.786	1.762	1.884	1.947	1.984	1.926	1.823	1.793	
	Ebn at Noon	203	210	214	220	226	215	224	228	231	224	202	199	
	Edh at Noon	60	69	77	76	70	72	63	59	55	54	56	55	
All-Sky Solar Radiation	RadAvg	655	809	1142	1348	1474	1309	1768	1689	1337	1093	757	642	
	RadStd	83	158	92	144	154	176	205	192	137	135	99	98	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page