

DINGHAI, China

WMO: 584770

Lat: 30.0352N

Lon: 122.1070E

Elev: 121

StdP: 14.63

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.7	32.9	13.7	11.1	37.4	17.6	13.4	38.9	18.7	41.8	16.6	41.2	5.0	320	0.372

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.7	92.1	80.8	89.8	79.9	88.0	79.2	82.2	88.7	81.2	87.1	80.3	85.8	6.2	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.7	159.9	85.7	79.7	154.6	84.8	78.8	150.2	84.0	46.2	89.2	45.1	87.0	44.2	86.0	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
17.6	15.2	13.3	DB	27.4	97.0	2.5	3.7	25.6	99.6	24.1	101.8	22.7	103.8	20.8	106.5
			WB	24.4	83.6	2.8	1.5	22.3	84.7	20.7	85.5	19.1	86.3	17.0	87.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.3	43.6	45.1	51.0	59.6	68.0	74.6	82.2	82.7	76.6	68.2	58.8	48.3	(6)
	DBStd	14.53	6.13	6.19	6.14	5.75	4.24	4.45	3.57	2.96	4.33	4.58	6.12	6.31	(7)
	HDD50	554	217	160	61	3	0	0	0	0	0	0	7	106	(8)
	HDD65	2592	665	556	435	180	18	0	0	0	0	20	201	517	(9)
	CDD50	5419	17	24	92	290	558	737	999	1014	797	566	270	55	(10)
	CDD65	1981	0	0	1	17	111	287	534	549	347	121	14	0	(11)
	CDH74	16677	0	1	4	50	330	1623	5789	6085	2452	325	18	0	(12)
	CDH80	5240	0	0	0	6	36	359	2084	2172	557	26	0	0	(13)
(14) Wind	WSAvg	6.1	6.2	6.1	6.2	6.0	5.8	5.1	6.5	6.8	6.3	5.8	5.7	6.1	(14)
(15) Precipitation	PrecAvg	52.0	2.3	3.0	4.1	4.6	5.6	6.7	4.4	6.0	7.0	3.5	3.0	1.9	(15)
	PrecMax	77.8	7.1	6.0	8.1	8.7	12.2	14.3	11.0	20.9	17.0	8.9	7.2	6.1	(16)
	PrecMin	23.8	0.0	0.7	1.1	2.0	2.0	1.5	0.0	0.1	0.3	0.1	0.2	0.0	(17)
	PrecStd	10.6	1.7	1.6	1.9	1.6	2.3	3.3	3.0	4.5	4.7	2.7	1.9	1.5	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.7	69.0	72.8	79.3	84.0	90.2	97.2	95.8	90.7	83.1	76.5	67.1	(19)
		MCWB	59.6	59.9	60.0	67.1	71.0	80.4	81.8	81.5	79.5	74.4	68.3	61.8	(20)
	2%	DB	59.8	61.8	67.4	74.5	80.0	86.9	93.0	91.8	87.5	79.8	72.9	63.2	(21)
		MCWB	54.9	56.1	58.1	65.1	69.3	78.7	81.2	80.4	78.1	71.8	66.3	57.3	(22)
	5%	DB	56.0	57.8	63.5	71.3	77.5	84.2	90.1	89.8	85.3	77.4	70.3	60.3	(23)
		MCWB	51.6	53.4	56.5	63.5	68.1	77.1	80.3	79.7	76.7	70.0	64.5	55.5	(24)
	10%	DB	52.4	54.5	60.4	68.6	75.3	81.4	88.0	88.1	83.2	75.5	67.7	57.6	(25)
		MCWB	48.2	49.9	55.1	62.3	67.5	75.5	79.6	79.2	75.8	68.5	62.7	53.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.1	61.5	63.6	70.9	75.3	82.0	84.0	83.3	81.4	77.6	70.6	64.5	(27)
		MCDB	63.8	67.0	68.8	75.4	80.5	88.8	92.5	90.5	87.6	80.6	74.3	66.8	(28)
	2%	WB	56.3	57.6	60.5	68.2	73.2	79.7	82.5	82.1	79.8	74.6	68.3	59.5	(29)
		MCDB	58.9	60.5	63.8	71.5	76.4	85.2	89.9	87.7	84.8	77.5	71.6	61.6	(30)
	5%	WB	52.2	54.0	58.3	66.1	71.6	78.1	81.3	81.3	78.7	72.1	66.1	56.7	(31)
		MCDB	55.0	56.9	62.2	69.6	74.8	82.6	87.7	86.8	82.8	75.8	68.3	59.5	(32)
	10%	WB	48.9	50.9	55.8	63.7	70.1	76.7	80.4	80.4	77.5	70.0	63.8	53.7	(33)
		MCDB	51.5	53.9	59.6	67.4	73.1	80.3	86.0	85.9	82.0	74.1	67.0	56.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	10.1	10.7	12.1	12.9	12.0	9.8	10.4	9.7	9.7	10.7	10.8	10.9	(35)
		MCDBR	15.7	16.8	17.9	17.4	15.9	13.4	14.6	12.6	11.9	12.9	13.7	14.8	(36)
	5% WB	MCWBR	10.6	10.7	9.9	9.1	8.0	6.4	5.3	4.2	4.5	6.1	7.2	9.5	(37)
		MCWBR	12.6	14.1	14.6	13.2	11.3	11.7	12.7	11.3	10.0	9.7	9.4	11.3	(38)
(40) Clear-Sky Solar Irradiance	taub		0.573	0.611	0.654	0.663	0.636	0.660	0.615	0.609	0.580	0.558	0.564	0.554	(40)
		taud	1.726	1.672	1.619	1.657	1.758	1.761	1.888	1.891	1.920	1.872	1.800	1.766	(41)
	Ebn at Noon		199	207	210	215	223	216	226	225	226	219	200	196	(42)
		Edh at Noon	62	72	80	80	72	72	63	62	59	58	57	57	(43)
(44) All-Sky Solar Radiation	RadAvg		677	811	1127	1329	1440	1310	1816	1657	1300	1098	764	675	(44)
	RadStd		99	173	95	147	165	174	198	176	143	143	104	110	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	+1.10	N/A	N/A	N/A	N/A	+140	+106
(47) Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+142	+92

Nomenclature: See separate page