

DINGHAI, China

WMO: 584770

Lat: 30.0352N

Lon: 122.1070E

Elev: 37

StdP: 100.88

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.7	0.5	-10.1	1.6	3.0	-8.0	1.9	3.8	8.4	5.4	7.4	5.1	2.3	320	0.372

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.4	33.4	27.1	32.1	26.6	31.1	26.2	27.9	31.5	27.3	30.6	26.9	29.9	2.8	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.0	22.8	29.8	26.5	22.1	29.3	26.0	21.5	28.9	89.7	31.8	87.1	30.6	85.0	30.0	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.9	6.8	5.9	-2.6	36.1	1.4	2.0	-3.6	37.6	-4.4	38.8	-5.2	39.9	-6.2	41.4		
			-4.2	28.7	1.6	0.8	-5.4	29.3	-6.3	29.7	-7.2	30.2	-8.3	30.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.4	6.4	7.3	10.5	15.3	20.0	23.6	27.9	28.2	24.8	20.1	14.9	9.1
	DBStd	8.07	3.40	3.44	3.41	3.20	2.35	2.47	1.98	1.64	2.41	2.54	3.40	3.51
	HDD10.0	308	121	89	34	2	0	0	0	0	0	0	4	59
	HDD18.3	1440	369	309	242	100	10	0	0	0	0	11	112	287
	CDD10.0	3011	9	13	51	161	310	409	555	563	443	314	150	31
	CDD18.3	1101	0	0	1	9	62	159	297	305	193	67	8	0
	CDH23.3	9265	0	1	2	28	183	902	3216	3381	1362	181	10	0
	CDH26.7	2911	0	0	0	3	20	199	1158	1207	309	14	0	0
Wind	WSAvg	2.7	2.8	2.7	2.8	2.7	2.6	2.3	2.9	3.1	2.8	2.6	2.5	2.7
Precipitation	PrecAvg	1321	58	77	103	116	142	169	112	153	178	89	75	49
	PrecMax	1977	181	152	207	222	310	362	280	532	432	226	182	156
	PrecMin	604	0	18	27	52	52	37	1	3	8	2	5	0
	PrecStd	270	42	41	49	40	58	83	75	115	120	68	48	38
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.2	20.5	22.6	26.3	28.9	32.3	36.2	35.4	32.6	28.4	24.7	19.5
		MCWB	15.3	15.5	15.6	19.5	21.7	26.9	27.7	27.5	26.4	23.6	20.2	16.5
	2%	DB	15.4	16.6	19.7	23.6	26.7	30.5	33.9	33.2	30.8	26.5	22.7	17.3
		MCWB	12.7	13.4	14.5	18.4	20.7	26.0	27.3	26.9	25.6	22.1	19.1	14.1
	5%	DB	13.3	14.4	17.5	21.8	25.3	29.0	32.3	32.1	29.6	25.2	21.3	15.7
		MCWB	10.9	11.9	13.6	17.5	20.1	25.1	26.8	26.5	24.9	21.1	18.1	13.0
	10%	DB	11.3	12.5	15.8	20.3	24.1	27.4	31.1	31.2	28.4	24.1	19.8	14.2
		MCWB	9.0	10.0	12.8	16.8	19.7	24.1	26.5	26.2	24.3	20.3	17.0	11.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.2	16.4	17.5	21.6	24.1	27.8	28.9	28.5	27.4	25.3	21.5	18.1
		MCDB	17.7	19.5	20.5	24.1	26.9	31.6	33.6	32.5	30.9	27.0	23.5	19.3
	2%	WB	13.5	14.2	15.8	20.1	22.9	26.5	28.0	27.8	26.6	23.7	20.2	15.3
		MCDB	14.9	15.8	17.7	21.9	24.7	29.6	32.2	31.0	29.4	25.3	22.0	16.4
	5%	WB	11.2	12.2	14.6	19.0	22.0	25.6	27.4	27.4	25.9	22.3	19.0	13.7
		MCDB	12.8	13.9	16.8	20.9	23.8	28.1	30.9	30.5	28.2	24.3	20.2	15.3
	10%	WB	9.4	10.5	13.2	17.6	21.2	24.8	26.9	26.9	25.3	21.1	17.7	12.0
		MCDB	10.8	12.1	15.3	19.7	22.9	26.8	30.0	29.9	27.8	23.4	19.4	13.7
Mean Daily Temperature Range	5% DB	MDBR	5.6	6.0	6.7	7.2	6.7	5.4	5.8	5.4	5.4	6.0	6.0	6.1
		MCDBR	8.7	9.3	9.9	9.6	8.8	7.4	8.1	7.0	6.6	7.2	7.6	8.2
		MCWBR	5.9	5.9	5.5	5.0	4.4	3.5	3.0	2.3	2.5	3.4	4.0	5.3
	5% WB	MCDBR	7.0	7.8	8.1	7.3	6.3	6.5	7.1	6.3	5.6	5.4	5.2	6.3
		MCWBR	5.6	5.9	5.6	4.8	4.1	3.4	2.9	2.5	2.5	3.4	3.9	5.2
Clear-Sky Solar Irradiance	taub	0.573	0.611	0.654	0.663	0.636	0.660	0.615	0.609	0.580	0.558	0.564	0.554	
	taud	1.726	1.672	1.619	1.657	1.758	1.761	1.888	1.891	1.920	1.872	1.800	1.766	
	Ebn at Noon	628	651	662	679	702	682	711	710	712	689	632	617	
	Edh at Noon	197	226	253	252	228	227	199	197	185	182	181	181	
All-Sky Solar Radiation	RadAvg	2.13	2.56	3.55	4.19	4.54	4.13	5.72	5.22	4.10	3.46	2.41	2.13	
	RadStd	0.31	0.55	0.30	0.46	0.52	0.55	0.62	0.56	0.45	0.45	0.33	0.35	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+0.61	N/A	N/A	N/A	N/A	+78	+59
(47)	Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+79	+51

Nomenclature: See separate page