

JINGDEZHEN, China

WMO: 585270

Lat: 29.3358N

Lon: 117.1786E

Elev: 197

StdP: 14.59

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 30.1	(c) 32.1	(d) 13.3	(e) 10.9	(f) 40.9	(g) 18.2	(h) 13.9	(i) 41.1	(j) 12.0	(k) 43.6	(l) 9.9	(m) 42.6	(n) 2.5	(o) 20	(p) 0.333

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 13.1	(c) 97.4	(d) 79.8	(e) 95.7	(f) 79.4	(g) 93.9	(h) 79.0	(i) 82.1	(j) 92.4	(k) 81.3	(l) 91.3	(m) 80.6	(n) 90.1	(o) 4.6	(p) 220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.6	154.8	86.8	78.9	150.9	86.2	78.1	147.3	85.6	46.2	92.9	45.3	91.8	44.5	90.3	84.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 10.8	(b) 9.1	(c) 7.6	(e) 26.3	(f) 100.0	(g) 2.9	(h) 2.1	(i) 24.2	(j) 101.5	(k) 22.5	(l) 102.7	(m) 20.9	(n) 103.9	(o) 18.7	(p) 105.4		
(a) 10.8	(b) 9.1	(c) 7.6	(e) 24.0	(f) 83.4	(g) 3.0	(h) 1.0	(i) 21.9	(j) 84.1	(k) 20.1	(l) 84.7	(m) 18.4	(n) 85.3	(o) 16.2	(p) 86.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	65.9	43.7	48.0	55.2	65.6	73.9	79.0	85.3	84.8	78.8	69.6	58.2	47.5	(6)
(7)		DBStd	15.55	6.12	7.60	7.53	6.48	4.80	4.69	4.39	4.22	5.68	5.75	6.92	5.84	(7)
(8)		HDD50	497	214	120	33	1	0	0	0	0	0	0	13	116	(8)
(9)		HDD65	2311	661	477	316	68	2	0	0	0	0	23	222	542	(9)
(10)		CDD50	6297	17	64	193	470	740	869	1095	1080	864	607	259	39	(10)
(11)		CDD65	2639	0	1	12	87	278	419	630	615	414	165	18	0	(11)
(12)		CDH74	27834	0	13	106	594	2054	3942	8326	7703	4024	981	91	0	(12)
(13)		CDH80	12628	0	1	19	144	682	1558	4401	3857	1700	254	12	0	(13)
(14)	Wind	WSAvg	3.0	2.7	3.0	3.2	3.4	3.2	3.0	3.4	3.3	3.2	3.0	2.7	2.6	(14)
(15)	Precipitation	PrecAvg	66.7	2.5	4.8	6.9	9.3	10.2	10.6	7.4	4.2	3.4	3.1	2.4	1.9	(15)
(16)		PrecMax	89.1	6.2	11.1	14.2	21.3	22.3	20.7	29.5	20.8	8.3	15.0	7.4	7.1	(16)
(17)		PrecMin	44.3	0.0	0.9	2.5	3.4	4.6	3.9	0.5	0.7	0.1	0.0	0.0	0.0	(17)
(18)		PrecStd	12.5	1.5	2.6	2.6	4.0	4.3	4.3	5.9	4.2	2.2	3.3	1.9	1.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	67.1	75.6	82.8	87.9	92.6	95.1	99.8	100.0	97.1	90.9	81.4	68.6	(19)
MCWB			54.9	61.9	68.1	71.5	73.4	78.3	80.6	79.7	77.8	73.8	65.6	56.3	(20)	
2%		DB	61.3	69.9	76.6	84.2	89.7	93.0	97.6	97.6	94.5	86.1	76.4	63.6	(21)	
		MCWB	52.1	58.3	63.0	68.2	72.1	78.4	80.2	79.9	77.6	70.3	63.1	53.2	(22)	
5%		DB	57.0	64.6	71.9	80.7	86.9	90.7	95.9	95.8	91.8	82.7	72.7	60.0	(23)	
		MCWB	49.3	55.1	59.2	66.5	71.5	77.7	79.9	79.7	77.1	68.1	61.0	52.0	(24)	
10%		DB	53.2	60.0	67.3	77.1	83.9	88.3	94.1	93.6	88.9	79.6	68.8	56.8	(25)	
		MCWB	46.9	52.7	58.0	65.0	70.9	76.8	79.5	79.4	75.7	66.6	59.7	49.9	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.4	63.9	70.5	74.4	78.5	81.8	83.3	83.0	81.5	76.8	69.8	60.1	(27)
MCD B			63.9	72.5	80.0	82.7	86.1	90.8	93.7	94.0	92.1	85.7	75.2	63.6	(28)	
2%		WB	54.6	60.5	65.8	71.9	76.7	80.5	82.3	81.9	80.0	73.7	66.6	56.9	(29)	
		MCD B	59.4	67.6	72.4	78.9	84.0	89.2	92.7	92.5	89.6	81.6	71.8	60.7	(30)	
5%		WB	50.5	57.1	62.6	70.1	75.1	79.4	81.6	81.1	78.9	71.6	64.2	53.5	(31)	
		MCD B	54.6	62.4	69.0	75.9	81.5	87.3	91.5	91.2	87.9	79.0	69.6	57.8	(32)	
10%		WB	47.8	53.7	59.7	68.2	73.6	78.3	80.8	80.4	77.7	69.8	61.5	50.9	(33)	
		MCD B	52.0	58.3	65.0	73.3	79.5	85.3	90.3	89.9	86.0	76.8	66.8	54.6	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.0	13.1	14.2	15.2	14.8	12.2	13.1	13.8	14.8	15.6	15.1	14.2	(35)
MCDBR			20.6	21.7	22.9	22.1	20.8	16.6	16.3	17.0	17.9	20.2	21.3	20.7	(36)	
MCWBR			11.3	11.3	10.4	9.3	7.5	5.7	4.3	4.4	5.2	7.2	9.3	10.7	(37)	
5% WB		MCD BR	15.7	18.9	18.0	16.4	14.2	13.7	15.2	15.5	15.7	15.1	15.1	14.6	(38)	
		MCWBR	9.7	11.2	10.1	8.9	6.8	5.4	5.1	5.1	5.3	6.9	8.0	8.8	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.640	0.693	0.747	0.739	0.676	0.679	0.630	0.665	0.658	0.659	0.615	0.594	(40)	
taud		1.573	1.511	1.456	1.515	1.665	1.688	1.814	1.715	1.696	1.622	1.653	1.657	(41)		
Ebn at Noon		182	187	190	200	214	212	222	213	207	193	187	185	(42)		
Edh at Noon		74	85	95	92	80	77	68	75	74	75	67	65	(43)		
(44)	All-Sky Solar Radiation	RadAvg	662	756	1000	1202	1364	1268	1689	1532	1345	1104	829	718	(44)	
(45)		RadStd	119	203	89	148	158	167	176	165	107	144	133	143	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.81	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+283	+175
(47)	Regional (7 neighbors)	+0.54	N/A	N/A	+0.79	N/A	N/A	N/A	N/A	+202	N/A

Nomenclature: See separate page