

JINGDEZHEN, China

WMO: 585270

Lat: 29.3358N

Lon: 117.1786E

Elev: 60

StdP: 100.61

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.1	0.1	-10.4	1.6	4.9	-7.7	2.0	5.1	5.3	6.5	4.4	5.9	1.1	20	0.333

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.3	36.4	26.6	35.4	26.3	34.4	26.1	27.8	33.6	27.4	32.9	27.0	32.3	2.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.5	22.1	30.5	26.0	21.6	30.1	25.6	21.0	29.8	89.5	33.8	87.5	33.2	85.6	32.4	29.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.8	4.1	3.4	-3.2	37.8	1.6	1.2	-4.3	38.6	-5.3	39.3	-6.2	39.9	-7.4	40.8		
			-4.4	28.6	1.7	0.6	-5.6	29.0	-6.6	29.3	-7.6	29.6	-8.8	30.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.8	6.5	8.9	12.9	18.7	23.3	26.1	29.6	29.4	26.0	20.9	14.6	8.6
	DBStd	8.64	3.40	4.22	4.18	3.60	2.67	2.60	2.44	2.34	3.16	3.19	3.84	3.25
	HDD10.0	276	119	67	18	1	0	0	0	0	0	0	7	64
	HDD18.3	1284	367	265	176	38	1	0	0	0	0	13	123	301
	CDD10.0	3498	9	36	107	261	411	483	608	600	480	337	144	22
	CDD18.3	1466	0	1	7	48	154	233	350	342	230	92	10	0
	CDH23.3	15463	0	7	59	330	1141	2190	4626	4279	2236	545	51	0
Wind	WSAvg	7016	0	1	11	80	379	866	2445	2143	944	141	7	0
	WSAvg	1.4	1.2	1.3	1.4	1.5	1.4	1.3	1.5	1.5	1.4	1.3	1.2	1.2
	PrecAvg	1694	64	121	174	236	258	270	188	107	86	80	62	47
	PrecMax	2262	158	282	360	540	567	527	749	529	211	381	189	180
	PrecMin	1126	0	24	63	86	116	98	13	17	3	0	1	0
	PrecStd	317	38	66	66	101	110	109	150	107	57	83	47	45
	PrecStd	317	38	66	66	101	110	109	150	107	57	83	47	45
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.5	24.2	28.2	31.0	33.7	35.0	37.7	37.8	36.2	32.7	27.4	20.3
		MCWB	12.7	16.6	20.0	21.9	23.0	25.7	27.0	26.5	25.4	23.2	18.7	13.5
	2%	DB	16.3	21.0	24.8	29.0	32.1	33.9	36.4	36.4	34.7	30.0	24.6	17.6
		MCWB	11.2	14.6	17.2	20.1	22.3	25.8	26.8	26.6	25.3	21.3	17.3	11.8
	5%	DB	13.9	18.1	22.2	27.0	30.5	32.6	35.5	35.4	33.2	28.1	22.6	15.6
		MCWB	9.6	12.8	15.1	19.2	21.9	25.4	26.6	26.5	25.0	20.1	16.1	11.1
	10%	DB	11.8	15.6	19.6	25.0	28.8	31.3	34.5	34.2	31.6	26.5	20.5	13.8
		MCWB	8.3	11.5	14.4	18.3	21.6	24.9	26.4	26.3	24.3	19.2	15.4	9.9
	0.4%	WB	15.2	17.7	21.4	23.5	25.8	27.7	28.5	28.3	27.5	24.9	21.0	15.6
		MCDB	17.7	22.5	26.7	28.2	30.1	32.7	34.3	34.5	33.4	29.8	24.0	17.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	12.5	15.8	18.8	22.2	24.8	26.9	27.9	27.7	26.7	23.2	19.2	13.8
		MCDB	15.2	19.8	22.4	26.0	28.9	31.8	33.7	33.6	32.0	27.5	22.1	16.0
	5%	WB	10.3	13.9	17.0	21.2	24.0	26.3	27.5	27.3	26.1	22.0	17.9	11.9
		MCDB	12.6	16.9	20.5	24.4	27.5	30.7	33.1	32.9	31.1	26.1	20.9	14.3
	10%	WB	8.8	12.1	15.4	20.1	23.1	25.7	27.1	26.9	25.4	21.0	16.4	10.5
		MCDB	11.1	14.6	18.3	22.9	26.4	29.6	32.4	32.2	30.0	24.9	19.3	12.6
Mean Daily Temperature Range	5% DB	MDBR	6.7	7.3	7.9	8.4	8.2	6.8	7.3	7.6	8.2	8.7	8.4	7.9
		MCDBR	11.4	12.1	12.7	12.3	11.5	9.2	9.0	9.4	9.9	11.2	11.8	11.5
		MCWBR	6.3	6.3	5.8	5.2	4.2	3.1	2.4	2.5	2.9	4.0	5.1	6.0
	5% WB	MDBR	8.7	10.5	10.0	9.1	7.9	7.6	8.4	8.6	8.7	8.4	8.4	8.1
		MCWBR	5.4	6.2	5.6	4.9	3.8	3.0	2.8	2.9	2.9	3.8	4.4	4.9
Clear-Sky Solar Irradiance	taub		0.640	0.693	0.747	0.739	0.676	0.679	0.630	0.665	0.658	0.659	0.615	0.594
	taud		1.573	1.511	1.456	1.515	1.665	1.688	1.814	1.715	1.696	1.622	1.653	1.657
	Ebn at Noon		573	591	598	629	674	669	701	671	653	608	589	584
	Edh at Noon		232	267	299	291	251	244	214	235	232	235	212	204
	RadAvg		2.09	2.38	3.15	3.79	4.30	4.00	5.32	4.83	4.24	3.48	2.61	2.26
All-Sky Solar Radiation	RadStd		0.38	0.64	0.28	0.47	0.50	0.53	0.56	0.52	0.34	0.45	0.42	0.45

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+157	+97
Regional (7 neighbors)		+0.30	N/A	N/A	+0.44	N/A	N/A	N/A	N/A	+112	N/A

Nomenclature: See separate page