

SHENGXIAN, China

WMO: 585560

Lat: 29.5921N

Lon: 120.8111E

Elev: 108

StdP: 100.03

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.5	(c) -1.3	(d) -11.5	(e) 1.4	(f) 2.8	(g) -9.3	(h) 1.7	(i) 2.9	(j) 8.5	(k) 7.6	(l) 7.5	(m) 6.8	(n) 1.4	(o) 250	(p) 0.364

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 8.2	(c) 36.5	(d) 26.1	(e) 35.2	(f) 26.0	(g) 33.9	(h) 25.9	(i) 27.3	(j) 33.3	(k) 26.9	(l) 32.6	(m) 26.5	(n) 31.9	(o) 2.6	(p) 220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.9	21.6	29.9	25.5	20.9	29.5	25.1	20.4	29.2	87.6	33.4	85.4	32.8	83.5	32.0	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max				
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.5	6.4	5.4	-4.7	38.1	1.4	1.4	-5.7	39.1	-6.5	40.0	-7.4	40.8	-8.4	41.8		
			-5.8	28.3	1.6	0.6	-6.9	28.7	-7.9	29.1	-8.8	29.4	-9.9	29.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.7	5.3	7.3	11.6	17.2	22.0	25.0	29.4	28.8	24.5	19.4	13.5	7.5
	DBStd	8.86	3.70	4.24	4.24	3.89	2.84	2.95	2.49	2.37	3.10	3.02	3.73	3.57
	HDD10.0	387	154	97	31	2	0	0	0	0	0	0	11	93
	HDD18.3	1506	404	310	212	66	4	0	0	0	0	23	150	337
	CDD10.0	3193	8	21	81	218	372	450	602	583	436	291	116	16
	CDD18.3	1270	0	1	4	32	117	201	344	324	186	56	6	0
	CDH23.3	12491	0	6	38	227	785	1662	4323	3740	1436	247	27	1
	CDH26.7	5362	0	0	6	54	239	632	2192	1707	484	44	4	0
Wind	WSAvg	2.2	2.4	2.5	2.4	2.3	2.0	1.8	2.1	2.1	2.1	2.1	2.1	2.3
Precipitation	PrecAvg	1282	48	77	112	129	157	201	138	130	133	68	51	39
	PrecMax	1679	121	174	225	236	451	354	334	322	335	191	176	145
	PrecMin	851	0	16	34	31	70	107	24	13	0	0	2	0
	PrecStd	226	30	44	55	49	77	73	79	68	81	55	42	34
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.0	24.1	27.1	30.7	33.6	35.6	38.3	38.4	34.9	30.3	26.6	19.0
		MCWB	15.1	15.5	17.4	19.8	22.1	25.9	25.7	25.8	26.0	22.8	19.1	13.2
	2%	DB	15.9	19.8	23.8	28.1	31.2	33.8	36.7	36.4	33.0	27.7	23.3	16.7
		MCWB	11.0	13.6	16.0	19.2	21.4	25.8	26.1	26.1	25.0	20.8	17.5	12.4
	5%	DB	13.0	16.7	21.0	25.9	29.3	32.0	35.7	34.9	31.2	25.9	21.1	14.8
		MCWB	9.1	11.8	14.2	17.9	20.8	25.0	26.1	26.0	24.6	19.9	16.7	11.0
	10%	DB	10.8	13.9	18.6	23.8	27.5	30.3	34.5	33.5	29.4	24.3	19.3	13.1
		MCWB	7.7	10.0	13.4	17.5	20.3	24.3	26.1	25.9	23.9	19.3	15.8	10.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.5	16.9	19.7	22.7	25.1	27.4	28.3	27.7	27.3	24.2	21.2	16.2
		MCDB	20.1	22.3	25.1	27.6	30.2	32.7	34.3	34.2	32.8	27.9	24.4	17.7
	2%	WB	12.3	14.5	17.2	21.3	24.0	26.7	27.5	27.1	26.2	22.9	19.4	13.7
		MCDB	14.9	18.8	21.3	24.9	28.2	31.7	33.5	33.2	30.7	25.7	21.4	15.3
	5%	WB	10.1	12.4	15.6	20.1	23.0	26.0	27.0	26.7	25.4	21.5	17.9	12.1
		MCDB	12.0	16.0	19.7	23.5	26.3	30.7	32.9	32.3	29.3	24.3	19.9	13.9
	10%	WB	8.2	10.4	14.2	18.7	22.1	25.3	26.6	26.3	24.7	20.4	16.4	10.5
		MCDB	10.1	13.1	17.5	22.3	25.3	29.1	32.2	31.4	28.2	23.3	18.6	12.3
Mean Daily Temperature Range	5% DB	MDBR	6.6	7.2	8.2	9.1	8.7	7.0	8.2	7.7	7.2	8.0	7.8	7.4
		MCDBR	11.6	13.4	13.3	13.1	12.4	10.1	10.3	10.4	9.5	10.3	11.5	11.1
	5% WB	MCWBR	7.0	7.4	6.4	5.5	4.6	3.3	2.7	2.5	2.9	4.0	5.5	6.4
		MCWBR	9.5	11.6	10.6	9.7	8.5	8.4	9.0	8.8	8.0	8.0	7.6	7.5
Clear-Sky Solar Irradiance	taub	taub	0.599	0.642	0.685	0.693	0.657	0.669	0.622	0.647	0.632	0.606	0.587	0.570
		taud	1.651	1.591	1.548	1.583	1.692	1.710	1.835	1.761	1.761	1.731	1.725	1.712
	Ebn at Noon	Ebn at Noon	606	628	641	659	687	676	706	683	672	649	613	604
		Edh at Noon	213	246	272	271	244	239	210	224	217	210	196	192
All-Sky Solar Radiation	RadAvg	RadAvg	2.17	2.53	3.44	4.12	4.41	3.99	5.55	4.75	3.72	3.31	2.41	2.24
	RadStd	RadStd	0.38	0.59	0.32	0.49	0.57	0.59	0.61	0.54	0.44	0.53	0.35	0.43

Historical Trends

		Heating		Cooling		Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
(a) Station Only	DBAvg	(d) +0.31	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A
(b) Regional (13 neighbors)	DBAvg	(d) +0.27	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) +104

Nomenclature: See separate page