

LISHUI, China

WMO: 586460

Lat: 28.4612N

Lon: 119.9296E

Elev: 197

StdP: 14.59

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.7	32.8	14.7	11.7	40.6	19.0	14.4	40.2	12.9	51.8	11.4	50.1	2.1	70	0.329

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.7	99.8	78.5	97.5	78.5	95.2	78.1	80.9	93.1	80.1	91.8	79.5	90.4	5.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.2	147.6	84.8	77.4	143.6	84.3	76.7	140.3	83.9	44.8	93.1	44.0	92.3	43.3	90.9	84.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.3	9.6	8.0	DB	26.2	102.6	2.8	2.4	24.2	104.3	22.5	105.7	21.0	107.0	18.9	108.7
			WB	24.3	82.4	2.6	1.3	22.4	83.3	20.9	84.1	19.4	84.8	17.5	85.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.0	45.7	49.9	56.7	66.7	74.4	79.6	86.4	85.5	78.6	69.9	59.8	49.2	(6)
	DBStd	15.11	6.76	8.18	7.51	6.81	4.95	5.26	3.80	3.65	5.78	5.64	6.74	6.46	(7)
	HDD50	386	169	96	22	1	0	0	0	0	0	0	6	92	(8)
	HDD65	2050	599	426	274	60	2	0	0	0	0	17	183	489	(9)
	CDD50	6576	36	93	230	502	756	888	1128	1099	858	618	300	68	(10)
	CDD65	2766	0	4	18	111	293	438	663	634	408	170	26	1	(11)
	CDH74	28747	4	37	153	770	2200	4159	8648	7817	3820	1018	117	4	(12)
	CDH80	13082	0	5	31	221	780	1749	4609	3866	1547	255	19	0	(13)
(14) Wind	WSAvg	3.2	3.1	3.4	3.3	3.3	3.1	2.8	3.5	3.5	3.2	3.1	2.8	2.8	(14)
(15) Precipitation	PrecAvg	54.0	2.0	3.3	4.8	6.5	7.9	9.1	4.7	4.5	5.0	2.4	2.2	1.5	(15)
	PrecMax	77.0	4.7	7.0	8.0	14.6	15.6	15.0	10.6	10.8	11.3	6.6	6.3	4.6	(16)
	PrecMin	38.1	0.0	0.6	1.8	1.3	3.7	3.7	0.6	1.1	1.0	0.0	0.0	0.0	(17)
	PrecStd	9.5	1.3	1.7	1.7	2.5	3.4	2.7	2.6	2.8	2.9	1.8	1.6	1.2	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.5	79.7	83.9	90.0	95.3	99.2	103.1	102.2	97.9	90.6	82.7	71.1	(19)
		MCWB	59.7	64.5	65.7	70.1	73.5	79.1	78.0	78.7	78.2	75.0	68.6	61.9	(20)
	2%	DB	64.4	72.4	78.3	85.8	90.7	95.5	100.3	99.1	94.2	85.9	77.3	65.7	(21)
		MCWB	55.7	60.3	63.3	68.7	71.6	78.0	78.2	78.7	77.1	71.3	65.6	57.8	(22)
	5%	DB	59.7	67.1	73.2	82.0	87.6	92.4	98.2	96.8	91.5	82.7	73.5	62.1	(23)
		MCWB	51.9	57.4	60.9	67.5	71.2	76.9	78.5	78.5	76.4	69.2	63.8	54.8	(24)
	10%	DB	56.1	62.1	68.9	78.4	84.3	89.4	95.9	94.2	88.4	79.6	70.1	59.1	(25)
		MCWB	50.1	54.2	58.5	65.5	70.5	75.9	78.5	78.4	75.2	67.4	62.4	53.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	62.0	65.1	69.5	74.3	78.2	81.1	82.0	81.8	80.6	76.4	71.1	64.0	(27)
		MCDB	68.0	76.7	81.4	84.7	86.4	92.9	94.4	94.1	92.8	85.9	78.6	68.8	(28)
	2%	WB	57.2	61.5	65.6	72.3	76.4	79.9	81.0	80.8	79.2	74.3	68.4	59.9	(29)
		MCDB	62.8	70.8	74.4	81.4	85.3	90.6	93.4	93.0	90.1	82.0	74.0	63.8	(30)
	5%	WB	53.6	58.4	63.0	70.3	74.8	78.9	80.1	80.0	78.1	72.5	66.1	56.7	(31)
		MCDB	58.1	65.6	70.0	77.3	82.4	88.4	92.2	91.5	87.5	79.5	71.2	60.3	(32)
	10%	WB	50.8	55.2	60.6	68.4	73.2	77.9	79.5	79.2	76.9	70.4	63.7	54.0	(33)
		MCDB	55.0	60.7	66.7	74.4	80.3	86.2	90.9	89.7	85.1	76.9	68.6	57.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	12.7	14.0	15.5	16.8	16.2	14.0	16.7	15.7	14.2	15.4	14.7	14.4	(35)
		MCDBR	21.5	23.7	24.3	23.6	23.1	19.8	21.2	20.5	18.6	19.9	20.8	19.7	(36)
	5% WB	MCWBR	12.6	12.4	11.3	9.8	7.9	5.4	4.7	4.5	5.0	6.9	9.5	11.1	(37)
		MCWBR	16.9	20.9	19.5	18.1	16.2	16.5	17.9	17.4	16.0	15.2	15.0	13.9	(38)
(40) Clear-Sky Solar Irradiance	taub		0.623	0.677	0.731	0.732	0.679	0.665	0.611	0.645	0.652	0.638	0.600	0.580	(40)
		taud	1.620	1.551	1.493	1.540	1.676	1.731	1.870	1.775	1.729	1.678	1.716	1.706	(41)
	Ebn at Noon		189	193	194	201	213	215	227	218	210	200	194	192	(42)
		Edh at Noon	71	82	92	90	79	74	64	70	71	71	64	62	(43)
(44) All-Sky Solar Radiation	RadAvg		707	826	1054	1241	1313	1268	1758	1518	1231	1112	803	756	(44)
	RadStd		140	193	117	155	191	179	180	158	124	187	116	137	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.49	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)		+0.50	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+191	+101

Nomenclature: See separate page