

LISHUI, China

WMO: 586460

Lat: 28.4612N

Lon: 119.9296E

Elev: 60

StdP: 100.61

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.7	0.4	-9.6	1.7	4.8	-7.2	2.1	4.6	5.8	11.0	5.1	10.1	0.9	70	0.329

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.3	37.6	25.8	36.4	25.8	35.1	25.6	27.2	34.0	26.7	33.2	26.4	32.4	2.2	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.7	21.1	29.4	25.2	20.5	29.0	24.8	20.0	28.8	86.4	34.0	84.5	33.5	82.7	32.7	29.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.1	4.3	3.6	-3.2	39.2	1.6	1.3	-4.3	40.2	-5.3	40.9	-6.1	41.7	-7.3	42.6		
			-4.3	28.0	1.5	0.7	-5.3	28.5	-6.2	28.9	-7.0	29.3	-8.0	29.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.4	7.6	9.9	13.7	19.3	23.5	26.4	30.2	29.7	25.9	21.1	15.4	9.6
	DBStd	8.40	3.76	4.55	4.17	3.78	2.75	2.92	2.11	2.03	3.21	3.13	3.75	3.59
	HDD10.0	214	94	53	12	1	0	0	0	0	0	0	3	51
	HDD18.3	1139	333	237	152	33	1	0	0	0	0	9	102	272
	CDD10.0	3653	20	52	128	279	420	493	627	611	477	343	167	38
	CDD18.3	1537	0	2	10	62	163	243	368	352	227	94	14	1
	CDH23.3	15971	2	21	85	428	1222	2311	4804	4343	2122	566	65	2
	CDH26.7	7268	0	3	17	123	433	972	2561	2148	859	142	11	0
Wind	WSAvg	1.4	1.4	1.5	1.5	1.5	1.4	1.3	1.5	1.5	1.4	1.4	1.2	1.3
Precipitation	PrecAvg	1371	51	83	123	164	201	232	120	115	126	61	56	38
	PrecMax	1956	120	178	203	370	395	380	268	274	287	168	160	117
	PrecMin	968	0	16	45	34	94	95	15	29	25	0	0	1
	PrecStd	242	32	42	44	64	86	69	65	71	74	46	40	31
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.4	26.5	28.9	32.2	35.2	37.3	39.5	39.0	36.6	32.6	28.2	21.7
		MCWB	15.4	18.1	18.7	21.2	23.1	26.1	25.6	25.9	25.7	23.9	20.3	16.6
	2%	DB	18.0	22.5	25.7	29.9	32.6	35.3	38.0	37.3	34.6	29.9	25.1	18.7
		MCWB	13.2	15.7	17.4	20.4	22.0	25.6	25.7	25.9	25.1	21.8	18.6	14.3
	5%	DB	15.4	19.5	22.9	27.8	30.9	33.6	36.8	36.0	33.1	28.2	23.0	16.7
		MCWB	11.1	14.1	16.0	19.7	21.8	25.0	25.8	25.8	24.6	20.7	17.7	12.7
	10%	DB	13.4	16.7	20.5	25.8	29.1	31.9	35.5	34.6	31.3	26.5	21.2	15.0
		MCWB	10.0	12.3	14.7	18.6	21.4	24.4	25.8	25.8	24.0	19.7	16.9	11.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.7	18.4	20.8	23.5	25.7	27.3	27.8	27.7	27.0	24.7	21.7	17.8
		MCDB	20.0	24.8	27.4	29.3	30.2	33.8	34.7	34.5	33.8	29.9	25.9	20.5
	2%	WB	14.0	16.4	18.7	22.4	24.7	26.6	27.2	27.1	26.2	23.5	20.2	15.5
		MCDB	17.1	21.6	23.5	27.4	29.6	32.5	34.1	33.9	32.3	27.8	23.3	17.7
	5%	WB	12.0	14.7	17.2	21.3	23.8	26.1	26.7	26.7	25.6	22.5	19.0	13.7
		MCDB	14.5	18.7	21.1	25.2	28.0	31.3	33.4	33.0	30.9	26.4	21.8	15.7
	10%	WB	10.5	12.9	15.9	20.2	22.9	25.5	26.4	26.2	25.0	21.4	17.6	12.2
		MCDB	12.8	15.9	19.3	23.6	26.8	30.1	32.7	32.1	29.5	25.0	20.3	14.3
Mean Daily Temperature Range	5% DB	MDBR	7.1	7.8	8.6	9.3	9.0	7.8	9.3	8.7	7.9	8.6	8.2	8.0
		MCDBR	11.9	13.2	13.5	13.1	12.8	11.0	11.8	11.4	10.4	11.0	11.6	10.9
		MCWBR	7.0	6.9	6.3	5.4	4.4	3.0	2.6	2.5	2.8	3.9	5.3	6.1
	5% WB	MCDBR	9.4	11.6	10.9	10.0	9.0	9.2	10.0	9.6	8.9	8.5	8.3	7.7
		MCWBR	6.0	6.8	5.9	5.1	3.8	3.0	2.8	2.7	2.7	3.5	4.4	5.0
Clear-Sky Solar Irradiance	taub	0.623	0.677	0.731	0.732	0.679	0.665	0.611	0.645	0.652	0.638	0.600	0.580	
	taud	1.620	1.551	1.493	1.540	1.676	1.731	1.870	1.775	1.729	1.678	1.716	1.706	
	Ebn at Noon	595	609	613	635	673	679	715	687	662	630	611	606	
	Edh at Noon	223	258	290	284	248	234	203	222	225	224	201	196	
All-Sky Solar Radiation	RadAvg	2.23	2.60	3.32	3.91	4.14	4.00	5.54	4.78	3.88	3.50	2.53	2.38	
	RadStd	0.44	0.61	0.37	0.49	0.60	0.56	0.57	0.50	0.39	0.59	0.37	0.43	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.27	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (12 neighbors)	+0.28	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+106	+56

Nomenclature: See separate page