

WENZHOU, China

WMO: 586590

Lat: 28.017N

Lon: 120.667E

Elev: 23

StdP: 14.68

Time Zone: 8.00 (E08)

Period: 90-01

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	34.3	37.0	17.3	13.2	42.0	22.8	17.2	42.6	15.1	48.0	13.7	47.6	3.7	290	0.327

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.0	93.0	81.2	91.2	80.7	89.6	80.0	82.5	90.7	81.6	89.0	80.8	87.3	7.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.2	157.1	86.8	79.7	154.0	85.9	79.0	150.9	84.9	46.5	91.0	45.5	89.2	44.6	87.8	85.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.4	12.2	11.0	30.7	97.6	2.2	2.0	29.1	99.0	27.8	100.2	26.5	101.4	24.9	102.8
			26.9	84.0	2.2	0.7	25.3	84.5	24.0	84.9	22.7	85.3	21.1	85.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.1	48.1	49.1	54.3	62.6	71.2	77.5	83.4	83.5	78.0	69.9	61.9	52.9
	DBStd	13.47	5.80	5.85	5.61	5.97	4.82	4.83	3.52	2.44	4.36	4.68	5.83	5.83
	HDD50	244	107	79	20	1	0	0	0	0	0	0	1	36
	HDD65	1937	524	446	334	111	8	0	0	0	0	12	126	376
	CDD50	6131	48	54	153	380	657	824	1036	1039	841	616	357	126
	CDD65	2350	0	1	2	41	200	374	571	574	391	163	32	1
	CDH74	20744	0	1	5	109	874	2913	6540	6518	3145	589	50	0
	CDH80	7083	0	0	0	13	160	859	2648	2472	854	75	2	0
(14) Wind	WSAvg	3.8	3.9	3.6	3.5	3.5	3.6	3.3	4.3	4.9	4.1	3.7	3.5	3.6
(15) Precipitation	PrecAvg	66.9	2.3	3.1	5.0	6.3	8.3	8.7	6.7	9.6	8.6	3.7	2.8	1.6
	PrecMax	98.2	6.4	6.1	9.7	12.6	17.0	15.3	18.8	24.1	23.8	15.1	16.6	4.1
	PrecMin	40.4	0.0	0.0	1.4	1.8	4.3	3.4	1.6	2.0	0.3	0.0	0.1	0.0
	PrecStd	15.2	1.6	1.5	2.3	2.7	3.4	3.1	4.3	6.2	5.4	3.7	3.1	1.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.5	70.5	73.4	81.8	88.1	93.2	96.8	94.6	91.9	85.6	78.9	70.5
		MCWB	57.9	62.1	64.1	72.4	76.6	81.3	82.6	81.2	81.2	75.1	69.9	62.7
	2%	DB	62.1	64.6	68.5	76.9	84.0	90.2	93.5	92.6	88.8	82.0	74.9	66.4
		MCWB	55.4	57.3	60.8	68.4	74.3	80.6	81.4	81.1	79.1	71.8	66.7	59.7
	5%	DB	58.2	60.4	65.5	73.9	81.2	87.6	91.4	90.9	86.9	79.5	72.7	63.6
		MCWB	52.4	55.5	59.2	67.4	72.2	79.7	80.7	80.5	77.9	69.9	65.6	57.5
	10%	DB	55.7	57.2	62.3	71.1	78.7	85.0	89.7	89.2	84.7	77.3	70.4	61.2
		MCWB	51.5	52.6	57.3	65.0	71.4	78.5	80.3	79.8	76.0	69.0	63.8	55.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.6	63.4	66.2	73.5	79.2	82.6	83.7	83.5	82.1	76.9	72.4	64.4
		MCDB	65.2	68.7	71.3	79.3	85.6	90.5	93.0	91.9	89.8	81.9	75.4	67.4
	2%	WB	56.5	59.3	62.9	70.7	76.5	81.3	82.7	82.1	80.7	75.3	69.5	61.8
		MCDB	59.9	62.6	66.6	75.3	81.1	88.5	91.2	90.1	86.8	79.3	73.7	64.8
	5%	WB	54.5	56.6	60.7	68.6	74.7	80.2	81.8	81.3	79.7	73.3	67.5	59.6
		MCDB	57.4	59.7	64.0	72.3	78.8	86.4	89.3	88.3	84.8	77.5	70.9	62.8
	10%	WB	52.5	53.6	58.4	66.6	73.2	79.2	80.9	80.6	78.7	71.3	65.5	56.8
		MCDB	55.1	56.2	61.4	70.3	77.1	84.1	87.5	86.7	83.0	75.7	69.0	59.6
(35) Mean Daily Temperature Range	5% DB	MDBR	10.8	10.7	10.3	11.9	11.6	10.2	11.2	11.0	10.8	11.9	12.6	12.5
		MCDBR	15.4	16.4	15.8	15.6	15.6	13.8	14.0	13.5	12.4	14.6	14.8	15.9
	5% WB	MCWBR	9.0	9.8	9.0	8.6	7.2	5.9	4.7	5.0	4.6	5.7	7.2	9.1
		MCWBR	12.8	13.9	13.5	14.3	12.5	12.6	12.9	12.4	10.6	11.2	11.0	13.1
(40) Clear-Sky Solar Irradiance	taub		0.589	0.647	0.699	0.706	0.658	0.638	0.585	0.612	0.606	0.596	0.575	0.555
		taud	1.701	1.623	1.563	1.603	1.737	1.810	1.948	1.868	1.851	1.791	1.795	1.782
	Ebn at Noon		200	201	202	207	218	221	233	226	221	212	203	201
		Edh at Noon	66	76	86	85	74	69	60	64	63	64	59	58
(44) All-Sky Solar Radiation	RadAvg		718	822	1071	1239	1314	1328	1832	1597	1308	1147	802	755
	RadStd		144	192	108	145	193	168	175	152	132	192	118	131

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page