

WENZHOU, China

WMO: 586590

Lat: 28.017N

Lon: 120.667E

Elev: 7

StdP: 101.24

Time Zone: 8.00 (E08)

Period: 90-01

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.3	2.8	-8.2	1.9	5.6	-5.1	2.5	5.9	6.7	8.9	6.1	8.7	1.7	290	0.327

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.1	33.9	27.3	32.9	27.0	32.0	26.7	28.0	32.6	27.6	31.6	27.1	30.7	3.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.8	22.4	30.5	26.5	22.0	29.9	26.1	21.6	29.4	90.3	32.8	87.9	31.8	86.0	31.0	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6.4	5.5	4.9	-0.7	36.4	1.2	1.1	-1.6	37.2	-2.4	37.9	-3.1	38.5	-4.0	39.4
			-2.8	28.9	1.2	0.4	-3.7	29.2	-4.4	29.4	-5.1	29.6	-6.0	29.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.0	8.9	9.5	12.4	17.0	21.8	25.3	28.6	28.6	25.6	21.0	16.6	11.6
	DBStd	7.48	3.22	3.25	3.12	3.32	2.68	2.68	1.95	1.36	2.42	2.60	3.24	3.24
	HDD10.0	136	59	44	11	1	0	0	0	0	0	0	1	20
	HDD18.3	1076	291	248	186	62	4	0	0	0	0	7	70	209
	CDD10.0	3406	27	30	85	211	365	458	576	577	467	342	198	70
	CDD18.3	1306	0	1	1	23	111	208	317	319	217	91	18	1
	CDH23.3	11524	0	1	3	61	486	1618	3633	3621	1747	327	28	0
	CDH26.7	3935	0	0	0	7	89	477	1471	1373	474	42	1	0
Wind	WSAvg	1.7	1.7	1.6	1.6	1.6	1.6	1.5	1.9	2.2	1.8	1.7	1.5	1.6
Precipitation	PrecAvg	1698	58	79	127	159	212	222	170	245	219	94	72	40
	PrecMax	2494	163	154	246	319	432	388	478	611	604	384	421	105
	PrecMin	1026	1	1	36	45	108	86	40	51	8	1	2	1
	PrecStd	387	40	39	58	69	87	78	108	157	137	94	80	31
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.2	21.4	23.0	27.6	31.2	34.0	36.0	34.8	33.3	29.8	26.1	21.4
		MCWB	14.4	16.7	17.8	22.5	24.8	27.4	28.1	27.3	27.3	24.0	21.1	17.1
	2%	DB	16.7	18.1	20.3	24.9	28.9	32.3	34.2	33.7	31.6	27.8	23.8	19.1
		MCWB	13.0	14.1	16.0	20.2	23.5	27.0	27.4	27.3	26.2	22.1	19.3	15.4
	5%	DB	14.6	15.8	18.6	23.3	27.4	30.9	33.0	32.7	30.5	26.4	22.6	17.5
		MCWB	11.3	13.1	15.1	19.6	22.4	26.5	27.0	27.0	25.5	21.1	18.7	14.2
	10%	DB	13.2	14.0	16.8	21.7	26.0	29.4	32.1	31.8	29.3	25.2	21.3	16.2
		MCWB	10.8	11.4	14.1	18.3	21.9	25.8	26.9	26.6	24.5	20.6	17.7	13.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.3	17.4	19.0	23.1	26.2	28.1	28.7	28.6	27.8	25.0	22.4	18.0
		MCDB	18.5	20.4	21.8	26.3	29.8	32.5	33.9	33.3	32.1	27.7	24.1	19.7
	2%	WB	13.6	15.2	17.2	21.5	24.7	27.4	28.2	27.9	27.1	24.1	20.8	16.6
		MCDB	15.5	17.0	19.2	24.1	27.3	31.4	32.9	32.3	30.5	26.3	23.1	18.2
	5%	WB	12.5	13.7	16.0	20.3	23.7	26.8	27.7	27.4	26.5	23.0	19.7	15.3
		MCDB	14.1	15.4	17.8	22.4	26.0	30.2	31.8	31.3	29.3	25.3	21.6	17.1
	10%	WB	11.4	12.0	14.6	19.2	22.9	26.2	27.2	27.0	26.0	21.8	18.6	13.8
		MCDB	12.8	13.5	16.3	21.3	25.1	28.9	30.8	30.4	28.3	24.3	20.6	15.4
Mean Daily Temperature Range	5% DB	MDBR	6.0	5.9	5.7	6.6	6.4	5.7	6.2	6.1	6.0	6.6	7.0	7.0
		MCDBR	8.6	9.1	8.8	8.7	8.6	7.7	7.8	7.5	6.9	8.1	8.2	8.8
		MCWBR	5.0	5.5	5.0	4.8	4.0	3.3	2.6	2.8	2.6	3.2	4.0	5.0
	5% WB	MCDBR	7.1	7.7	7.5	8.0	6.9	7.0	7.2	6.9	5.9	6.2	6.1	7.3
		MCWBR	5.0	5.3	4.9	4.7	3.8	3.2	3.0	2.9	2.4	3.3	4.1	5.0
Clear-Sky Solar Irradiance	taub	0.589	0.647	0.699	0.706	0.658	0.638	0.585	0.612	0.606	0.596	0.575	0.555	
	taud	1.701	1.623	1.563	1.603	1.737	1.810	1.948	1.868	1.851	1.791	1.795	1.782	
	Ebn at Noon	629	634	637	654	688	698	734	711	698	668	639	634	
	Edh at Noon	207	241	271	267	234	216	188	202	200	201	186	183	
All-Sky Solar Radiation	RadAvg	2.27	2.59	3.38	3.91	4.14	4.19	5.77	5.04	4.12	3.62	2.53	2.38	
	RadStd	0.45	0.60	0.34	0.46	0.61	0.53	0.55	0.48	0.42	0.60	0.37	0.41	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page