

LINHAI, China

WMO: 586600

Lat: 28.850N

Lon: 121.133E

Elev: 9

StdP: 101.22

Time Zone: 8.00 (E08)

Period: 94-10

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -0.6	(c) 0.6	(d) -12.7	(e) 1.3	(f) 4.6	(g) -9.9	(h) 1.6	(i) 4.7	(j) 5.7	(k) 6.1	(l) 5.0	(m) 5.8	(n) 0.7	(o) 290	(p) 0.321

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.0	36.2	27.0	34.8	26.8	33.5	26.4	28.0	34.1	27.4	32.9	26.9	31.9	2.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.4	21.8	31.2	25.9	21.3	30.3	25.6	20.8	29.8	89.7	34.2	87.2	33.2	84.9	32.0	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 5.0	(b) 4.1	(c) 3.4	(e) -2.5	(f) 38.4	(g) 1.2	(h) 1.5	(i) -3.4	(j) 39.4	(k) -4.1	(l) 40.3	(m) -4.7	(n) 41.1	(o) -5.6	(p) 42.2		
(a) 5.0	(b) 4.1	(c) 3.4	(e) -4.5	(f) 29.1	(g) 1.4	(h) 0.7	(i) -5.5	(j) 29.6	(k) -6.4	(l) 30.0	(m) -7.2	(n) 30.3	(o) -8.2	(p) 30.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.8	7.5	9.3	12.6	17.7	22.3	25.7	29.7	28.9	25.5	21.1	15.4	9.7
	DBStd	8.20	3.40	4.06	3.75	3.88	2.65	3.03	2.16	1.83	2.80	2.86	3.62	3.32
	HDD10.0	217	94	56	16	1	0	0	0	0	0	0	3	47
	HDD18.3	1209	337	254	180	57	2	0	0	0	0	8	102	268
	CDD10.0	3442	16	37	97	231	383	471	610	587	466	343	164	37
	CDD18.3	1392	0	2	3	37	127	221	352	329	216	93	13	0
	CDH23.3	13212	0	12	26	211	742	1868	4336	3756	1779	439	43	0
	CDH26.7	5284	0	1	3	50	197	688	2113	1578	569	79	5	0
Wind	WSAvg	1.3	1.2	1.2	1.3	1.3	1.2	1.0	1.4	1.5	1.5	1.2	1.2	1.1
Precipitation	PrecAvg	1688	71	69	131	134	163	238	190	300	205	96	74	52
	PrecMax	2234	191	152	311	283	296	429	334	437	400	262	210	140
	PrecMin	1177	32	18	45	65	73	57	82	116	80	17	15	8
	PrecStd	229	34	33	66	56	75	99	72	100	87	80	49	39
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.9	25.2	26.2	30.6	32.5	36.2	38.7	37.1	34.6	30.5	27.2	20.3
		MCWB	16.9	18.2	18.3	20.7	23.2	26.8	26.4	27.3	26.8	22.9	20.8	14.8
	2%	DB	17.0	20.7	23.2	27.9	30.3	34.1	37.0	35.4	32.8	28.6	24.4	17.8
		MCWB	12.9	15.5	16.4	20.3	21.9	26.3	26.7	27.0	25.9	21.5	18.7	13.9
	5%	DB	14.5	17.8	20.7	25.7	28.8	32.2	35.5	34.0	31.4	27.2	22.5	16.3
		MCWB	10.8	13.9	15.1	19.1	21.3	25.7	27.0	26.6	25.0	20.6	18.0	12.7
	10%	DB	12.7	15.2	18.6	23.6	27.2	30.4	34.1	32.8	29.9	25.7	20.7	14.9
		MCWB	9.7	11.6	14.2	18.0	21.2	25.0	26.8	26.3	24.0	19.9	16.9	11.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.8	18.8	19.6	23.4	25.4	28.0	28.7	28.6	28.1	24.6	22.1	16.7
		MCDB	19.6	23.9	23.8	28.0	29.7	33.9	35.2	34.5	33.3	28.3	25.3	18.0
	2%	WB	13.7	16.5	17.7	21.8	24.4	27.0	28.1	27.7	26.9	23.6	20.4	15.2
		MCDB	15.6	20.1	21.2	25.7	28.0	32.2	34.4	33.5	31.3	26.7	23.1	16.9
	5%	WB	11.8	14.4	16.4	20.6	23.4	26.4	27.6	27.2	26.1	22.5	19.1	13.7
		MCDB	13.8	17.2	19.6	24.0	26.5	31.0	33.4	32.4	29.5	25.4	21.4	15.6
	10%	WB	10.1	12.3	15.0	19.2	22.5	25.8	27.1	26.7	25.3	21.4	17.6	12.3
		MCDB	12.1	14.8	18.0	22.6	25.4	29.6	32.4	31.3	28.6	24.6	19.9	14.2
Mean Daily Temperature Range	5% DB	MDBR	6.9	7.6	7.9	8.8	8.2	6.9	8.0	7.1	6.9	7.9	7.7	7.7
		MCDBR	10.8	12.6	12.6	12.2	11.5	9.8	10.5	9.5	8.5	9.9	10.7	10.7
		MCWBR	6.6	7.0	6.4	5.7	4.6	3.6	3.1	3.0	2.7	3.6	5.1	6.1
	5% WB	MCDBR	8.8	11.2	10.5	10.0	8.3	8.4	9.2	8.3	7.7	7.3	7.5	7.1
		MCWBR	6.2	6.9	6.4	5.4	4.2	3.5	3.4	3.1	2.8	3.8	4.3	4.9
Clear-Sky Solar Irradiance	taub	0.593	0.644	0.689	0.700	0.661	0.657	0.612	0.633	0.615	0.596	0.577	0.562	
	taud	1.671	1.604	1.553	1.586	1.704	1.749	1.868	1.801	1.813	1.768	1.763	1.742	
	Ebn at Noon	618	632	640	656	685	684	715	694	688	662	629	619	
	Edh at Noon	211	244	272	271	241	230	203	216	207	204	190	188	
All-Sky Solar Radiation	RadAvg	2.27	2.60	3.46	4.07	4.31	4.11	5.74	4.96	3.99	3.54	2.51	2.34	
	RadStd	0.40	0.60	0.34	0.47	0.58	0.55	0.58	0.51	0.43	0.55	0.35	0.40	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+102	+59

Nomenclature: See separate page