

SHAOWU, China

WMO: 587250

Lat: 27.333N

Lon: 117.467E

Elev: 219

StdP: 98.72

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.5	0.1	-7.8	2.0	7.4	-4.9	2.6	6.3	5.3	8.4	4.4	8.7	0.7	200	0.307

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	35.7	25.1	34.7	25.0	33.6	24.9	26.7	31.9	26.2	31.3	25.9	30.8	1.9	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.6	21.3	28.3	25.1	20.8	28.0	24.7	20.3	27.7	85.2	32.0	83.4	31.6	81.8	30.9	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4.4	3.6	3.1	-4.0	37.4	1.6	1.0	-5.1	38.1	-6.1	38.6	-7.0	39.2	-8.1	39.9
			-4.5	27.5	1.7	0.6	-5.7	27.9	-6.7	28.3	-7.6	28.6	-8.8	29.0
					</									

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	19.2	8.2	10.5	13.8	19.1	23.1	26.0	28.6	28.3	25.7	21.0	15.4	9.8	(6)
(7)		DBStd	7.79	3.66	4.36	4.02	3.58	2.59	2.37	1.70	1.69	2.75	3.07	3.61	3.53	(7)
(8)		HDD10.0	183	79	42	10	1	0	0	0	0	0	0	4	47	(8)
(9)		HDD18.3	1093	313	220	149	33	2	0	0	0	0	9	101	266	(9)
(10)		CDD10.0	3534	25	57	128	273	406	481	577	568	472	343	166	40	(10)
(11)		CDD18.3	1403	0	2	9	56	148	231	318	309	222	94	12	1	(11)
(12)		CDH23.3	12764	1	17	72	351	976	1937	3569	3226	1941	613	60	1	(12)
(13)		CDH26.7	5236	0	2	10	92	324	743	1683	1422	793	160	7	0	(13)
(14)	Wind	WSAvg	1.1	1.1	1.2	1.1	1.1	1.0	1.1	1.2	1.1	1.0	1.0	1.1	(14)	
(15)	Precipitation	PrecAvg	1793	65	115	189	258	308	336	140	123	83	67	62	44	(15)
(16)		PrecMax	2403	173	268	342	479	610	634	366	352	181	161	195	143	(16)
(17)		PrecMin	1231	6	7	38	102	112	142	6	4	6	2	3	1	(17)
(18)		PrecStd	303	47	57	80	95	115	128	87	74	51	51	51	36	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.4	25.7	28.0	31.4	33.7	35.4	37.4	36.9	35.5	32.5	27.6	21.5	(19)
(20)		0.4%	MCWB	15.5	18.4	19.3	21.6	22.6	25.7	25.1	25.1	24.8	22.9	19.7	16.2	(20)
(21)		2%	DB	18.5	22.6	25.5	29.3	31.8	33.8	36.0	35.6	33.9	30.2	25.1	18.9	(21)
(22)		2%	MCWB	13.2	16.2	17.5	20.7	22.0	24.8	25.1	25.1	24.3	21.7	18.0	14.3	(22)
(23)		5%	DB	16.3	19.8	22.8	27.3	30.2	32.5	34.9	34.3	32.7	28.4	23.0	17.0	(23)
(24)		5%	MCWB	12.3	14.6	16.3	19.7	21.7	24.5	25.1	25.2	24.0	20.3	17.1	12.7	(24)
(25)		10%	DB	14.1	17.2	20.2	25.2	28.4	31.0	33.8	33.0	31.2	26.8	21.2	15.5	(25)
(26)		10%	MCWB	10.9	13.3	15.6	19.1	21.6	24.3	25.2	25.2	23.6	19.3	16.4	11.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.7	19.1	21.0	23.5	25.6	26.9	27.2	27.2	26.6	24.6	21.4	18.0	(27)
(28)		0.4%	MCDWB	19.7	23.9	26.2	27.9	29.9	31.9	32.4	32.4	32.3	29.1	24.9	20.1	(28)
(29)		2%	WB	14.7	17.2	19.5	22.5	24.6	26.2	26.7	26.6	25.7	23.4	20.1	15.9	(29)
(30)		2%	MCDWB	17.5	21.2	23.4	26.8	28.5	31.0	31.9	32.0	30.7	27.1	22.8	17.9	(30)
(31)		5%	WB	13.0	15.6	18.1	21.6	23.9	25.7	26.2	26.2	25.1	22.5	18.9	14.3	(31)
(32)		5%	MCDWB	15.5	18.9	20.9	25.4	27.4	30.2	31.4	31.3	29.8	25.9	21.2	16.0	(32)
(33)		10%	WB	11.2	14.0	16.6	20.6	23.1	25.3	25.9	25.8	24.6	21.6	17.6	12.6	(33)
(34)		10%	MCDWB	13.3	16.8	19.3	23.4	26.1	29.1	30.9	30.6	28.8	25.1	20.0	14.7	(34)
(35)	Mean Daily Temperature Range		MDBR	7.9	8.1	8.3	8.7	8.4	7.5	9.2	8.8	9.0	10.0	9.5	9.5	(35)
(36)		5% DB	MCDBR	12.5	13.3	13.5	13.1	12.6	10.8	11.8	11.4	11.2	12.2	12.7	12.8	(36)
(37)		5% DB	MCWBR	7.1	6.8	6.0	5.0	4.0	3.0	2.6	2.7	2.9	3.9	5.7	7.0	(37)
(38)		5% WB	MCDBR	9.7	11.0	10.2	9.5	8.1	8.6	9.6	9.5	9.5	8.7	8.3	7.7	(38)
(39)		5% WB	MCWBR	5.9	6.1	5.6	4.5	3.3	3.0	2.9	2.8	2.8	3.4	4.2	5.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.670	0.722	0.803	0.781	0.686	0.650	0.606	0.660	0.661	0.674	0.621	0.605	(40)	
(41)		taud	1.537	1.482	1.391	1.468	1.670	1.753	1.867	1.725	1.699	1.608	1.667	1.657	(41)	
(42)		Ebn at Noon	566	582	570	606	670	690	720	678	658	608	602	593	(42)	
(43)		Edh at Noon	246	280	323	306	250	229	204	234	234	242	214	209	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.19	2.47	2.92	3.41	3.81	3.89	5.39	4.76	4.14	3.65	2.71	2.49	(44)	
(45)		RadStd	0.48	0.59	0.42	0.52	0.62	0.53	0.50	0.42	0.36	0.63	0.45	0.50	(45)	

Historical Trends

		DBAvg		Heating		Cooling			Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	+0.45	N/A	N/A	N/A	N/A	+91	+58	(46)
(47)	Regional (9 neighbors)	+0.30	N/A	N/A	+0.50	N/A	N/A	N/A	N/A	+112	+82	(47)

Nomenclature: See separate page