

WUYISHAN, China

WMO: 587300

Lat: 27.7559N

Lon: 118.0233E

Elev: 725

StdP: 14.31

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	31.3	33.8	15.8	12.6	45.3	20.5	15.8	44.0	11.3	48.2	9.7	49.9	2.3	0	0.299

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.7	95.8	77.4	94.0	77.1	92.0	76.6	79.6	89.3	78.9	88.4	78.2	87.3	5.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.4	146.6	82.7	76.6	142.7	82.3	76.0	139.7	81.8	43.8	89.3	43.1	88.3	42.4	87.7	82.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	9.8	7.9	6.9	DB	25.6	98.7	4.7	2.1	22.2	100.2	19.4	101.4	16.8	102.5	13.3	104.0
(5)				WB	24.1	81.2	4.2	0.8	21.1	81.7	18.6	82.2	16.3	82.6	13.2	83.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	66.8	47.7	51.3	57.0	66.2	73.3	78.4	83.5	83.1	78.6	70.6	60.5	50.7	(6)
(7)		DBStd	13.65	6.23	7.51	6.76	6.14	4.33	4.26	3.14	3.04	4.84	5.30	6.17	6.08	(7)
(8)		HDD50	271	119	69	14	0	0	0	0	0	0	5	64	(8)	
(9)		HDD65	1862	535	388	262	59	1	0	0	0	13	160	444	(9)	
(10)		CDD50	6411	49	104	232	485	724	852	1038	1026	857	639	319	86	(10)
(11)		CDD65	2527	0	3	14	94	260	402	573	561	407	187	25	1	(11)
(12)		CDH74	22770	1	20	88	528	1607	3288	6417	5972	3591	1150	106	2	(12)
(13)		CDH80	8973	0	1	9	117	490	1168	2927	2560	1404	286	11	0	(13)
(14)	Wind	WSAvg	2.8	2.6	2.7	2.7	2.6	2.6	3.1	3.0	3.0	3.0	2.7	2.7	(14)	
(15)	Precipitation	PrecAvg	77.8	3.3	4.2	7.9	9.2	10.9	16.1	6.6	7.0	4.1	2.3	3.6	2.5	(15)
(16)		PrecMax	109.8	9.6	7.9	15.9	17.1	20.1	41.3	17.2	14.1	10.8	8.7	9.4	8.3	(16)
(17)		PrecMin	52.8	0.3	0.7	3.0	4.2	4.8	3.8	0.9	2.9	1.6	0.4	0.4	0.2	(17)
(18)		PrecStd	15.9	1.9	1.9	3.3	3.1	4.4	7.8	3.9	2.8	2.0	2.0	2.6	2.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	69.5	76.9	80.8	87.1	92.0	95.0	98.6	97.7	95.6	90.1	81.6	71.0	(19)
(20)		0.4%	MCWB	58.9	63.5	66.1	70.2	72.1	77.4	77.4	77.6	76.3	72.5	66.8	60.6	(20)
(21)		2%	DB	64.7	71.5	76.3	83.4	88.4	92.1	96.2	95.5	92.8	86.0	77.1	66.2	(21)
(22)		2%	MCWB	55.2	60.9	63.0	68.4	70.9	76.3	77.7	77.4	75.5	70.5	64.0	56.1	(22)
(23)		5%	DB	61.1	66.6	72.0	80.0	85.6	89.5	94.4	93.4	90.5	83.0	73.7	63.2	(23)
(24)		5%	MCWB	53.4	57.7	60.4	66.4	70.5	75.6	77.6	77.3	75.1	68.5	62.2	55.1	(24)
(25)		10%	DB	57.6	62.4	67.5	76.6	82.4	86.8	92.3	91.1	88.0	80.4	70.5	60.4	(25)
(26)		10%	MCWB	51.4	55.4	59.2	65.7	70.0	75.5	77.4	77.0	74.1	66.8	61.2	53.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.2	65.7	69.3	73.3	77.5	79.9	80.9	80.5	79.2	75.6	70.2	63.5	(27)
(28)		0.4%	MCDWB	66.2	73.3	78.1	81.2	85.0	88.6	90.9	90.3	89.7	84.6	76.1	67.6	(28)
(29)		2%	WB	58.0	62.4	66.1	71.8	75.9	78.8	79.7	79.3	77.9	73.7	68.0	60.2	(29)
(30)		2%	MCDWB	63.1	69.5	72.2	79.3	82.4	87.2	89.6	89.1	87.5	80.8	72.7	63.9	(30)
(31)		5%	WB	55.2	59.5	63.6	70.3	74.6	78.0	78.9	78.7	76.9	72.1	65.9	57.7	(31)
(32)		5%	MCDWB	59.6	65.1	68.8	76.2	79.9	85.5	88.6	88.3	85.6	78.9	70.2	61.1	(32)
(33)		10%	WB	52.5	56.9	61.3	68.6	73.3	77.1	78.3	78.0	75.9	70.5	63.7	54.9	(33)
(34)		10%	MCDWB	56.1	61.5	65.6	73.3	77.5	84.0	87.5	87.1	84.1	77.4	68.3	58.7	(34)
(35)	Mean Daily Temperature Range		MDBR	13.4	13.7	14.1	14.7	14.4	12.4	15.7	15.0	15.6	16.7	16.0	15.9	(35)
(36)		5% DB	MCDBR	20.5	21.4	22.8	22.0	21.9	18.5	20.0	19.3	18.9	20.3	21.4	20.8	(36)
(37)		5% DB	MCWBR	11.2	11.1	10.2	8.6	7.2	5.2	4.7	4.5	5.0	6.7	9.1	11.2	(37)
(38)		5% WB	MCDBR	15.1	17.7	16.7	15.6	13.0	14.2	16.7	16.2	16.2	14.2	12.7	12.7	(38)
(39)		5% WB	MCWBR	9.0	10.0	8.9	7.2	5.4	4.8	5.0	4.7	5.0	5.3	6.6	8.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.684	0.736	0.814	0.794	0.705	0.676	0.627	0.682	0.679	0.687	0.634	0.617	(40)	
(41)		taud	1.507	1.450	1.368	1.441	1.627	1.693	1.812	1.678	1.657	1.577	1.635	1.626	(41)	
(42)		Ebn at Noon	175	180	178	189	208	213	224	210	204	189	186	184	(42)	
(43)		Edh at Noon	80	91	105	100	83	77	68	78	77	79	70	68	(43)	
(44)	All-Sky Solar Radiation	RadAvg	703	796	965	1125	1248	1246	1734	1535	1334	1166	857	787	(44)	
(45)		RadStd	148	193	126	162	196	174	164	138	110	190	137	155	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.52	N/A	N/A	+0.95	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	+0.54	N/A	N/A	+0.79	N/A	N/A	N/A	N/A	+198	+121

Nomenclature: See separate page