

PUCHENG, China

WMO: 587310

Lat: 27.9232N

Lon: 118.5418E

Elev: 902

StdP: 14.22

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.8	31.4	15.9	12.7	43.9	20.8	16.1	42.3	17.9	43.6	16.1	45.0	1.8	20	0.323

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.2	95.5	77.3	93.6	77.3	91.7	76.8	79.8	89.1	79.0	88.3	78.3	87.1	5.6	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.8	149.4	82.2	76.9	145.1	81.8	76.2	141.4	81.4	44.2	89.2	43.4	88.3	42.6	87.7	84.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.9	12.6	10.5	DB	24.4	98.8	2.4	2.3	22.7	100.4	21.3	101.8	20.0	103.1	18.2	104.8	
			WB	23.6	81.4	2.7	1.4	21.7	82.4	20.1	83.2	18.6	84.0	16.7	84.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	65.4	45.3	49.4	55.7	65.3	72.5	77.5	82.9	82.3	77.1	68.9	58.7	48.5
	DBStd	14.24	6.69	8.06	7.31	6.54	4.56	4.45	3.15	3.31	5.27	5.53	6.57	6.34
	HDD50	421	178	102	27	1	0	0	0	0	0	0	10	103
	HDD65	2171	610	440	300	74	4	0	0	0	1	23	208	511
	CDD50	6057	33	85	204	461	699	826	1020	1002	814	586	270	57
	CDD65	2330	0	2	12	84	237	376	555	537	364	145	18	0
	CDH74	20678	2	20	104	538	1528	2990	6080	5447	2980	896	92	1
	CDH80	8276	0	1	12	118	466	1065	2794	2408	1180	221	11	0
Wind	WSAvg	3.7	3.7	3.8	3.8	3.8	3.6	3.7	3.9	3.7	3.6	3.5	3.4	3.7
Precipitation	PrecAvg	66.4	2.5	4.1	6.7	8.9	11.1	13.6	4.8	4.3	3.9	2.4	2.2	1.7
	PrecMax	94.2	6.0	7.3	12.8	18.4	24.1	22.9	12.8	9.3	10.0	4.8	5.6	4.4
	PrecMin	43.6	0.0	0.2	2.1	2.9	4.7	5.9	0.7	0.7	0.2	0.0	0.1	0.0
	PrecStd	11.8	1.6	1.9	2.9	3.7	5.3	3.9	3.0	2.0	2.1	1.6	1.7	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.0	77.1	81.2	87.3	91.3	93.7	98.6	98.3	95.8	89.3	81.5	70.2
		MCWB	59.2	63.5	65.9	69.5	71.4	77.1	77.4	77.8	76.1	73.1	66.9	59.6
	2%	DB	64.5	71.9	76.9	83.3	88.1	91.2	95.7	95.6	92.5	85.5	76.6	65.4
		MCWB	55.1	60.4	63.0	67.6	70.8	76.2	77.6	77.5	75.9	70.8	64.1	55.6
	5%	DB	60.2	66.7	72.2	80.2	85.3	88.9	93.9	93.4	89.9	82.1	72.8	62.1
		MCWB	52.1	57.3	60.7	66.4	70.1	75.6	77.6	77.5	75.4	68.0	61.8	54.3
	10%	DB	56.1	61.9	67.5	76.8	82.2	86.4	91.9	91.1	87.2	79.0	69.3	58.7
		MCWB	49.8	54.6	58.3	64.9	69.8	75.2	77.4	77.4	74.5	66.4	60.6	52.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.5	65.6	68.7	73.2	77.4	80.0	80.9	80.9	79.4	75.5	70.0	62.9
		MCDB	66.5	73.3	78.2	81.9	84.4	87.9	89.5	90.7	89.5	83.9	77.4	66.7
	2%	WB	57.6	61.9	66.0	71.4	75.8	78.6	79.9	79.7	78.1	73.5	67.3	59.3
		MCDB	63.1	69.4	73.0	79.2	82.0	86.5	88.9	89.6	87.1	81.1	72.6	63.5
	5%	WB	54.0	58.9	63.4	69.7	74.3	77.8	79.0	78.9	77.1	71.8	65.2	56.5
		MCDB	58.7	65.3	68.5	75.6	79.5	84.9	88.4	88.6	85.1	77.9	69.3	59.7
	10%	WB	50.9	55.9	60.6	68.0	72.9	77.0	78.3	78.1	76.0	70.0	62.8	53.6
		MCDB	54.4	60.7	65.3	72.8	77.5	83.3	87.4	87.2	83.5	76.0	67.6	57.2
Mean Daily Temperature Range	5% DB	MDBR	14.3	14.7	15.4	15.9	15.2	12.9	16.2	16.1	16.5	18.0	17.3	16.6
		MCDBR	23.2	24.0	24.5	23.1	22.6	18.4	20.5	20.6	20.3	22.4	23.6	23.4
		MCWBR	12.9	12.5	10.8	8.7	7.5	5.5	5.0	5.0	5.4	7.4	10.2	12.5
	5% WB	MCDBR	18.3	19.9	18.1	16.2	13.7	14.4	17.2	17.7	17.2	16.1	15.0	14.9
		MCWBR	11.1	11.2	9.7	7.5	6.1	5.3	5.4	5.3	5.5	6.1	7.6	9.3
Clear-Sky Solar Irradiance	taub	0.605	0.654	0.728	0.714	0.638	0.620	0.580	0.619	0.615	0.611	0.565	0.549	
	taud	1.645	1.586	1.491	1.565	1.758	1.819	1.933	1.821	1.795	1.725	1.777	1.761	
	Ebn at Noon	195	200	196	206	223	226	234	224	219	208	205	203	
	Edh at Noon	69	80	92	88	73	68	61	67	67	68	60	59	
All-Sky Solar Radiation	RadAvg	713	813	994	1156	1271	1253	1743	1543	1333	1170	855	789	
	RadStd	146	196	124	162	198	176	172	141	109	186	131	151	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	+0.81	N/A	N/A	N/A	N/A	N/A	N/A
Regional (8 neighbors)	+0.49	N/A	N/A	+0.83	N/A	N/A	N/A	N/A	+175	+101

Nomenclature: See separate page