

FUDING, China

WMO: 587540

Lat: 27.3351N

Lon: 120.2071E

Elev: 125

StdP: 14.63

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	34.3	36.9	19.3	14.6	46.1	23.9	18.2	45.2	12.0	50.2	10.1	51.4	1.8	20	0.311

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.4	94.8	79.7	93.0	79.2	91.3	78.7	81.6	91.3	80.7	89.7	79.9	88.1	7.7	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.1	151.6	86.6	78.3	147.6	85.5	77.7	144.7	84.8	45.6	91.8	44.6	90.2	43.7	88.6	84.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
12.0	10.3	9.0	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			29.9	99.0	2.6	2.3	28.0	100.6	26.4	102.0	24.9	103.2	23.0	104.9
			27.8	83.2	2.7	1.2	25.8	84.1	24.2	84.8	22.7	85.4	20.7	86.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	67.4	49.6	51.2	56.4	64.7	72.3	78.5	84.4	83.8	79.1	71.5	62.8	53.7
	DBStd	13.25	6.11	6.67	6.30	6.20	4.71	5.05	2.87	2.54	4.33	4.77	5.93	5.99
	HDD50	186	83	58	14	0	0	0	0	0	0	0	1	30
	HDD65	1691	476	387	276	80	4	0	0	0	0	6	110	352
	CDD50	6549	72	93	211	442	692	855	1066	1049	873	665	385	146
	CDD65	2578	0	2	8	71	231	405	601	584	423	207	44	2
	CDH74	24216	1	11	41	331	1280	3567	7274	6752	3788	1045	123	3
	CDH80	9118	0	0	4	60	300	1258	3250	2807	1238	190	11	0
Wind	WSAvg	3.4	2.9	3.1	3.1	3.2	3.2	3.3	4.2	4.1	3.7	3.5	3.0	3.0
Precipitation	PrecAvg	66.0	2.0	3.0	5.1	6.3	8.3	9.0	5.2	10.4	9.6	3.4	2.3	1.4
	PrecMax	97.8	5.5	6.1	10.0	15.6	16.1	15.1	16.1	29.8	26.0	20.0	9.7	3.6
	PrecMin	41.2	0.0	0.1	1.3	2.0	3.0	3.3	0.0	2.9	0.0	0.0	0.0	0.0
	PrecStd	13.4	1.5	1.6	2.4	3.0	3.4	3.0	3.5	6.5	6.7	3.9	2.2	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.6	75.7	78.9	85.3	89.9	95.0	98.2	96.7	93.7	88.1	81.6	73.3
		MCWB	60.7	63.5	65.4	72.1	76.1	80.2	80.2	79.7	78.4	74.0	69.2	63.5
	2%	DB	65.9	69.5	73.6	81.4	86.1	92.1	95.4	94.1	90.9	84.6	77.5	68.5
		MCWB	58.0	60.0	62.8	69.5	73.7	79.7	80.0	79.3	77.0	71.6	66.9	60.0
	5%	DB	61.9	64.9	69.8	77.9	83.3	89.6	93.5	92.3	89.0	81.8	74.5	65.4
		MCWB	55.3	57.6	60.7	67.6	72.1	79.0	79.6	78.8	76.3	69.6	65.5	58.3
	10%	DB	58.4	60.7	65.9	74.5	80.7	86.9	91.6	90.6	86.6	79.5	71.7	62.6
		MCWB	52.8	54.8	58.3	65.7	70.9	77.6	79.1	78.5	75.0	68.6	64.3	56.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.0	65.2	67.7	74.2	78.7	82.4	82.8	82.6	81.3	77.4	72.5	65.8
		MCDB	68.2	73.3	75.2	82.2	87.3	91.6	93.1	93.0	90.5	82.8	78.2	69.8
	2%	WB	59.4	61.7	64.7	71.8	76.7	80.9	81.7	81.2	79.6	75.5	69.9	63.0
		MCDB	64.2	68.0	71.2	78.7	83.3	89.4	91.6	90.4	86.8	81.0	74.5	66.7
	5%	WB	56.6	58.7	62.3	69.7	75.0	79.8	80.8	80.3	78.4	73.6	68.0	60.2
		MCDB	60.9	63.9	67.9	75.4	80.3	87.4	90.3	88.6	84.8	79.1	72.3	63.8
	10%	WB	54.0	55.8	59.9	67.7	73.3	78.7	80.0	79.6	77.4	71.6	65.9	57.8
		MCDB	57.4	60.0	64.5	72.9	78.1	85.4	88.7	87.2	83.4	76.8	70.0	61.1
Mean Daily Temperature Range	5% DB	MDBR	12.7	12.8	13.7	14.2	13.1	11.7	13.4	12.8	12.8	13.9	13.4	14.1
		MCDBR	19.3	20.6	20.9	19.4	17.8	15.4	16.9	16.0	15.4	17.0	17.2	18.2
		MCWBR	11.2	11.7	10.9	9.1	7.5	5.6	5.2	5.0	4.7	5.9	7.6	9.7
	5% WB	MCDBR	15.7	18.7	17.5	16.2	13.8	14.4	14.9	13.9	12.9	12.1	12.1	12.9
		MCWBR	10.0	11.6	10.4	8.5	7.0	6.0	5.4	5.2	4.6	5.4	6.9	8.7
Clear-Sky Solar Irradiance	taub	0.582	0.635	0.697	0.699	0.636	0.608	0.561	0.594	0.585	0.587	0.565	0.546	
	taud	1.725	1.657	1.572	1.622	1.791	1.881	2.010	1.912	1.904	1.820	1.826	1.813	
	Ebn at Noon	203	206	203	209	223	228	239	230	227	215	207	206	
	Edh at Noon	64	74	85	83	70	64	56	62	60	62	58	57	
All-Sky Solar Radiation	RadAvg	717	814	1045	1194	1282	1341	1831	1622	1341	1158	805	760	
	RadStd	153	186	109	143	202	159	174	141	134	204	125	133	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	+0.76	N/A	N/A	N/A	N/A	N/A	N/A
Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page