

NANJI SHAN, China

WMO: 587650

Lat: 27.4619N

Lon: 121.0779E

Elev: 364

StdP: 14.50

Time Zone: 8.00 (E08)

Period: 83-94

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	36.9	38.4	17.8	13.7	40.3	21.4	16.2	41.9	39.9	42.1	38.5	43.0	23.9	20	0.626

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.4	85.7	79.6	84.7	79.2	83.7	78.9	80.9	83.8	80.3	83.1	79.8	82.6	11.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.0	157.8	82.9	79.4	154.6	82.4	78.9	152.2	82.0	44.9	84.0	44.3	83.6	43.8	82.8	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 38.6	34.7	31.9	DB	32.9	88.5	3.2	1.3	30.6	89.4	28.7	90.2	26.9	91.0	24.6	91.9	(4)
(5)			WB	28.4	81.7	2.1	0.8	26.9	82.2	25.6	82.7	24.4	83.1	22.9	83.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.6	46.8	46.0	49.5	57.5	66.5	74.4	80.0	81.2	77.9	69.9	61.5	51.2		
	DBStd	13.38	4.77	4.22	4.44	4.73	4.78	3.66	2.28	1.87	3.49	3.89	5.71	5.99		
	HDD50	376	121	123	65	4	0	0	0	0	0	0	3	60		
	HDD65	2407	564	531	482	229	41	0	0	0	0	0	127	427		
	CDD50	5350	22	12	48	228	513	732	929	967	836	617	349	97		
	CDD65	1907	0	0	0	3	88	283	464	502	386	158	23	0		
	CDH74	14233	0	0	0	0	46	1298	4410	5253	2960	257	9	0		
	CDH80	2290	0	0	0	0	1	59	699	1134	388	8	1	0		
(14) Wind	WSAvg	16.0	19.0	18.2	15.7	11.6	12.3	14.1	14.3	14.4	16.6	18.9	18.7	17.9		
(15) Precipitation	PrecAvg	55.7	2.6	3.3	5.2	5.0	6.2	7.7	4.4	7.5	5.9	2.5	3.0	2.3		
	PrecMax	71.9	7.0	6.0	10.9	8.3	12.8	14.3	16.7	16.6	15.1	9.4	7.5	7.8		
	PrecMin	32.9	0.3	0.7	1.6	1.1	1.7	1.1	0.1	0.9	0.6	0.1	0.1	0.2		
	PrecStd	10.0	1.5	1.5	2.4	2.1	3.1	3.4	3.7	3.9	4.2	2.6	1.9	1.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.4	60.2	63.3	70.1	76.8	82.7	87.2	87.2	85.0	81.0	74.4	64.8		
		MCWB	55.7	54.2	61.3	67.0	72.9	78.3	80.0	79.4	78.2	76.3	71.2	59.6		
	2%	DB	56.3	56.5	60.7	67.9	75.3	81.5	86.0	85.7	83.8	78.7	71.5	62.1		
		MCWB	53.3	53.7	58.2	65.7	72.5	78.0	80.2	79.3	78.1	75.4	68.9	58.3		
	5%	DB	54.2	53.8	58.0	66.1	74.0	80.5	84.9	84.8	82.9	77.0	69.3	60.6		
		MCWB	51.6	51.2	54.9	64.0	71.4	77.5	79.9	79.1	78.0	74.2	66.6	56.8		
	10%	DB	52.6	52.0	55.6	64.1	72.9	79.5	83.7	84.0	82.0	74.7	68.0	58.9		
		MCWB	49.8	49.6	53.2	61.8	70.4	77.0	79.5	78.9	77.8	70.2	65.1	54.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.9	56.8	62.3	67.9	74.3	79.5	81.7	81.8	80.8	77.9	72.4	61.1		
		MCDB	59.5	58.4	62.6	68.7	75.3	81.4	85.3	84.7	82.8	79.5	73.8	63.2		
	2%	WB	54.2	54.3	58.8	66.4	73.2	78.6	80.9	81.0	79.8	76.6	69.1	59.5		
		MCDB	55.8	55.8	59.7	67.6	74.5	80.5	84.2	83.7	82.1	78.4	70.8	61.9		
	5%	WB	52.4	52.0	55.8	64.7	72.3	78.0	80.4	80.4	79.1	74.6	67.8	57.4		
		MCDB	54.0	53.5	57.4	65.8	73.7	79.9	83.5	83.1	81.8	76.7	69.2	60.1		
	10%	WB	50.2	50.1	53.7	62.4	70.9	77.3	79.9	79.9	78.6	71.7	66.2	55.2		
		MCDB	52.1	51.6	55.2	63.6	72.5	79.3	82.8	82.7	81.4	74.1	67.9	58.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.0	4.4	5.2	5.5	5.2	4.5	4.2	4.4	4.6	4.5	5.0	5.7		
		MCDBR	8.4	7.6	9.7	7.8	7.0	5.3	6.5	5.4	5.3	6.7	6.1	7.7		
	5% WB	MCWBR	6.8	6.1	7.2	5.4	4.5	3.1	2.5	2.7	3.0	4.3	5.0	6.0		
		MCWBR	7.8	6.5	8.4	7.1	5.5	5.2	4.8	4.4	4.4	6.0	6.4	7.0		
(40) Clear-Sky Solar Irradiance	taub		0.571	0.621	0.674	0.677	0.621	0.589	0.542	0.567	0.557	0.556	0.554	0.543		
		taud	1.761	1.690	1.617	1.669	1.831	1.950	2.089	2.012	1.998	1.911	1.865	1.830		
	Ebn at Noon		207	209	208	214	226	233	244	237	234	224	210	207		
		Edh at Noon	62	72	82	79	68	60	52	56	55	57	56	56		
(44) All-Sky Solar Radiation	RadAvg		693	787	1059	1213	1325	1402	1959	1747	1437	1191	793	728		
	RadStd		150	187	102	137	201	165	161	147	141	191	113	127		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)		N/A	N/A	N/A	+0.74	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page