

NANJI SHAN, China

WMO: 587650

Lat: 27.4619N

Lon: 121.0779E

Elev: 111

StdP: 100.00

Time Zone: 8.00 (E08)

Period: 83-94

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	2.7	3.6	-7.9	2.0	4.6	-5.9	2.3	5.5	17.8	5.6	17.2	6.1	10.7	20	0.626

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.5	29.8	26.5	29.3	26.2	28.7	26.0	27.2	28.8	26.8	28.4	26.6	28.1	4.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.7	22.5	28.3	26.3	22.1	28.0	26.1	21.7	27.8	86.5	28.9	85.3	28.6	84.1	28.2	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
17.3	15.5	14.3	DB	0.5	31.4	1.8	0.7	-0.8	31.9	-1.8	32.3	-2.8	32.8	-4.1	33.3
			WB	-2.0	27.6	1.2	0.4	-2.8	27.9	-3.5	28.1	-4.2	28.4	-5.1	28.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.6	8.2	7.8	9.7	14.2	19.2	23.6	26.6	27.3	25.5	21.1	16.4	10.7	(6)
	DBStd	7.43	2.65	2.34	2.46	2.63	2.65	2.04	1.27	1.04	1.94	2.16	3.17	3.33	(7)
	HDD10.0	209	67	68	36	2	0	0	0	0	0	0	2	33	(8)
	HDD18.3	1337	313	295	268	127	23	0	0	0	0	3	71	237	(9)
	CDD10.0	2972	12	7	27	127	285	407	516	537	464	343	194	54	(10)
	CDD18.3	1059	0	0	0	2	49	157	258	279	214	88	13	0	(11)
	CDH23.3	7907	0	0	0	0	26	721	2450	2918	1644	143	5	0	(12)
	CDH26.7	1272	0	0	0	0	1	33	388	630	216	4	1	0	(13)
(14) Wind	WSAvg	7.1	8.5	8.2	7.0	5.2	5.5	6.3	6.4	6.4	7.4	8.4	8.4	8.0	(14)
(15) Precipitation	PrecAvg	1415	66	84	132	127	158	195	112	191	150	64	77	59	(15)
	PrecMax	1825	179	152	277	211	324	362	423	422	383	240	190	197	(16)
	PrecMin	835	7	18	40	28	42	29	3	24	14	2	2	4	(17)
	PrecStd	255	38	39	61	53	80	87	95	100	107	66	47	48	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.8	15.7	17.4	21.2	24.9	28.2	30.7	30.7	29.4	27.2	23.5	18.2	(19)
		MCWB	13.2	12.3	16.3	19.4	22.7	25.7	26.7	26.3	25.7	24.6	21.8	15.3	(20)
	2%	DB	13.5	13.6	15.9	19.9	24.1	27.5	30.0	29.9	28.8	25.9	22.0	16.7	(21)
		MCWB	11.9	12.0	14.5	18.7	22.5	25.6	26.8	26.3	25.6	24.1	20.5	14.6	(22)
	5%	DB	12.4	12.1	14.5	19.0	23.4	27.0	29.4	29.4	28.3	25.0	20.7	15.9	(23)
		MCWB	10.9	10.7	12.7	17.8	21.9	25.3	26.6	26.2	25.6	23.4	19.2	13.8	(24)
	10%	DB	11.4	11.1	13.1	17.9	22.7	26.4	28.7	28.9	27.8	23.7	20.0	15.0	(25)
		MCWB	9.9	9.8	11.8	16.6	21.3	25.0	26.4	26.0	25.4	21.2	18.4	12.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.8	13.8	16.8	19.9	23.5	26.4	27.6	27.7	27.1	25.5	22.5	16.1	(27)
		MCDB	15.3	14.6	17.0	20.4	24.1	27.4	29.6	29.3	28.2	26.4	23.2	17.3	(28)
	2%	WB	12.3	12.4	14.9	19.1	22.9	25.9	27.2	27.2	26.6	24.8	20.6	15.3	(29)
		MCDB	13.2	13.2	15.4	19.8	23.6	26.9	29.0	28.7	27.9	25.8	21.5	16.6	(30)
	5%	WB	11.3	11.1	13.2	18.2	22.4	25.6	26.9	26.9	26.2	23.7	19.9	14.1	(31)
		MCDB	12.2	11.9	14.1	18.8	23.1	26.6	28.6	28.4	27.6	24.8	20.7	15.6	(32)
	10%	WB	10.1	10.0	12.0	16.9	21.6	25.2	26.6	26.6	25.9	22.0	19.0	12.9	(33)
		MCDB	11.2	10.9	12.9	17.6	22.5	26.3	28.2	28.2	27.4	23.4	19.9	14.5	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	2.8	2.4	2.9	3.0	2.9	2.5	2.3	2.5	2.5	2.5	2.8	3.1	(35)
		MCDBR	4.7	4.2	5.4	4.3	3.9	3.0	3.6	3.0	3.0	3.7	3.4	4.3	(36)
	5% WB	MCWBR	3.8	3.4	4.0	3.0	2.5	1.7	1.4	1.5	1.7	2.4	2.8	3.3	(37)
		MCWBR	4.3	3.6	4.7	4.0	3.1	2.9	2.9	2.7	2.4	3.3	3.6	3.9	(38)
(40) Clear-Sky Solar Irradiance	taub		0.571	0.621	0.674	0.677	0.621	0.589	0.542	0.567	0.557	0.556	0.554	0.543	(40)
		taud	1.761	1.690	1.617	1.669	1.831	1.950	2.089	2.012	1.998	1.911	1.865	1.830	(41)
	Ebn at Noon		651	659	657	675	714	733	768	747	739	706	663	653	(42)
		Edh at Noon	196	227	257	250	213	188	163	175	173	179	175	175	(43)
(44) All-Sky Solar Radiation	RadAvg		2.19	2.48	3.34	3.82	4.18	4.42	6.17	5.51	4.53	3.75	2.50	2.29	(44)
	RadStd		0.47	0.59	0.32	0.43	0.63	0.52	0.51	0.46	0.45	0.60	0.36	0.40	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	+0.41	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page