

NANPING, China

WMO: 588340

Lat: 26.6484N

Lon: 118.1726E

Elev: 153

StdP: 99.50

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.1	3.4	-6.1	2.3	9.0	-3.4	2.9	8.0	4.4	10.4	3.9	9.6	1.1	20	0.302

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.8	36.4	25.3	35.4	25.3	34.4	25.2	26.9	32.7	26.5	31.9	26.2	31.2	2.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.7	21.4	28.4	25.3	20.9	28.2	25.0	20.4	28.1	86.0	32.8	84.1	32.1	82.5	31.3	28.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4.3	3.5	3.1	-0.3	37.8	1.5	1.1	-1.4	38.5	-2.3	39.2	-3.1	39.8	-4.2	40.6
			-1.3	27.7	1.8	0.7	-2.6	28.1	-3.6	28.5	-4.6	28.9	-5.9	29.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.8	10.6	12.6	15.7	20.4	24.2	27.0	29.6	29.3	26.9	22.7	17.5	12.2	
	DBStd	7.35	3.72	4.45	4.01	3.70	2.81	2.53	1.78	1.80	2.71	2.91	3.48	3.50	
	HDD10.0	81	37	21	3	0	0	0	0	0	0	0	1	18	
	HDD18.3	784	239	167	103	22	1	0	0	0	0	3	56	194	
	CDD10.0	4012	57	94	179	313	440	509	609	599	508	393	225	84	
	CDD18.3	1674	1	6	21	84	183	259	351	341	258	138	29	3	
	CDH23.3	16469	3	37	122	511	1328	2503	4367	4059	2576	854	102	6	
	CDH26.7	7027	0	6	23	149	451	1021	2178	1919	1049	217	14	0	
Wind	WSAvg	1.3	1.3	1.3	1.3	1.2	1.3	1.3	1.5	1.5	1.4	1.3	1.2	1.2	
Precipitation	PrecAvg	1622	58	95	180	216	280	270	132	121	107	64	49	37	
	PrecMax	2041	198	220	316	450	546	653	393	232	285	199	142	147	
	PrecMin	921	1	5	32	78	112	68	13	34	31	0	0	1	
	PrecStd	258	52	46	87	92	117	129	94	54	51	52	39	34	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.2	27.3	29.3	32.5	34.6	36.1	37.9	37.6	36.0	33.1	28.5	23.9	
		MCWB	16.6	18.7	20.5	22.2	23.9	25.8	25.1	25.0	25.1	23.7	20.9	18.5	
	2%	DB	20.2	24.1	26.5	30.3	32.5	34.7	36.6	36.2	34.6	30.7	26.0	20.6	
		MCWB	14.9	17.4	18.6	21.5	22.9	25.3	25.2	25.3	24.8	22.4	19.2	16.0	
	5%	DB	18.2	21.6	24.1	28.4	30.9	33.4	35.6	35.1	33.4	29.0	24.2	18.8	
		MCWB	13.9	16.2	17.8	20.8	22.3	25.0	25.3	25.5	24.5	21.4	18.3	14.9	
	10%	DB	16.3	19.1	21.9	26.4	29.3	32.0	34.5	34.0	32.0	27.5	22.6	17.1	
		MCWB	12.7	14.9	16.9	20.0	22.2	24.7	25.3	25.4	24.0	20.4	17.7	13.7	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.7	19.7	21.7	23.7	26.0	27.2	27.6	27.4	26.9	24.9	22.5	19.1
			MCDB	21.1	25.0	27.6	28.4	30.3	32.5	33.8	33.3	33.3	29.4	26.4	21.9
2%		WB	16.0	18.2	20.3	22.9	25.2	26.5	27.0	26.8	26.1	24.0	21.1	17.4	
		MCDB	19.2	22.4	24.5	27.7	29.2	31.6	32.9	32.4	31.4	27.6	23.9	19.8	
5%		WB	14.5	17.0	19.2	22.2	24.5	26.1	26.5	26.4	25.6	23.2	20.1	15.9	
		MCDB	17.5	20.6	22.4	26.6	28.1	30.8	32.0	31.7	30.3	26.8	22.8	17.8	
10%		WB	13.3	15.5	17.9	21.4	23.8	25.6	26.1	26.0	25.1	22.4	19.0	14.5	
		MCDB	15.6	18.6	21.1	24.9	27.1	29.9	31.2	31.1	29.4	26.1	21.4	16.5	
Mean Daily Temperature Range	5% DB	MDBR	6.6	7.0	7.5	7.9	7.7	7.3	8.8	8.3	7.8	8.0	7.5	7.3	
		MCDBR	9.7	11.2	11.7	11.4	11.0	10.1	10.7	10.3	9.8	9.7	9.7	9.5	
		MCWBR	4.8	5.2	4.9	4.0	3.3	2.4	2.3	2.3	2.1	2.8	3.8	4.7	
	5% WB	MCDBR	8.0	9.8	9.7	9.1	7.9	8.5	9.1	9.0	8.6	7.4	7.2	6.6	
		MCWBR	4.3	5.1	4.9	3.8	3.0	2.6	2.6	2.5	2.3	2.7	3.4	3.6	
Clear-Sky Solar Irradiance	taub	0.589	0.639	0.718	0.704	0.613	0.578	0.544	0.590	0.588	0.587	0.549	0.536		
	taud	1.705	1.645	1.536	1.608	1.840	1.945	2.046	1.903	1.883	1.808	1.851	1.827		
	Ebn at Noon	640	648	628	657	721	742	767	730	716	682	673	664		
	Edh at Noon	209	238	280	267	211	189	171	196	195	199	179	178		
All-Sky Solar Radiation	RadAvg	2.35	2.66	3.08	3.56	3.94	4.15	5.51	4.95	4.25	3.71	2.75	2.55		
	RadStd	0.49	0.57	0.47	0.51	0.62	0.50	0.53	0.40	0.38	0.65	0.40	0.47		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+0.31	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (11 neighbors)	+0.27	N/A	N/A	+0.43	N/A	N/A	N/A	N/A	+94	+72

Nomenclature: See separate page