

FUZHOU, China

WMO: 588470

Lat: 26.0776N

Lon: 119.2890E

Elev: 279

StdP: 14.55

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 40.7	(c) 42.7	(d) 23.9	(e) 18.2	(f) 47.7	(g) 28.0	(h) 22.2	(i) 48.0	(j) 24.7	(k) 50.5	(l) 23.0	(m) 49.8	(n) 7.2	(o) 320	(p) 0.388

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 13.7	(c) 95.8	(d) 79.8	(e) 93.5	(f) 79.5	(g) 91.6	(h) 79.2	(i) 81.9	(j) 90.9	(k) 81.0	(l) 89.3	(m) 80.3	(n) 87.9	(o) 9.1	(p) 140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.2	153.3	86.4	78.9	151.8	86.0	78.4	149.1	85.4	46.1	91.8	45.2	89.7	44.4	88.7	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 23.7	(b) 21.0	(c) 18.7	(e) 36.6	(f) 100.3	(g) 2.7	(h) 1.7	(i) 34.7	(j) 101.4	(k) 33.2	(l) 102.4	(m) 31.7	(n) 103.3	(o) 29.7	(p) 104.5		
(a) 32.2	(b) 83.8	(c) 2.9	(e) 32.2	(f) 83.8	(g) 2.9	(h) 1.2	(i) 30.1	(j) 84.7	(k) 28.3	(l) 85.3	(m) 26.7	(n) 86.0	(o) 24.6	(p) 86.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	69.9	53.4	54.3	58.7	67.0	74.2	80.5	85.7	84.9	80.8	74.0	66.2	57.4		
	DBStd	12.58	5.91	6.74	6.68	6.61	5.12	5.07	3.21	3.08	4.24	4.53	5.42	5.56		
	HDD50	71	30	28	6	0	0	0	0	0	0	0	0	7		
	HDD65	1232	362	306	216	53	3	0	0	0	0	1	48	243		
	CDD50	7318	135	147	278	512	749	915	1108	1082	925	744	487	236		
	CDD65	3004	2	5	22	115	287	465	643	617	476	280	85	7		
	CDH74	27887	5	24	98	556	1646	4366	7791	7289	4535	1372	197	8		
	CDH80	10692	0	1	15	131	420	1602	3596	3154	1494	252	27	0		
(14) Wind	WSAvg	7.8	7.8	7.5	7.1	6.7	6.6	7.4	8.7	8.2	8.4	9.2	8.3	8.3		
(15) Precipitation	PrecAvg	53.2	1.9	2.8	5.2	6.4	7.6	8.4	3.5	6.9	5.8	1.7	1.5	1.1		
	PrecMax	81.7	8.0	7.6	12.8	11.9	12.9	16.4	12.0	24.1	20.1	5.8	5.5	3.9		
	PrecMin	30.6	0.0	0.0	0.9	0.5	3.6	0.6	0.2	0.6	0.3	0.0	0.0	0.0		
	PrecStd	8.9	1.9	1.7	3.0	2.9	3.0	3.9	2.9	5.1	4.7	1.5	1.4	1.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.4	77.5	82.0	88.1	91.2	95.8	99.2	98.0	94.9	88.8	83.5	74.7		
		MCWB	62.3	65.2	68.4	73.4	77.2	80.4	80.1	79.8	79.1	75.1	70.7	65.3		
	2%	DB	68.3	71.9	76.5	83.9	87.4	92.7	96.6	95.0	91.4	85.5	78.9	70.2		
		MCWB	59.2	62.9	66.1	72.2	75.5	79.7	79.8	79.7	78.2	73.3	68.4	61.9		
	5%	DB	64.5	67.6	72.1	80.2	84.5	90.2	94.1	92.8	89.2	82.7	75.6	67.5		
		MCWB	57.3	59.9	63.3	70.6	74.3	79.3	79.6	79.6	77.2	71.6	66.8	60.5		
	10%	DB	61.1	63.3	68.3	76.7	81.9	87.8	91.8	90.9	87.0	80.4	73.4	64.8		
		MCWB	55.6	57.3	60.9	68.8	72.8	78.8	79.4	79.2	76.3	70.7	66.0	58.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.9	67.4	70.5	75.7	79.2	82.5	83.3	83.1	81.6	78.7	73.0	67.4		
		MCDB	69.4	74.9	79.1	84.8	86.9	92.1	94.5	92.9	89.9	84.1	79.6	71.9		
	2%	WB	61.1	63.9	67.6	73.8	77.8	81.1	81.8	81.8	80.1	76.4	71.0	64.6		
		MCDB	66.8	70.4	74.1	81.2	84.6	89.4	91.4	90.2	87.0	81.8	76.2	68.7		
	5%	WB	58.6	61.1	64.7	72.1	76.3	80.1	81.0	80.9	79.1	74.5	69.2	62.1		
		MCDB	63.4	66.7	71.1	78.3	82.2	87.6	89.8	88.4	85.4	80.3	74.0	66.0		
	10%	WB	56.3	57.9	62.0	70.1	74.8	79.2	80.2	80.0	78.3	72.6	67.4	59.9		
		MCDB	60.4	62.6	67.1	75.5	80.0	85.7	88.3	87.1	84.3	78.5	72.0	63.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.7	11.9	13.5	14.0	12.9	11.9	13.7	12.8	11.5	11.5	11.0	11.2		
		MCDBR	16.8	19.6	20.9	19.7	17.5	15.3	16.8	16.1	14.4	14.3	14.7	15.4		
	5% WB	MCWBR	9.2	11.3	11.3	9.6	7.7	5.8	5.4	5.5	5.2	6.0	6.9	8.6		
		MCWBR	14.6	18.8	19.6	17.8	15.2	14.3	15.1	14.3	13.1	12.1	12.5	12.4		
(40) Clear-Sky Solar Irradiance	taub		0.603	0.662	0.744	0.743	0.650	0.601	0.566	0.611	0.606	0.605	0.581	0.570		
	taud		1.696	1.619	1.503	1.551	1.767	1.893	1.985	1.857	1.848	1.783	1.800	1.777		
	Ebn at Noon		201	201	194	201	220	230	238	227	223	213	206	202		
	Edh at Noon		67	78	92	90	72	63	57	65	64	65	60	60		
(44) All-Sky Solar Radiation	RadAvg		747	849	1058	1186	1311	1411	1838	1639	1382	1158	834	772		
	RadStd		159	174	127	161	209	153	163	141	131	190	122	134		

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	DBAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	DBAvg	N/A	N/A	N/A	+0.63	N/A	N/A	N/A	+171	+140

Nomenclature: See separate page