

FUZHOU, China

WMO: 588470

Lat: 26.0776N

Lon: 119.2890E

Elev: 85

StdP: 100.31

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.8	5.9	-4.5	2.6	8.7	-2.2	3.2	8.9	11.0	10.3	10.3	9.9	3.2	320	0.388

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.6	35.5	26.6	34.2	26.4	33.1	26.2	27.7	32.7	27.2	31.8	26.8	31.1	4.1	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.9	30.2	26.1	21.7	30.0	25.8	21.3	29.7	89.3	33.2	87.3	32.0	85.3	31.5	29.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.6	9.4	8.4	2.6	37.9	1.5	0.9	1.5	38.6	0.6	39.1	-0.2	39.6	-1.3	40.3		
			0.1	28.8	1.6	0.6	-1.1	29.3	-2.0	29.6	-2.9	30.0	-4.1	30.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.0	11.9	12.4	14.9	19.5	23.4	27.0	29.9	29.4	27.1	23.3	19.0	14.1
	DBStd	6.99	3.28	3.74	3.71	3.67	2.84	2.81	1.78	1.71	2.36	2.52	3.01	3.09
	HDD10.0	39	17	16	3	0	0	0	0	0	0	0	0	4
	HDD18.3	684	201	170	120	29	2	0	0	0	1	27	135	
	CDD10.0	4066	75	82	154	284	416	508	616	601	514	413	271	131
	CDD18.3	1669	1	3	12	64	159	258	357	343	264	156	47	4
	CDH23.3	15493	3	13	54	309	914	2426	4328	4049	2519	762	109	4
	CDH26.7	5940	0	1	8	73	233	890	1998	1752	830	140	15	0
Wind	WSAvg	3.5	3.5	3.3	3.2	3.0	3.0	3.3	3.9	3.7	3.8	4.1	3.7	3.7
Precipitation	PrecAvg	1351	48	70	132	162	194	214	88	175	147	43	39	28
	PrecMax	2075	202	194	326	301	328	417	305	613	510	148	140	99
	PrecMin	777	1	0	23	13	91	16	5	14	7	0	0	0
	PrecStd	226	49	42	75	74	76	99	73	129	119	38	35	28
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.0	25.3	27.8	31.2	32.9	35.5	37.3	36.6	34.9	31.6	28.6	23.7
		MCWB	16.8	18.5	20.2	23.0	25.1	26.9	26.7	26.6	26.2	24.0	21.5	18.5
	2%	DB	20.2	22.2	24.7	28.8	30.8	33.7	35.9	35.0	33.0	29.7	26.0	21.2
		MCWB	15.1	17.2	18.9	22.3	24.1	26.5	26.6	26.5	25.7	22.9	20.2	16.6
	5%	DB	18.0	19.8	22.3	26.8	29.2	32.4	34.5	33.8	31.8	28.2	24.2	19.7
		MCWB	14.1	15.5	17.4	21.4	23.5	26.3	26.5	26.4	25.1	22.0	19.4	15.8
	10%	DB	16.2	17.4	20.2	24.8	27.7	31.0	33.2	32.7	30.6	26.9	23.0	18.2
		MCWB	13.1	14.0	16.1	20.4	22.6	26.0	26.3	26.2	24.6	21.5	18.9	14.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.7	19.7	21.4	24.3	26.2	28.0	28.5	28.4	27.6	25.9	22.8	19.7
		MCDB	20.8	23.8	26.2	29.3	30.5	33.4	34.7	33.8	32.2	28.9	26.4	22.2
	2%	WB	16.1	17.7	19.8	23.2	25.4	27.3	27.7	27.7	26.7	24.7	21.6	18.1
		MCDB	19.4	21.3	23.4	27.3	29.2	31.9	33.0	32.4	30.6	27.7	24.5	20.4
	5%	WB	14.8	16.1	18.2	22.3	24.6	26.7	27.2	27.2	26.2	23.6	20.7	16.7
		MCDB	17.5	19.3	21.7	25.7	27.9	30.9	32.1	31.4	29.7	26.9	23.4	18.9
	10%	WB	13.5	14.4	16.7	21.2	23.8	26.2	26.8	26.7	25.7	22.6	19.7	15.5
		MCDB	15.8	17.0	19.5	24.2	26.7	29.8	31.3	30.6	29.1	25.8	22.2	17.6
Mean Daily Temperature Range		MDBR	6.0	6.6	7.5	7.8	7.2	6.6	7.6	7.1	6.4	6.4	6.1	6.2
	5% DB	MCDBR	9.3	10.9	11.6	11.0	9.7	8.5	9.3	8.9	8.0	8.0	8.2	8.6
		MCWBR	5.1	6.3	6.3	5.3	4.3	3.2	3.0	3.0	2.9	3.4	3.8	4.8
	5% WB	MCDBR	8.1	10.5	10.9	9.9	8.5	7.9	8.4	7.9	7.3	6.7	7.0	6.9
		MCWBR	4.8	6.4	6.6	5.3	4.3	3.4	3.2	3.2	3.0	3.2	3.7	4.3
Clear-Sky Solar Irradiance	taub	0.603	0.662	0.744	0.743	0.650	0.601	0.566	0.611	0.606	0.605	0.581	0.570	
	taud	1.696	1.619	1.503	1.551	1.767	1.893	1.985	1.857	1.848	1.783	1.800	1.777	
	Ebn at Noon	633	634	613	633	695	725	750	715	704	670	648	638	
	Edh at Noon	212	246	290	283	227	199	181	205	202	205	189	188	
All-Sky Solar Radiation	RadAvg	2.35	2.68	3.33	3.74	4.13	4.45	5.79	5.17	4.36	3.65	2.63	2.43	
	RadStd	0.50	0.55	0.40	0.51	0.66	0.48	0.51	0.45	0.41	0.60	0.39	0.42	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (7 neighbors)	N/A	N/A	N/A	+0.35	N/A	N/A	N/A	N/A	+95	+78

Nomenclature: See separate page