

YONG'AN, China

WMO: 589210

Lat: 25.9731N

Lon: 117.3610E

Elev: 204

StdP: 98.90

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.4	3.0	-4.8	2.6	8.6	-2.2	3.2	7.2	5.7	10.2	5.0	10.6	1.3	200	0.313

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.0	36.0	25.3	35.1	25.1	34.1	25.0	26.6	32.6	26.2	32.0	25.8	31.3	2.5	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.3	20.9	28.2	24.9	20.4	28.0	24.5	20.0	27.8	84.8	32.8	82.9	32.2	81.3	31.5	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.2	4.4	3.8	DB	-1.0	37.6	1.4	0.9	-2.0	38.2	-2.8	38.8	-3.6	39.2	-4.6	39.9	(4)
			WB	-1.8	27.3	1.7	0.6	-3.0	27.8	-4.0	28.1	-4.9	28.4	-6.1	28.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.8	10.9	13.1	16.1	21.0	24.4	27.1	29.2	28.7	26.5	22.4	17.3	12.0
	DBStd	7.18	3.91	4.83	4.29	3.73	2.73	2.35	1.65	1.73	2.57	2.92	3.56	3.55
	HDD10.0	79	36	20	3	0	0	0	0	0	0	0	1	19
	HDD18.3	768	232	158	97	18	1	0	0	0	0	4	59	199
	CDD10.0	4008	64	106	193	331	446	512	594	581	495	384	221	81
	CDD18.3	1654	2	11	28	99	188	262	336	323	245	129	29	3
	CDH23.3	15629	8	74	185	657	1433	2562	3963	3540	2253	821	124	9
CDH26.7	6412	1	13	37	199	494	1042	1897	1589	901	217	21	1	
Wind	WSAvg	1.7	1.5	1.6	1.7	1.7	1.7	1.8	1.9	1.8	1.7	1.6	1.6	1.5
Precipitation	PrecAvg	1566	59	93	185	196	259	274	93	137	116	68	49	38
	PrecMax	2337	197	242	376	369	558	603	241	307	344	170	162	132
	PrecMin	1043	0	3	44	76	52	35	8	22	7	0	0	0
	PrecStd	231	56	52	103	79	105	136	58	68	67	54	39	37
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.4	28.6	29.7	32.6	34.4	35.8	37.4	37.0	35.7	32.8	29.0	24.6
		MCWB	17.2	19.2	20.6	21.9	23.5	25.6	25.2	25.2	25.3	23.5	20.8	19.2
	2%	DB	21.7	25.6	27.6	30.8	32.7	34.5	36.2	35.8	34.3	30.7	26.5	21.2
		MCWB	16.1	18.0	19.3	21.6	23.0	25.1	25.2	25.3	24.7	22.4	19.8	16.5
	5%	DB	19.2	23.2	25.4	29.1	31.2	33.3	35.2	34.7	32.9	29.1	24.5	19.1
		MCWB	14.5	17.1	18.5	21.1	22.6	24.8	25.2	25.3	24.5	21.5	18.6	14.9
	10%	DB	16.9	20.6	23.1	27.2	29.5	31.9	34.1	33.5	31.5	27.6	22.8	17.4
		MCWB	13.3	15.9	17.6	20.4	22.5	24.5	25.2	25.3	24.0	20.4	17.8	14.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.2	20.3	21.7	23.7	26.0	26.8	27.2	27.1	26.4	24.7	22.5	20.0
		MCDB	22.4	26.5	27.8	28.7	30.6	32.0	33.6	33.3	32.6	29.6	26.8	22.2
	2%	WB	16.7	18.9	20.6	22.9	25.1	26.2	26.6	26.6	25.7	23.8	21.2	17.7
		MCDB	20.4	24.4	25.4	28.2	29.7	31.3	32.8	32.6	31.4	27.8	24.5	20.5
	5%	WB	15.3	17.7	19.6	22.3	24.4	25.7	26.1	26.1	25.3	23.1	20.2	16.2
		MCDB	18.6	21.9	23.9	27.0	28.5	30.6	32.1	32.0	30.4	26.9	22.9	18.0
	10%	WB	13.9	16.4	18.5	21.6	23.8	25.3	25.7	25.7	24.8	22.3	19.0	14.7
		MCDB	16.4	20.0	22.1	25.8	27.3	30.0	31.4	31.1	29.5	26.0	21.7	16.6
Mean Daily Temperature Range	5% DB	MDBR	7.6	7.8	8.1	8.3	8.0	7.5	9.0	8.5	8.2	8.8	8.3	8.1
		MCDBR	11.6	12.2	12.3	11.7	11.4	10.2	11.0	10.9	10.3	10.6	11.0	10.7
		MCWBR	6.0	5.4	5.0	4.1	3.5	2.8	2.6	2.6	2.6	3.3	4.5	5.6
	5% WB	MCDBR	9.6	10.7	10.1	9.1	8.0	8.4	9.4	9.2	8.9	8.1	8.4	7.5
		MCWBR	5.1	5.1	4.9	3.7	3.1	2.9	2.8	2.7	2.6	2.9	3.9	4.4
Clear-Sky Solar Irradiance	taub	0.639	0.700	0.803	0.786	0.664	0.619	0.588	0.650	0.662	0.656	0.600	0.585	
	taud	1.612	1.541	1.408	1.475	1.727	1.835	1.914	1.749	1.706	1.661	1.737	1.727	
	Ebn at Noon	602	606	575	605	685	713	734	687	662	630	631	624	
	Edh at Noon	231	266	319	305	237	211	195	229	233	232	202	198	
All-Sky Solar Radiation	RadAvg	2.48	2.71	3.01	3.48	3.83	4.09	5.41	4.87	4.28	3.79	2.91	2.71	
	RadStd	0.48	0.55	0.47	0.54	0.62	0.48	0.50	0.43	0.39	0.64	0.41	0.49	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.37	N/A	N/A	+0.49	N/A	+0.17	N/A	N/A	+137	+103
Regional (11 neighbors)		+0.32	N/A	N/A	+0.43	N/A	N/A	N/A	N/A	+99	+81

Nomenclature: See separate page