

JIUXIAN SHAN, China

WMO: 589310

Lat: 25.7104N

Lon: 118.1058E

Elev: 1651

StdP: 83.00

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.6	-2.9	-19.0	0.9	2.2	-14.0	1.4	2.2	19.2	8.1	17.4	7.5	8.7	40	0.663

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.8	24.6	20.1	23.7	19.9	22.7	19.5	20.9	23.1	20.5	22.5	20.0	22.0	3.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.2	18.3	21.9	19.8	17.8	21.4	19.4	17.4	20.9	69.4	23.3	67.6	22.7	65.8	22.1	27.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 18.8	(b) 16.5	(c) 14.8	(e) -7.8	(f) 27.1	(g) 2.5	(h) 1.6	(i) -9.6	(j) 28.3	(k) -11.1	(l) 29.2	(m) -12.5	(n) 30.2	(o) -14.3	(p) 31.4		
(a) 18.8	(b) 16.5	(c) 14.8	(e) -9.1	(f) 22.2	(g) 2.3	(h) 1.4	(i) -10.7	(j) 23.2	(k) -12.0	(l) 24.0	(m) -13.3	(n) 24.7	(o) -14.9	(p) 25.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.1	5.7	7.0	9.5	13.1	16.0	18.2	19.7	19.5	17.2	13.8	10.4	6.6
	DBStd	5.85	4.22	4.50	3.84	3.23	2.40	1.87	1.62	1.60	2.41	2.80	3.48	4.06
	HDD10.0	463	140	101	54	12	1	0	0	0	0	4	36	116
	HDD18.3	2046	392	319	272	158	78	23	6	7	48	143	238	363
	CDD10.0	1591	7	15	40	104	186	246	302	295	216	121	48	11
	CDD18.3	132	0	0	0	1	5	19	49	43	13	1	0	0
	CDH23.3	115	0	0	1	0	3	13	57	34	6	1	0	0
	CDH26.7	3	0	0	0	0	0	1	2	1	0	0	0	0
Wind	WSAvg	6.7	6.1	6.7	7.4	6.9	6.4	7.9	7.2	6.4	6.3	6.5	6.4	6.2
Precipitation	PrecAvg	1720	54	79	137	173	243	260	173	230	189	84	58	40
	PrecMax	2378	186	266	280	337	464	520	362	685	440	233	159	112
	PrecMin	1387	2	9	46	81	108	51	66	34	39	0	6	0
	PrecStd	261	48	53	73	63	94	112	81	125	100	53	40	36
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.1	17.2	19.1	21.5	23.6	24.7	26.3	25.5	24.2	21.6	19.6	16.6
		MCWB	11.1	13.1	14.5	16.5	18.5	20.0	20.3	20.5	20.0	17.3	15.3	12.3
	2%	DB	13.4	15.0	16.8	19.6	21.7	23.3	24.7	24.3	22.7	19.7	17.7	14.4
		MCWB	10.6	12.0	13.3	15.7	17.5	19.7	20.1	20.3	19.4	16.7	14.1	11.4
	5%	DB	12.1	13.6	15.2	18.2	20.3	22.0	23.7	23.4	21.5	18.5	16.1	13.1
		MCWB	9.9	11.6	12.8	15.3	16.9	19.1	19.9	20.0	18.8	15.9	13.4	10.7
	10%	DB	10.9	12.4	14.1	16.9	19.1	20.8	22.7	22.3	20.4	17.4	14.9	11.9
		MCWB	9.1	11.1	12.6	15.0	16.8	18.7	19.7	19.7	18.3	15.5	12.9	9.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.0	14.6	15.8	18.1	20.2	21.1	21.5	21.6	20.7	19.1	16.9	14.1
		MCDB	13.7	15.5	17.5	19.9	22.3	23.0	24.0	23.7	22.7	20.3	18.6	14.9
	2%	WB	11.6	13.2	14.7	17.0	19.1	20.3	20.9	20.9	19.9	17.7	15.7	12.8
		MCDB	12.5	14.0	15.6	18.4	20.4	22.1	23.2	23.1	21.8	18.7	16.6	13.5
	5%	WB	10.6	12.3	13.9	16.3	18.4	19.7	20.4	20.4	19.3	16.9	14.7	11.6
		MCDB	11.5	13.1	14.7	17.4	19.3	21.2	22.6	22.5	20.8	17.8	15.4	12.6
	10%	WB	9.6	11.3	13.1	15.6	17.7	19.1	20.0	19.9	18.8	16.2	13.7	10.4
		MCDB	10.6	12.1	13.6	16.5	18.4	20.3	21.9	21.8	19.9	17.0	14.3	11.4
Mean Daily Temperature Range	5% DB	MDBR	5.6	5.3	5.4	5.2	4.6	3.9	4.8	4.4	4.5	5.0	5.4	6.0
		MCDBR	6.3	6.3	6.5	6.8	6.4	6.1	6.6	6.2	5.9	6.1	6.5	6.7
		MCWBR	4.2	4.0	4.3	4.5	4.4	3.6	3.5	3.5	3.7	4.2	4.7	4.7
	5% WB	MCDBR	5.0	5.1	5.0	5.5	4.7	5.1	5.7	5.5	5.0	4.5	4.8	5.3
		MCWBR	3.7	3.6	3.6	3.9	3.3	3.2	3.4	3.5	3.4	3.2	3.7	4.1
Clear-Sky Solar Irradiance	taub	0.423	0.465	0.533	0.533	0.464	0.441	0.421	0.460	0.458	0.442	0.408	0.397	
	taud	2.043	1.966	1.814	1.877	2.141	2.236	2.289	2.166	2.137	2.100	2.163	2.143	
	Ebn at Noon	810	805	772	785	838	851	868	836	828	818	822	820	
	Edh at Noon	149	173	212	204	156	141	134	151	152	149	131	130	
All-Sky Solar Radiation	RadAvg	2.58	2.79	3.21	3.63	3.91	4.20	5.45	4.87	4.28	3.78	2.91	2.74	
	RadStd	0.47	0.54	0.46	0.54	0.64	0.49	0.51	0.46	0.41	0.61	0.38	0.45	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	+0.46	+0.35	+0.38	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)	+0.29	N/A	N/A	+0.40	N/A	N/A	N/A	N/A	+99	+81

Nomenclature: See separate page