

PINGTAN, China

WMO: 589440

Lat: 25.5048N

Lon: 119.7828E

Elev: 31

StdP: 100.95

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.2	7.1	-1.6	3.3	8.7	0.2	3.8	9.1	9.3	9.5	8.7	9.3	5.6	20	0.409

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.8	32.1	26.1	31.4	26.2	30.8	26.2	27.4	29.8	27.1	29.5	26.9	29.2	3.9	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.7	22.4	28.7	26.5	22.1	28.6	26.2	21.7	28.5	87.4	29.9	86.1	29.6	85.0	29.3	28.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.8	8.0	7.3	5.1	33.5	1.9	0.5	3.8	33.8	2.7	34.1	1.6	34.4	0.3	34.8		
(5)			2.3	27.7	1.8	0.5	1.0	28.0	-0.1	28.3	-1.1	28.6	-2.4	28.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.5	11.7	11.8	14.1	18.4	22.6	26.2	28.6	28.6	26.9	23.3	19.2	14.5		
	DBStd	6.61	2.77	3.14	3.11	3.22	2.36	2.30	1.14	1.14	1.75	2.03	2.46	2.62		
	HDD10.0	33	13	16	3	0	0	0	0	0	0	0	0	1		
	HDD18.3	706	205	185	135	39	1	0	0	0	0	1	18	122		
	CDD10.0	3881	67	64	131	251	390	487	577	577	508	413	276	141		
	CDD18.3	1512	0	1	4	39	133	237	319	318	258	156	44	2		
	CDH23.3	13500	1	1	8	94	548	2145	3790	3767	2525	583	37	1		
	CDH26.7	3994	0	0	0	4	53	529	1382	1363	618	43	1	0		
(14) Wind	WSAvg	3.9	4.3	4.1	3.6	3.4	3.2	3.7	3.9	3.6	3.8	4.6	4.6	4.4		
(15) Precipitation	PrecAvg	1192	45	68	123	134	155	244	91	132	106	32	36	26		
	PrecMax	1863	196	265	319	283	249	710	358	557	339	109	153	83		
	PrecMin	801	0	1	13	31	5	4	0	4	8	0	0	0		
	PrecStd	222	43	59	87	61	59	167	88	133	102	32	38	25		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.7	22.3	24.4	27.4	29.5	32.0	33.1	32.8	32.1	29.4	26.2	22.1		
		MCWB	16.8	18.4	19.9	22.5	25.3	26.2	25.8	26.0	25.7	24.9	22.1	18.4		
	2%	DB	18.3	19.9	22.1	25.8	28.1	31.0	32.1	32.0	31.0	27.8	24.3	20.1		
		MCWB	15.5	17.2	18.9	22.1	24.5	26.2	26.2	26.2	25.7	24.3	21.2	17.6		
	5%	DB	16.8	17.9	20.3	24.3	27.1	30.1	31.4	31.4	30.1	26.8	23.2	18.9		
		MCWB	14.3	15.2	17.8	21.5	23.9	26.1	26.2	26.2	25.6	23.4	20.6	16.9		
	10%	DB	15.5	16.0	18.6	23.0	26.1	29.3	30.8	30.7	29.3	26.0	22.3	17.8		
		MCWB	13.2	13.7	16.1	20.8	23.6	26.0	26.2	26.2	25.4	22.9	19.9	15.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.8	19.6	21.2	23.7	26.3	27.6	27.7	27.9	27.2	26.1	22.9	19.4		
		MCDB	19.6	21.2	22.8	25.6	28.0	29.6	30.2	30.4	29.8	27.9	24.6	20.7		
	2%	WB	16.0	17.8	19.8	22.9	25.5	27.1	27.3	27.5	26.7	25.3	22.0	18.3		
		MCDB	17.9	19.5	21.7	24.5	27.1	29.2	29.7	29.9	29.2	27.1	23.8	19.7		
	5%	WB	14.7	15.6	17.9	22.1	24.9	26.7	27.1	27.1	26.4	24.4	21.2	17.1		
		MCDB	16.6	17.6	19.8	24.0	26.5	28.8	29.5	29.5	28.9	26.2	22.8	18.7		
	10%	WB	13.5	14.0	16.4	21.2	24.1	26.3	26.9	26.9	26.1	23.3	20.4	15.9		
		MCDB	15.2	15.6	18.4	23.0	25.8	28.4	29.3	29.3	28.5	25.5	22.1	17.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	3.1	3.6	4.3	4.4	3.9	3.5	3.8	3.7	3.1	2.5	2.7	2.9		
		MCDBR	5.7	7.1	7.6	6.5	5.2	4.4	4.8	4.6	4.1	3.4	4.1	4.4		
		MCWBR	3.6	4.8	5.2	3.8	2.6	1.4	1.3	1.5	1.4	1.9	2.3	3.1		
	5% WB	MCDBR	5.4	7.0	7.3	5.8	4.6	4.0	3.8	3.9	3.6	3.2	3.9	4.2		
		MCWBR	3.7	5.3	5.6	4.0	2.8	1.6	1.4	1.5	1.5	1.9	2.5	3.3		
(40) Clear-Sky Solar Irradiance	taub		0.583	0.635	0.718	0.717	0.614	0.558	0.533	0.568	0.568	0.572	0.567	0.564		
	taud		1.766	1.690	1.563	1.615	1.872	2.039	2.111	2.000	1.973	1.891	1.870	1.826		
	Ebn at Noon		656	658	633	651	721	757	776	748	736	701	666	650		
	Edh at Noon		199	230	274	265	205	172	160	178	179	185	178	181		
(44) All-Sky Solar Radiation	RadAvg		2.30	2.61	3.42	3.81	4.35	4.80	6.15	5.54	4.66	3.65	2.57	2.29		
	RadStd		0.51	0.53	0.38	0.54	0.71	0.52	0.44	0.48	0.46	0.52	0.37	0.40		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) +0.37	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (15 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+78	(47)

Nomenclature: See separate page