

GUANGNAN, China

WMO: 590070

Lat: 24.0536N

Lon: 105.0517E

Elev: 4104

StdP: 12.64

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	33.9	35.9	26.6	23.9	49.5	29.7	27.7	45.7	16.5	70.0	14.1	68.8	3.0	40	0.292

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.8	88.8	66.3	86.7	67.5	84.8	67.8	72.9	81.6	72.0	80.5	71.5	79.7	8.1	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.6	131.4	76.2	69.9	128.3	75.3	69.2	125.4	74.7	39.7	81.9	38.9	80.9	38.3	79.9	76.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.5	12.0	10.0	30.3	93.4	2.4	2.1	28.5	94.9	27.1	96.1	25.7	97.3	24.0	98.8		
			29.3	75.0	2.4	0.9	27.6	75.7	26.2	76.3	24.9	76.8	23.2	77.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	64.7	49.5	54.1	61.5	68.8	72.3	74.3	74.8	73.8	70.5	65.4	58.9	51.3
	DBStd	10.73	7.79	9.37	7.79	7.05	5.81	3.90	2.66	2.73	4.04	4.96	5.84	6.07
	HDD50	248	110	65	9	0	0	0	0	0	0	6	58	
	HDD65	1692	481	314	159	44	11	1	0	7	57	194	424	
	CDD50	5597	95	180	366	565	690	728	770	737	615	478	273	100
	CDD65	1566	0	10	50	159	236	279	305	272	173	70	12	0
	CDH74	9322	19	163	536	1297	1698	1547	1613	1309	765	279	85	11
	CDH80	2267	0	20	135	422	533	384	352	274	123	19	5	0
Wind	WSAvg	3.7	3.6	4.4	4.8	5.1	4.3	3.5	3.4	3.0	3.0	3.1	3.0	3.2
Precipitation	PrecAvg	40.8	0.6	0.6	1.0	2.6	5.2	6.9	7.1	7.5	4.4	2.7	1.6	0.6
	PrecMax	54.9	1.6	2.2	3.9	7.4	8.6	15.2	13.8	13.0	10.0	7.2	5.2	2.2
	PrecMin	30.4	0.0	0.0	0.1	0.1	1.5	2.0	2.8	1.5	1.2	0.6	0.2	0.0
	PrecStd	5.9	0.4	0.5	0.9	1.7	2.0	2.9	3.1	3.0	1.8	1.6	1.3	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.4	83.0	87.7	91.2	92.3	89.9	88.2	87.9	86.5	82.4	80.1	75.6
		MCWB	53.6	55.6	58.3	61.2	65.4	70.3	71.2	70.8	69.8	67.3	61.8	57.1
	2%	DB	71.9	78.8	83.7	88.2	88.5	86.7	85.8	85.1	83.2	79.5	76.6	70.7
		MCWB	54.8	55.5	57.8	62.0	67.1	70.7	71.0	70.8	69.1	66.1	61.6	56.3
	5%	DB	68.1	75.4	80.1	85.0	85.5	84.3	83.9	83.1	81.0	77.3	73.3	66.3
		MCWB	54.4	56.3	59.0	63.0	67.3	70.7	70.7	70.5	68.6	65.3	60.5	55.0
	10%	DB	63.3	71.0	76.1	81.7	82.7	81.9	81.8	81.0	78.7	74.6	69.7	62.3
		MCWB	53.3	55.9	59.5	63.6	67.3	70.3	70.5	70.3	68.1	64.7	59.5	53.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.4	61.2	64.3	69.2	72.7	73.7	73.9	73.7	72.3	69.3	65.7	59.8
		MCDB	68.3	75.4	76.8	80.8	82.6	82.8	83.1	82.9	80.8	77.2	74.6	70.2
	2%	WB	56.7	59.2	62.7	67.4	70.9	72.6	72.7	72.5	71.0	68.1	63.8	57.3
		MCDB	66.8	72.4	74.8	79.1	80.6	81.5	81.1	81.2	79.3	75.6	71.9	66.9
	5%	WB	55.2	57.7	61.4	66.1	69.9	71.8	71.9	71.7	70.1	66.9	62.3	55.7
		MCDB	65.3	70.0	73.2	77.7	79.8	80.3	80.1	79.9	77.6	74.1	69.9	64.6
	10%	WB	53.4	56.2	60.1	64.9	68.9	71.1	71.2	70.9	69.2	65.8	60.7	54.2
		MCDB	62.5	67.7	71.7	76.0	78.2	78.8	78.8	78.3	76.0	72.5	67.3	61.5
Mean Daily Temperature Range	5% DB	MDBR	15.9	18.0	19.3	18.0	15.5	12.9	12.8	13.4	13.9	13.4	16.3	15.5
		MCDBR	27.9	28.8	28.1	23.6	20.3	17.1	16.9	17.8	18.4	18.9	22.7	25.0
		MCWBR	12.3	10.2	8.4	5.9	5.7	4.9	4.9	5.4	6.0	6.9	8.9	11.5
	5% WB	MCDBR	23.9	24.8	22.9	19.7	16.5	14.2	14.2	15.0	15.1	15.5	18.5	21.4
		MCWBR	11.9	10.6	9.5	6.8	6.0	5.1	4.9	5.2	5.6	6.3	8.1	10.6
Clear-Sky Solar Irradiance	taub	0.464	0.466	0.617	0.581	0.465	0.463	0.443	0.488	0.493	0.533	0.479	0.500	
	taud	1.964	1.998	1.645	1.791	2.185	2.225	2.274	2.125	2.079	1.897	1.966	1.853	
	Ebn at Noon	246	258	225	238	266	264	269	258	254	235	239	227	
	Edh at Noon	52	54	80	71	48	45	43	50	51	59	52	56	
All-Sky Solar Radiation	RadAvg	792	1105	1273	1541	1558	1386	1472	1429	1293	984	1000	764	
	RadStd	151	215	120	146	152	144	92	90	102	111	115	107	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.08	N/A	N/A	+1.39	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	+0.68	N/A	N/A	+1.03	N/A	N/A	N/A	N/A	+223	+155

Nomenclature: See separate page