

GUANGNAN, China

WMO: 590070

Lat: 24.0536N

Lon: 105.0517E

Elev: 1251

StdP: 87.17

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.0	2.2	-3.0	3.4	9.7	-1.3	4.0	7.6	7.4	21.1	6.3	20.4	1.4	40	0.292

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.1	31.6	19.1	30.4	19.7	29.3	19.9	22.7	27.6	22.2	27.0	21.9	26.5	3.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.4	18.8	24.5	21.1	18.3	24.0	20.7	17.9	23.7	74.4	27.7	72.6	27.2	71.1	26.6	24.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.5	5.4	4.5	DB	-1.0	34.1	1.4	1.2	-1.9	34.9	-2.7	35.6	-3.5	36.3	-4.5	37.1	(4)
			WB	-1.5	23.9	1.3	0.5	-2.5	24.3	-3.2	24.6	-4.0	24.9	-4.9	25.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	18.1	9.7	12.3	16.4	20.5	22.4	23.5	23.8	23.2	21.4	18.6	14.9	10.7	(6)
		DBStd	5.96	4.33	5.21	4.33	3.91	3.23	2.17	1.48	1.52	2.24	2.75	3.24	3.37	(7)
		HDD10.0	138	61	36	5	0	0	0	0	0	0	3	32		(8)
		HDD18.3	940	267	174	88	24	6	1	0	4	32	108	236		(9)
		CDD10.0	3109	53	100	203	314	383	404	428	409	342	266	152	56	(10)
		CDD18.3	870	0	6	28	88	131	155	169	151	96	39	7	0	(11)
		CDH23.3	5179	11	91	298	721	943	859	896	727	425	155	47	6	(12)
(13)	Wind	CDH26.7	1259	0	11	75	234	296	213	196	152	68	11	3	0	(13)
		WSAvg	1.7	1.6	2.0	2.1	2.3	1.9	1.6	1.5	1.3	1.3	1.4	1.4	1.4	(14)
		PrecAvg	1037	15	16	26	66	133	175	180	190	111	69	41	15	(15)
		PrecMax	1394	41	56	98	187	218	386	351	331	254	182	133	56	(16)
		PrecMin	773	1	1	2	3	37	52	70	37	30	15	4	0	(17)
		PrecStd	150	10	12	23	43	50	74	78	76	45	40	34	14	(18)
		DB	24.7	28.4	30.9	32.9	33.5	32.2	31.2	31.1	30.3	28.0	26.7	24.2		(19)
(20)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	MCWB	12.0	13.1	14.6	16.2	18.6	21.3	21.8	21.6	21.0	19.6	16.5	13.9		(20)
		DB	22.2	26.0	28.7	31.2	31.4	30.4	29.9	29.5	28.4	26.4	24.8	21.5		(21)
		MCWB	12.7	13.1	14.3	16.7	19.5	21.5	21.7	21.6	20.6	19.0	16.4	13.5		(22)
		DB	20.1	24.1	26.7	29.4	29.7	29.1	28.8	28.4	27.2	25.2	22.9	19.1		(23)
		MCWB	12.4	13.5	15.0	17.2	19.6	21.5	21.5	21.4	20.3	18.5	15.8	12.8		(24)
		DB	17.4	21.7	24.5	27.6	28.2	27.7	27.7	27.2	25.9	23.7	21.0	16.8		(25)
		MCWB	11.8	13.3	15.3	17.6	19.6	21.3	21.4	21.3	20.1	18.2	15.3	12.1		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	14.7	16.2	18.0	20.7	22.6	23.2	23.3	23.2	22.4	20.7	18.7	15.4		(27)
		MCDB	20.2	24.1	24.9	27.1	28.1	28.2	28.4	28.3	27.1	25.1	23.6	21.2		(28)
		WB	13.7	15.1	17.1	19.7	21.6	22.6	22.6	22.5	21.7	20.0	17.7	14.1		(29)
		MCDB	19.4	22.4	23.8	26.2	27.0	27.5	27.3	27.3	26.3	24.2	22.2	19.4		(30)
		WB	12.9	14.3	16.3	19.0	21.0	22.1	22.2	22.0	21.2	19.4	16.8	13.2		(31)
		MCDB	18.5	21.1	22.9	25.4	26.6	26.8	26.7	26.6	25.4	23.4	21.0	18.1		(32)
		WB	11.9	13.4	15.6	18.3	20.5	21.7	21.8	21.6	20.6	18.8	15.9	12.3		(33)
(34)	Mean Daily Temperature Range	MCDB	16.9	19.9	22.0	24.5	25.7	26.0	25.7	25.7	24.4	22.5	19.6	16.4		(34)
		MDBR	8.9	10.0	10.7	10.0	8.6	7.2	7.1	7.4	7.7	7.5	9.0	8.6		(35)
		5% DB	15.5	16.0	15.6	13.1	11.3	9.5	9.4	9.9	10.2	10.5	12.6	13.9		(36)
		MCWBR	6.8	5.7	4.7	3.3	3.2	2.7	2.7	3.0	3.4	3.8	5.0	6.4		(37)
		5% WB	13.3	13.8	12.7	10.9	9.2	7.9	7.9	8.4	8.4	8.6	10.3	11.9		(38)
		MCWBR	6.6	5.9	5.3	3.8	3.4	2.8	2.7	2.9	3.1	3.5	4.5	5.9		(39)
		taub	0.464	0.466	0.617	0.581	0.465	0.463	0.443	0.488	0.493	0.533	0.479	0.500		(40)
(41)	Clear-Sky Solar Irradiance	taud	1.964	1.998	1.645	1.791	2.185	2.225	2.274	2.125	2.079	1.897	1.966	1.853		(41)
		Ebn at Noon	777	813	709	750	837	833	849	814	801	740	755	717		(42)
		Edh at Noon	164	170	253	223	150	143	136	158	162	185	163	178		(43)
(44)	All-Sky Solar Radiation	RadAvg	2.50	3.48	4.01	4.86	4.91	4.37	4.64	4.50	4.08	3.10	3.15	2.41		(44)
		RadStd	0.48	0.68	0.38	0.46	0.48	0.45	0.29	0.28	0.32	0.35	0.36	0.34		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.60	N/A	N/A	+0.77	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	+0.38	N/A	N/A	+0.57	N/A	N/A	N/A	N/A	+124	+86

Nomenclature: See separate page