

HECHI, China

WMO: 590230

Lat: 24.6939N

Lon: 108.0392E

Elev: 261

StdP: 98.23

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.1	5.4	-4.4	2.7	9.4	-2.3	3.2	9.4	5.2	13.2	4.5	12.0	1.8	40	0.298

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.4	35.0	25.6	34.1	25.5	33.2	25.3	27.2	31.7	26.8	31.2	26.5	30.7	2.2	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.2	22.3	28.8	25.7	21.7	28.6	25.4	21.2	28.4	88.2	31.9	86.4	31.4	84.7	30.9	30.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.7	4.1	3.4	DB	2.7	37.1	1.3	0.9	1.7	37.8	1.0	38.3	0.2	38.8	-0.7	39.5	(4)
			WB	1.2	28.0	1.3	0.7	0.2	28.5	-0.5	28.9	-1.3	29.3	-2.2	29.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	21.3	11.3	13.4	16.6	21.8	25.3	27.4	28.7	28.6	26.8	23.1	18.4	13.3	(6)
		DBStd	6.90	3.81	4.61	4.11	3.83	2.65	1.99	1.84	1.85	2.45	2.94	3.32	3.15	(7)
		HDD10.0	52	29	14	2	0	0	0	0	0	0	1	7		(8)
		HDD18.3	669	221	150	84	12	0	0	0	0	3	40	159		(9)
		CDD10.0	4163	68	110	207	354	474	523	578	503	406	251	109		(10)
		CDD18.3	1739	2	12	31	117	216	273	320	319	253	151	41	4	(11)
		CDH23.3	16490	4	59	137	764	1822	2803	3673	3616	2451	968	179	13	(12)
(13)		CDH26.7	6210	0	8	23	204	621	1025	1549	1556	943	258	22	1	(13)
(14)	Wind	WSAvg	1.5	1.4	1.6	1.6	1.6	1.5	1.6	1.5	1.4	1.4	1.3	1.4		(14)
(15)	Precipitation	PrecAvg	1471	31	41	60	126	218	260	233	230	101	82	58	31	(15)
(16)		PrecMax	2057	83	122	186	266	434	512	523	503	269	288	174	118	(16)
(17)		PrecMin	1102	0	5	8	28	45	66	46	52	17	6	0	0	(17)
(18)		PrecStd	235	21	26	38	55	105	103	105	110	62	52	47	29	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	23.4	28.1	29.2	32.7	33.7	34.6	36.4	36.2	35.1	32.5	28.8	25.2		(19)
(20)		0.4% MCWB	17.5	19.6	22.0	24.3	25.5	25.6	26.1	25.6	24.5	22.3	21.7	19.3		(20)
(21)		2% DB	20.8	25.2	26.6	30.7	32.5	33.4	35.0	35.0	33.7	30.7	27.1	22.1		(21)
(22)		2% MCWB	15.7	18.9	20.5	23.4	24.4	25.6	26.1	25.6	24.6	22.2	19.9	16.2		(22)
(23)		5% DB	18.8	22.9	24.6	29.0	31.4	32.4	33.8	34.0	32.7	29.4	25.5	20.1		(23)
(24)		5% MCWB	14.6	18.0	19.6	22.7	24.0	25.5	25.9	25.6	24.4	21.7	19.0	14.5		(24)
(25)		10% DB	16.9	20.5	22.8	27.4	30.1	31.4	32.7	32.9	31.5	28.1	23.8	18.2		(25)
(26)		10% MCWB	13.6	16.7	18.6	22.1	23.8	25.4	25.8	25.6	23.9	21.2	18.4	13.4		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	18.4	20.7	22.6	25.3	27.3	27.7	27.6	27.5	26.6	25.1	23.8	20.4		(27)
(28)		0.4% MCDB	22.0	26.1	27.5	30.2	31.5	31.2	32.6	32.6	31.3	28.9	26.3	23.8		(28)
(29)		2% WB	17.2	19.6	21.6	24.4	26.4	27.1	27.1	27.0	26.1	24.2	22.2	18.0		(29)
(30)		2% MCDB	19.9	24.2	25.6	29.0	30.2	30.7	32.0	32.0	30.7	28.0	25.4	21.4		(30)
(31)		5% WB	15.7	18.4	20.6	23.6	25.6	26.6	26.7	26.6	25.7	23.6	21.0	16.2		(31)
(32)		5% MCDB	18.1	22.2	23.9	27.9	29.3	30.2	31.3	31.4	29.9	27.2	23.8	18.4		(32)
(33)		10% WB	14.2	17.1	19.5	22.9	24.9	26.2	26.4	26.2	25.2	22.8	19.7	14.4		(33)
(34)		10% MCDB	16.2	20.1	22.2	26.7	28.5	29.6	30.7	30.8	29.1	26.2	22.5	17.1		(34)
(35)	Mean Daily Temperature Range	MDBR	5.0	5.4	5.5	6.1	6.5	5.9	6.4	7.1	7.2	6.8	6.8	6.2		(35)
(36)		5% DB MCDBR	9.0	9.6	8.8	8.5	8.9	7.8	8.6	9.3	9.2	9.0	9.8	10.1		(36)
(37)		5% WB MCWBR	4.5	4.2	3.8	3.1	2.7	2.1	1.9	2.2	2.2	2.6	3.6	4.6		(37)
(38)		5% WB MCDBR	6.8	8.8	7.8	7.5	6.9	6.2	6.9	7.9	7.4	6.7	6.8	7.1		(38)
(39)		5% WB MCWBR	4.3	4.5	4.3	3.4	2.8	2.4	2.2	2.4	2.4	2.6	3.6	4.5		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.653	0.668	0.790	0.759	0.612	0.588	0.552	0.614	0.651	0.731	0.634	0.660		(40)
(41)		taud	1.564	1.577	1.405	1.503	1.840	1.917	2.015	1.829	1.719	1.521	1.655	1.573		(41)
(42)		Ebn at Noon	599	635	587	624	722	735	762	715	674	582	611	570		(42)
(43)		Edh at Noon	246	259	322	297	212	195	176	212	232	270	222	236		(43)
(44)	All-Sky Solar Radiation	RadAvg	1.77	2.23	2.61	3.39	3.87	3.78	4.60	4.54	4.11	3.25	2.68	2.13		(44)
(45)		RadStd	0.45	0.50	0.39	0.47	0.48	0.49	0.37	0.31	0.38	0.37	0.49	0.42		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	N/A	+0.38	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page