

FOGANG, China

WMO: 590870

Lat: 23.8814N

Lon: 113.5227E

Elev: 322

StdP: 14.53

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	39.4	41.6	18.5	14.1	49.7	23.6	18.1	51.5	16.4	47.2	14.9	48.0	6.7	90	0.305

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.7	94.6	79.0	93.1	78.6	91.6	78.5	81.8	89.3	81.0	88.2	80.4	87.3	4.9	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.0	157.7	85.0	79.2	153.5	84.4	78.6	150.2	83.9	46.1	89.7	45.2	88.5	44.4	87.4	85.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.5	11.8	10.2	35.8	98.1	2.4	1.6	34.1	99.3	32.7	100.2	31.4	101.1	29.7	102.3		
(5)			31.9	82.7	2.6	1.3	30.0	83.7	28.5	84.4	27.0	85.2	25.1	86.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	71.5	55.0	58.4	63.5	71.7	77.9	81.9	84.2	83.7	80.9	75.3	67.0	58.1
	DBStd	11.67	7.10	8.77	7.36	6.12	4.15	3.35	2.82	2.74	3.68	4.49	6.02	6.05
	HDD50	63	30	22	3	0	0	0	0	0	0	0	1	7
	HDD65	949	319	217	119	18	0	0	0	0	0	1	47	228
	CDD50	7918	184	257	422	651	864	956	1059	1045	927	784	511	258
	CDD65	3329	8	32	73	219	399	506	594	580	477	320	107	14
	CDH74	30749	26	118	271	1215	3208	5180	6830	6455	4634	2227	535	50
	CDH80	11100	0	5	21	224	934	1858	2921	2663	1733	653	87	1
(14) Wind	WSAvg	4.5	5.5	5.1	4.6	4.1	3.8	3.9	3.7	3.7	4.2	4.8	5.2	5.7
(15) Precipitation	PrecAvg	86.5	2.5	3.3	5.9	11.0	18.0	15.4	8.9	9.1	5.8	3.2	1.9	1.4
	PrecMax	138.6	10.9	14.4	20.9	25.7	37.2	40.9	27.6	22.3	16.1	8.3	7.8	5.4
	PrecMin	53.6	0.0	0.1	0.8	2.4	2.9	6.0	2.5	2.3	0.8	0.0	0.0	0.0
	PrecStd	15.6	2.8	3.1	4.1	5.2	8.5	8.0	5.2	4.3	3.2	2.6	2.2	1.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.4	80.5	82.2	87.8	92.1	94.5	97.1	96.6	94.4	91.3	86.3	78.4
		MCWB	64.9	67.4	69.2	74.7	76.8	79.5	79.5	79.2	78.6	75.9	71.1	66.8
	2%	DB	73.6	77.6	79.3	84.9	89.6	92.4	94.8	94.4	92.4	88.1	82.5	75.0
		MCWB	63.1	66.5	68.7	73.6	76.7	78.7	79.2	79.0	77.8	73.4	68.8	64.5
	5%	DB	70.3	74.8	77.1	82.7	87.6	90.5	93.0	92.8	90.7	86.1	80.0	71.8
		MCWB	60.6	65.8	68.1	72.7	75.9	78.8	79.1	78.7	77.2	72.1	67.0	61.8
	10%	DB	66.7	71.8	74.6	80.4	85.3	88.5	91.1	91.0	88.7	84.0	77.0	68.3
		MCWB	59.1	64.5	67.5	72.5	75.8	78.7	79.0	78.9	76.5	70.9	65.8	58.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.7	71.0	73.6	78.1	81.5	82.6	82.7	83.0	81.4	78.7	74.7	71.3
		MCDB	73.3	76.9	78.6	83.2	87.4	89.1	91.1	90.9	89.0	86.9	81.8	75.4
	2%	WB	65.7	69.4	71.9	76.3	79.5	81.3	81.6	81.8	80.2	77.1	72.7	67.8
		MCDB	71.1	74.8	76.5	81.3	84.9	87.9	89.6	89.5	87.6	83.8	78.2	72.3
	5%	WB	63.1	67.4	70.5	75.1	78.4	80.4	80.8	80.8	79.3	75.7	71.0	64.3
		MCDB	68.7	72.6	74.9	79.9	83.9	87.0	88.3	88.1	86.2	81.5	76.5	68.8
	10%	WB	60.1	65.1	68.7	74.0	77.5	79.7	80.1	80.0	78.4	74.5	69.0	60.8
		MCDB	65.5	70.9	73.2	78.6	82.6	85.8	87.2	86.8	84.8	80.1	74.5	66.9
(35) Mean Daily Temperature Range	5% DB	MDBR	13.1	12.3	11.4	10.7	11.4	10.8	12.7	12.9	13.4	14.4	14.9	14.3
		MCDBR	20.4	17.7	16.3	14.8	15.5	14.3	15.9	16.3	16.5	17.4	19.6	20.4
		MCWBR	10.3	7.8	6.9	5.4	5.0	4.0	3.8	4.1	4.5	5.4	7.8	10.0
	5% WB	MCDBR	15.3	13.1	10.9	10.3	11.4	12.0	13.3	13.9	14.0	13.3	14.1	14.5
		MCWBR	8.7	7.3	6.5	5.2	5.0	4.8	4.4	4.7	4.6	5.2	6.8	8.3
(40) Clear-Sky Solar Irradiance	taub		0.610	0.673	0.800	0.785	0.636	0.602	0.582	0.639	0.661	0.677	0.581	0.569
	taud		1.690	1.617	1.430	1.491	1.803	1.890	1.935	1.778	1.715	1.632	1.804	1.794
	Ebn at Noon		204	202	185	193	224	230	234	221	212	198	210	208
	Edh at Noon		69	79	100	95	70	63	61	71	74	77	61	60
(44) All-Sky Solar Radiation	RadAvg		842	837	871	957	1196	1282	1566	1520	1419	1295	1038	940
	RadStd		148	154	135	177	177	176	141	114	99	147	147	164

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	+0.54	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)		N/A	N/A	N/A	+0.50	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page