

FOGANG, China

WMO: 590870

Lat: 23.8814N

Lon: 113.5227E

Elev: 98

StdP: 100.15

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.1	5.3	-7.5	2.0	9.8	-4.6	2.6	10.8	7.3	8.4	6.6	8.9	3.0	90	0.305

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.0	34.8	26.1	34.0	25.9	33.1	25.8	27.7	31.9	27.2	31.2	26.9	30.7	2.2	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.7	22.5	29.4	26.2	21.9	29.1	25.9	21.5	28.8	89.3	32.1	87.2	31.4	85.4	30.8	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.1	5.3	4.6	DB	2.1	36.7	1.3	0.9	1.2	37.4	0.4	37.9	-0.3	38.4	-1.3	39.0	(4)
			WB	0.0	28.2	1.5	0.7	-1.1	28.7	-2.0	29.1	-2.8	29.6	-3.8	30.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	22.0	12.8	14.7	17.5	22.1	25.5	27.7	29.0	28.7	27.2	24.1	19.4	14.5	(6)
		DBStd	6.48	3.94	4.87	4.09	3.40	2.30	1.86	1.57	1.52	2.05	2.49	3.34	3.36	(7)
		HDD10.0	35	17	12	2	0	0	0	0	0	0	1	4		(8)
		HDD18.3	527	177	121	66	10	0	0	0	0	1	26	127		(9)
		CDD10.0	4399	102	143	234	362	480	531	588	581	515	436	284	143	(10)
		CDD18.3	1849	4	18	41	122	222	281	330	322	265	178	59	8	(11)
		CDH23.3	17083	14	66	151	675	1782	2878	3794	3586	2574	1237	297	28	(12)
(13)	Wind	CDH26.7	6167	0	3	12	124	519	1032	1623	1479	963	363	48	1	(13)
		WSAvg	2.0	2.5	2.3	2.1	1.8	1.7	1.7	1.6	1.9	2.2	2.3	2.6		(14)
		PrecAvg	2198	64	85	151	280	458	391	226	230	147	81	48	36	(15)
		PrecMax	3520	276	367	530	653	945	1039	701	567	408	210	198	138	(16)
		PrecMin	1362	1	3	20	62	73	152	63	59	21	0	0	0	(17)
		PrecStd	397	71	78	105	133	215	204	132	108	82	65	56	35	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	25.2	27.0	27.9	31.0	33.4	34.7	36.2	35.9	34.7	32.9	30.2	25.8		(19)
		0.4% MCWB	18.3	19.6	20.7	23.7	24.9	26.4	26.4	26.2	25.9	24.4	21.7	19.3		(20)
		2% DB	23.1	25.3	26.3	29.4	32.0	33.6	34.9	34.7	33.5	31.1	28.1	23.9		(21)
		2% MCWB	17.3	19.2	20.4	23.1	24.8	26.0	26.2	26.1	25.5	23.0	20.4	18.1		(22)
		5% DB	21.3	23.8	25.0	28.2	30.9	32.5	33.9	33.8	32.6	30.1	26.6	22.1		(23)
		5% MCWB	15.9	18.8	20.1	22.6	24.4	26.0	26.2	25.9	25.1	22.3	19.4	16.5		(24)
		10% DB	19.3	22.1	23.7	26.9	29.6	31.4	32.8	32.8	31.5	28.9	25.0	20.2		(25)
		10% MCWB	15.1	18.0	19.7	22.5	24.3	26.0	26.1	26.0	24.7	21.6	18.8	14.8		(26)
		0.4% WB	19.8	21.7	23.1	25.6	27.5	28.1	28.1	28.3	27.5	26.0	23.7	21.8		(27)
		0.4% MCDB	23.0	25.0	25.9	28.5	30.8	31.7	32.8	32.7	31.7	30.5	27.7	24.1		(28)
(29)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	18.7	20.8	22.2	24.6	26.4	27.4	27.6	27.6	26.8	25.0	22.6	19.9		(29)
		2% MCDB	21.7	23.8	24.7	27.4	29.4	31.0	32.0	31.9	30.9	28.8	25.7	22.4		(30)
		5% WB	17.3	19.7	21.4	23.9	25.8	26.9	27.1	27.1	26.3	24.3	21.7	17.9		(31)
		5% MCDB	20.4	22.6	23.8	26.6	28.8	30.6	31.3	31.1	30.1	27.5	24.7	20.5		(32)
		10% WB	15.6	18.4	20.4	23.3	25.3	26.5	26.7	26.7	25.8	23.6	20.5	16.0		(33)
		10% MCDB	18.6	21.6	22.9	25.9	28.1	29.9	30.6	30.4	29.4	26.7	23.6	19.4		(34)
(35)	Mean Daily Temperature Range	MDBR	7.3	6.8	6.3	6.0	6.3	6.0	7.0	7.2	7.5	8.0	8.3	8.0		(35)
		5% DB MCDBR	11.3	9.8	9.1	8.2	8.6	8.0	8.8	9.1	9.2	9.6	10.9	11.4		(36)
		5% DB MCWBR	5.7	4.4	3.8	3.0	2.8	2.2	2.1	2.3	2.5	3.0	4.4	5.5		(37)
		5% WB MCDBR	8.5	7.3	6.0	5.7	6.3	6.6	7.4	7.7	7.8	7.4	7.8	8.1		(38)
		5% WB MCWBR	4.8	4.1	3.6	2.9	2.8	2.6	2.5	2.6	2.6	2.9	3.8	4.6		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.610	0.673	0.800	0.785	0.636	0.602	0.582	0.639	0.661	0.677	0.581	0.569		(40)
		taud	1.690	1.617	1.430	1.491	1.803	1.890	1.935	1.778	1.715	1.632	1.804	1.794		(41)
		Ebn at Noon	642	637	584	609	706	725	739	698	669	624	663	657		(42)
		Edh at Noon	218	250	315	301	220	200	191	223	233	243	193	190		(43)
(44)	All-Sky Solar Radiation	RadAvg	2.65	2.64	2.75	3.02	3.77	4.04	4.94	4.79	4.47	4.08	3.27	2.96		(44)
		RadStd	0.47	0.49	0.43	0.56	0.56	0.56	0.44	0.36	0.31	0.46	0.46	0.52		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+0.30	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (14 neighbors)	N/A	N/A	N/A	+0.28	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page