

LIANPING, China

WMO: 590960

Lat: 24.3886N

Lon: 114.4958E

Elev: 837

StdP: 14.26

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	37.0	39.0	16.9	13.3	49.7	22.5	17.5	49.1	14.3	51.6	11.7	50.9	3.4	20	0.287

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	95.2	77.6	93.6	77.4	92.0	77.0	80.0	89.2	79.3	88.2	78.7	87.3	4.8	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.0	150.0	83.1	77.2	146.2	82.6	76.5	142.8	82.2	44.4	89.7	43.7	88.6	43.0	87.6	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
10.8	8.9	7.5	DB	33.3	98.6	2.1	1.8	31.8	99.9	30.6	100.9	29.5	102.0	28.0	103.3
			WB	29.5	81.0	2.5	1.1	27.8	81.8	26.3	82.5	24.9	83.1	23.1	83.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	70.4	53.3	56.8	62.4	70.6	76.9	81.1	83.7	83.2	80.1	74.1	65.4	56.3	(6)
(7)		DBStd	12.11	7.48	9.11	7.46	6.05	4.29	3.53	2.69	2.79	4.02	4.74	6.42	6.33	(7)
(8)		HDD50	104	49	35	5	0	0	0	0	0	0	0	1	14	(8)
(9)		HDD65	1133	368	252	139	22	0	0	0	0	0	3	71	278	(9)
(10)		CDD50	7545	152	226	390	617	833	933	1043	1029	902	746	463	211	(10)
(11)		CDD65	3097	5	23	58	189	369	483	578	564	452	284	83	9	(11)
(12)		CDH74	27505	14	107	257	973	2718	4625	6375	5935	4122	1916	435	28	(12)
(13)		CDH80	10184	0	9	27	207	831	1662	2750	2459	1587	579	73	0	(13)
(14)	Wind	WSAvg	3.2	3.3	3.2	2.9	2.9	2.9	3.1	3.2	3.1	3.2	3.4	3.5	3.5	(14)
(15)	Precipitation	PrecAvg	70.1	2.2	3.5	6.0	9.0	12.8	11.8	7.1	7.4	4.6	2.3	1.7	1.3	(15)
(16)		PrecMax	107.6	8.8	16.5	17.5	20.7	29.7	32.4	13.7	16.6	11.9	7.4	5.7	6.3	(16)
(17)		PrecMin	39.3	0.0	0.1	0.2	3.0	2.2	3.4	2.4	2.6	0.8	0.0	0.0	0.0	(17)
(18)		PrecStd	13.1	2.2	3.3	3.9	4.6	6.2	6.5	3.1	3.8	2.8	2.1	1.8	1.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.9	81.4	82.8	88.0	92.8	95.2	97.7	97.1	94.8	91.4	85.8	77.4	(19)
(20)		0.4%	MCWB	63.1	66.9	68.8	72.3	75.2	77.7	77.8	77.7	76.9	74.4	69.6	65.9	(20)
(21)		2%	DB	72.4	77.3	79.9	84.9	89.9	92.8	95.4	95.0	92.6	88.0	81.9	73.6	(21)
(22)		2%	MCWB	62.0	64.6	67.1	71.2	73.7	77.1	77.7	77.8	76.5	71.6	67.7	62.8	(22)
(23)		5%	DB	68.9	74.0	76.8	82.3	87.5	90.7	93.6	93.2	90.8	85.8	79.1	70.5	(23)
(24)		5%	MCWB	59.5	63.7	66.1	70.5	74.1	77.1	77.7	77.6	76.0	70.2	65.7	59.8	(24)
(25)		10%	DB	65.3	70.4	73.6	79.6	84.8	88.4	91.6	91.1	88.4	83.4	75.9	66.8	(25)
(26)		10%	MCWB	57.7	62.8	65.5	70.2	73.8	76.9	77.7	77.5	75.4	69.4	64.1	57.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.3	69.3	72.0	76.0	79.3	80.4	80.8	80.9	79.7	76.6	73.4	70.1	(27)
(28)		0.4%	MCDWB	71.8	76.6	79.0	83.1	85.3	88.4	91.2	90.6	89.0	86.0	81.1	73.5	(28)
(29)		2%	WB	64.2	67.5	70.2	74.4	77.8	79.5	79.9	79.9	78.5	75.3	71.3	66.0	(29)
(30)		2%	MCDWB	69.6	73.8	75.8	80.7	84.2	87.4	89.7	89.4	87.6	82.9	78.1	70.9	(30)
(31)		5%	WB	61.6	65.8	68.8	73.1	76.8	78.7	79.2	79.1	77.7	74.0	69.5	62.7	(31)
(32)		5%	MCDWB	67.5	71.7	73.9	78.7	83.3	86.5	88.5	88.3	86.2	81.2	75.7	67.7	(32)
(33)		10%	WB	58.8	63.6	67.1	72.1	75.9	78.0	78.5	78.5	76.9	72.7	67.4	59.4	(33)
(34)		10%	MCDWB	64.4	69.8	72.0	77.2	81.7	85.2	87.3	87.0	84.8	79.5	73.2	65.4	(34)
(35)	Mean Daily Temperature Range		MDBR	14.5	13.5	12.8	12.1	12.4	12.0	14.3	14.2	14.6	16.1	16.6	16.2	(35)
(36)		5% DB	MCDBR	21.7	19.7	19.3	17.5	18.0	16.6	18.3	18.6	18.3	20.4	22.1	22.8	(36)
(37)		5% DB	MCWBR	10.9	8.9	7.9	6.3	5.6	4.3	4.3	4.5	5.0	6.3	8.7	10.9	(37)
(38)		5% WB	MCDBR	16.1	15.0	13.2	12.1	12.2	13.0	15.2	15.3	15.6	14.8	16.1	15.6	(38)
(39)			MCWBR	9.1	7.9	7.4	5.7	4.9	4.3	4.6	4.7	4.9	5.5	7.5	9.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.608	0.667	0.792	0.778	0.635	0.601	0.574	0.632	0.655	0.671	0.582	0.565	(40)	
(41)		taud	1.675	1.606	1.426	1.490	1.789	1.876	1.944	1.783	1.717	1.629	1.783	1.782	(41)	
(42)		Ebn at Noon	203	202	186	194	224	230	236	223	213	199	209	208	(42)	
(43)		Edh at Noon	70	80	100	95	71	64	60	70	74	77	62	61	(43)	
(44)	All-Sky Solar Radiation	RadAvg	828	843	890	969	1176	1269	1593	1504	1352	1233	993	908	(44)	
(45)		RadStd	149	157	136	181	188	180	151	129	110	176	148	164	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	+0.61	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	N/A	N/A	N/A	+0.63	N/A	N/A	N/A	N/A	N/A	+103

Nomenclature: See separate page