

LIANPING, China

WMO: 590960

Lat: 24.3886N

Lon: 114.4958E

Elev: 255

StdP: 98.30

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.8	3.9	-8.4	1.9	9.8	-5.3	2.5	9.5	6.4	10.9	5.2	10.5	1.5	20	0.287

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.0	35.1	25.3	34.2	25.2	33.3	25.0	26.7	31.8	26.3	31.2	26.0	30.7	2.1	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.5	21.4	28.4	25.1	20.9	28.1	24.7	20.4	27.9	85.4	32.0	83.8	31.5	82.2	30.9	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.8	4.0	3.4	DB	0.7	37.0	1.1	1.0	-0.1	37.7	-0.8	38.3	-1.4	38.9	-2.2	39.6	(4)
			WB	-1.4	27.2	1.4	0.6	-2.4	27.7	-3.2	28.0	-3.9	28.4	-4.9	28.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	21.3	11.8	13.8	16.9	21.4	24.9	27.3	28.7	28.4	26.7	23.4	18.5	13.5	(6)
		DBStd	6.73	4.16	5.06	4.15	3.36	2.39	1.96	1.49	1.55	2.23	2.63	3.57	3.52	(7)
		HDD10.0	58	27	19	3	0	0	0	0	0	0	1	8		(8)
		HDD18.3	629	204	140	77	12	0	0	0	0	2	39	154		(9)
		CDD10.0	4192	84	126	217	343	463	518	579	572	501	414	257	117	(10)
		CDD18.3	1721	3	13	32	105	205	268	321	313	251	158	46	5	(11)
		CDH23.3	15281	8	59	143	541	1510	2569	3542	3297	2290	1064	242	16	(12)
(13)		CDH26.7	5658	0	5	15	115	462	923	1528	1366	882	322	41	0	(13)
(14)	Wind	WSAvg	1.4	1.5	1.4	1.3	1.3	1.3	1.4	1.4	1.4	1.4	1.5	1.6	1.6	(14)
(15)	Precipitation	PrecAvg	1781	56	90	152	228	324	300	181	189	118	58	44	34	(15)
(16)		PrecMax	2732	224	418	445	526	755	824	349	421	303	187	144	160	(16)
(17)		PrecMin	998	0	2	6	75	56	86	60	66	21	0	1	0	(17)
(18)		PrecStd	332	57	85	98	116	158	164	79	96	71	54	45	37	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	24.4	27.4	28.2	31.1	33.8	35.1	36.5	36.1	34.9	33.0	29.9	25.2		(19)
(20)		0.4% MCWB	17.3	19.4	20.4	22.4	24.0	25.4	25.4	25.4	24.9	23.5	20.9	18.8		(20)
(21)		2% DB	22.4	25.2	26.6	29.4	32.2	33.8	35.2	35.0	33.7	31.1	27.7	23.1		(21)
(22)		2% MCWB	16.6	18.1	19.5	21.8	23.2	25.1	25.4	25.4	24.7	22.0	19.8	17.1		(22)
(23)		5% DB	20.5	23.3	24.9	28.0	30.8	32.6	34.2	34.0	32.6	29.9	26.2	21.4		(23)
(24)		5% MCWB	15.3	17.6	19.0	21.4	23.4	25.0	25.4	25.3	24.4	21.2	18.7	15.5		(24)
(25)		10% DB	18.5	21.3	23.1	26.5	29.4	31.3	33.1	32.8	31.3	28.6	24.4	19.3		(25)
(26)		10% MCWB	14.3	17.1	18.6	21.2	23.2	25.0	25.4	25.3	24.1	20.8	17.8	14.1		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	19.1	20.7	22.2	24.4	26.3	26.9	27.1	27.2	26.5	24.8	23.0	21.1		(27)
(28)		0.4% MCDB	22.1	24.8	26.1	28.4	29.6	31.4	32.9	32.5	31.7	30.0	27.3	23.1		(28)
(29)		2% WB	17.9	19.7	21.2	23.6	25.4	26.4	26.6	26.6	25.8	24.1	21.8	18.9		(29)
(30)		2% MCDB	20.9	23.2	24.3	27.0	29.0	30.8	32.1	31.9	30.9	28.3	25.6	21.6		(30)
(31)		5% WB	16.5	18.8	20.5	22.9	24.9	26.0	26.2	26.2	25.4	23.3	20.8	17.1		(31)
(32)		5% MCDB	19.7	22.1	23.3	26.0	28.5	30.3	31.4	31.3	30.1	27.4	24.3	19.8		(32)
(33)		10% WB	14.9	17.6	19.5	22.3	24.4	25.6	25.8	25.8	24.9	22.6	19.7	15.2		(33)
(34)		10% MCDB	18.0	21.0	22.2	25.1	27.6	29.6	30.7	30.6	29.3	26.4	22.9	18.5		(34)
(35)	Mean Daily Temperature Range	MDBR	8.1	7.5	7.1	6.7	6.9	6.7	8.0	7.9	8.1	8.9	9.2	9.0		(35)
(36)		5% DB MCDBR	12.1	11.0	10.7	9.7	10.0	9.2	10.2	10.3	10.2	11.3	12.3	12.7		(36)
(37)		5% WB MCWBR	6.1	4.9	4.4	3.5	3.1	2.4	2.4	2.5	2.8	3.5	4.8	6.1		(37)
(38)		5% WB MCDBR	9.0	8.3	7.3	6.7	6.8	7.2	8.4	8.5	8.6	8.2	8.9	8.7		(38)
(39)		5% WB MCWBR	5.1	4.4	4.1	3.2	2.7	2.4	2.5	2.6	2.7	3.0	4.1	5.1		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.608	0.667	0.792	0.778	0.635	0.601	0.574	0.632	0.655	0.671	0.582	0.565		(40)
(41)		taud	1.675	1.606	1.426	1.490	1.789	1.876	1.944	1.783	1.717	1.629	1.783	1.782		(41)
(42)		Ebn at Noon	640	638	587	613	706	725	745	702	672	626	658	656		(42)
(43)		Edh at Noon	220	252	316	301	223	203	189	222	232	243	196	191		(43)
(44)	All-Sky Solar Radiation	RadAvg	2.61	2.66	2.81	3.05	3.71	4.00	5.02	4.74	4.26	3.89	3.13	2.86		(44)
(45)		RadStd	0.47	0.49	0.43	0.57	0.59	0.57	0.48	0.41	0.35	0.55	0.47	0.52		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+0.34	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	N/A	N/A	N/A	+0.35	N/A	N/A	N/A	N/A	N/A	+57

Nomenclature: See separate page