

XUNWU, China

WMO: 591020

Lat: 24.9501N

Lon: 115.6422E

Elev: 981

StdP: 14.18

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	33.6	35.9	18.1	14.2	45.9	23.0	18.0	45.5	13.1	46.9	11.9	46.2	2.7	20	0.289

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.3	93.8	77.9	92.2	77.6	90.6	77.1	79.9	88.6	79.2	87.7	78.6	86.8	4.2	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.0	150.7	82.9	77.2	146.9	82.3	76.5	143.4	81.8	44.5	88.9	43.7	88.2	43.0	87.0	87.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.4	9.7	8.5	29.2	97.0	2.6	1.4	27.3	98.0	25.8	98.8	24.4	99.6	22.5	100.5		
(5)			26.9	81.7	2.9	1.8	24.9	83.0	23.2	84.1	21.6	85.1	19.5	86.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	68.1	50.0	54.5	60.1	68.6	74.9	79.6	82.1	81.6	78.3	71.4	62.5	53.1	(6)
(7)		DBStd	12.64	7.72	9.14	7.78	6.24	4.49	3.42	2.48	2.62	4.09	4.92	6.57	6.65	(7)
(8)		HDD50	207	96	55	11	1	0	0	0	0	0	0	4	40	(8)
(9)		HDD65	1504	465	308	191	37	1	0	0	0	0	9	120	373	(9)
(10)		CDD50	6825	98	180	324	560	772	888	996	979	848	664	379	137	(10)
(11)		CDD65	2646	2	13	38	146	308	438	531	514	398	207	46	5	(11)
(12)		CDH74	22077	8	81	197	758	2052	3713	5425	4937	3278	1331	280	17	(12)
(13)		CDH80	7911	0	5	18	151	596	1264	2278	1992	1216	350	41	0	(13)
(14)	Wind	WSAvg	2.9	3.4	3.1	2.8	2.7	2.4	2.5	2.7	2.6	2.9	3.3	3.3	3.5	(14)
(15)	Precipitation	PrecAvg	65.0	2.2	3.6	6.8	7.9	10.7	10.9	5.7	6.6	5.0	2.3	2.0	1.5	(15)
(16)		PrecMax	98.0	8.3	11.5	18.2	17.1	21.4	23.0	15.4	21.4	14.5	9.7	7.0	6.6	(16)
(17)		PrecMin	40.5	0.0	0.0	0.8	1.9	1.6	2.9	1.3	1.7	0.6	0.0	0.0	0.0	(17)
(18)		PrecStd	12.4	2.4	2.8	4.3	3.5	4.1	5.3	3.0	3.5	3.0	2.3	1.7	1.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.2	80.3	82.2	87.1	91.4	93.5	96.2	93.8	90.1	84.1	76.3	(19)	
MCWB			62.7	66.6	68.6	72.3	74.5	78.1	78.0	78.0	77.5	74.1	69.1	65.2	(20)	
2%		DB	71.6	76.6	79.0	84.0	88.5	91.3	94.0	93.6	91.3	86.4	80.6	72.0	(21)	
		MCWB	60.7	64.2	66.7	70.8	74.3	77.5	78.1	78.0	76.8	71.7	67.2	61.5	(22)	
5%		DB	67.6	72.8	75.9	81.4	86.2	89.2	92.2	91.8	89.4	83.9	77.4	68.4	(23)	
		MCWB	58.3	63.0	65.3	70.3	73.5	77.1	77.9	77.8	76.1	70.1	65.3	58.8	(24)	
10%		DB	63.5	68.7	72.3	78.6	83.5	87.1	90.3	89.6	87.2	81.5	73.9	64.6	(25)	
		MCWB	56.2	61.0	64.3	69.6	73.4	76.8	77.6	77.6	75.2	69.0	63.2	56.6	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	65.3	69.0	71.1	75.2	79.3	80.4	80.8	80.9	79.6	76.5	72.8	69.0	(27)
MCD B			71.8	77.6	79.2	82.5	86.5	88.4	90.1	89.1	88.9	84.2	80.4	73.4	(28)	
2%		WB	63.0	66.4	69.2	73.6	77.7	79.2	79.8	79.9	78.4	74.8	70.4	64.7	(29)	
		MCD B	68.6	72.5	75.6	80.0	84.3	86.6	89.1	88.4	87.4	82.0	76.5	69.3	(30)	
5%		WB	60.1	64.3	67.7	72.4	76.4	78.5	79.0	79.0	77.6	73.5	68.6	61.2	(31)	
		MCD B	66.5	70.3	73.0	78.3	82.3	85.4	88.1	87.8	85.7	79.7	73.9	65.9	(32)	
10%		WB	57.1	62.2	65.8	71.1	75.3	77.8	78.3	78.3	76.7	72.0	66.3	58.1	(33)	
		MCD B	62.3	68.2	70.5	76.4	80.5	84.2	86.8	86.5	83.9	78.2	71.5	63.1	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	14.8	14.5	14.0	13.6	13.3	12.6	15.3	14.8	15.2	16.8	17.1	16.5	(35)
MCDBR			23.6	22.2	21.1	18.6	18.9	16.8	19.1	19.2	19.0	21.8	23.5	24.1	(36)	
MCWBR			12.8	10.7	9.5	7.2	6.5	4.9	5.3	5.5	5.8	7.6	10.1	12.4	(37)	
5% WB		MCDBR	19.1	18.2	15.7	13.9	13.4	13.7	16.3	16.4	16.3	15.6	16.8	17.1	(38)	
		MCWBR	11.2	10.2	8.5	6.6	5.8	4.9	5.4	5.6	5.7	6.0	8.3	10.2	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.594	0.654	0.769	0.753	0.623	0.585	0.558	0.618	0.633	0.651	0.571	0.553	(40)	
taud		1.696	1.624	1.457	1.528	1.815	1.917	1.987	1.814	1.759	1.668	1.803	1.802	(41)		
Ebn at Noon		205	205	190	199	227	234	240	226	218	203	211	210	(42)		
Edh at Noon		68	78	97	92	69	62	57	68	70	74	61	59	(43)		
(44)	All-Sky Solar Radiation	RadAvg	821	875	938	1064	1224	1323	1675	1548	1387	1243	985	898	(44)	
(45)		RadStd	152	166	148	179	186	163	150	138	115	193	142	168	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (7 neighbors)		N/A	N/A	N/A	+0.70	N/A	N/A	N/A	N/A	N/A
		+0.50	N/A	N/A	+0.74	N/A	N/A	N/A	+148	+124

Nomenclature: See separate page