

XUNWU, China

WMO: 591020

Lat: 24.9501N

Lon: 115.6422E

Elev: 299

StdP: 97.78

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.9	2.2	-7.7	2.0	7.7	-5.0	2.6	7.5	5.8	8.3	5.3	7.9	1.2	20	0.289

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.5	34.3	25.5	33.5	25.3	32.5	25.1	26.6	31.4	26.2	30.9	25.9	30.5	1.9	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.5	21.5	28.3	25.1	21.0	28.0	24.7	20.5	27.7	85.5	31.6	83.7	31.2	82.2	30.6	30.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.1	4.4	3.8	DB	-1.6	36.1	1.4	0.8	-2.6	36.7	-3.4	37.1	-4.2	37.5	-5.3	38.1	(4)
			WB	-2.8	27.6	1.6	1.0	-4.0	28.3	-4.9	28.9	-5.8	29.5	-7.0	30.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	20.1	10.0	12.5	15.6	20.4	23.8	26.4	27.9	27.5	25.7	21.9	17.0	11.7	(6)
		DBStd	7.02	4.29	5.08	4.32	3.47	2.50	1.90	1.38	1.46	2.27	2.74	3.65	3.70	(7)
		HDD10.0	115	53	31	6	1	0	0	0	0	0	2	22		(8)
		HDD18.3	836	258	171	106	21	1	0	0	0	5	67	207		(9)
		CDD10.0	3792	54	100	180	311	429	493	553	544	471	369	211	76	(10)
		CDD18.3	1470	1	7	21	81	171	243	295	286	221	115	26	3	(11)
		CDH23.3	12265	4	45	109	421	1140	2063	3014	2743	1821	739	156	9	(12)
		CDH26.7	4395	0	3	10	84	331	702	1266	1107	676	194	23	0	(13)
(14)	Wind	WSAvg	1.3	1.5	1.4	1.3	1.2	1.1	1.1	1.2	1.1	1.3	1.5	1.5	1.6	(14)
(15)	Precipitation	PrecAvg	1651	57	91	172	200	271	276	146	168	126	59	50	38	(15)
(16)		PrecMax	2489	211	293	463	434	544	585	392	543	368	247	177	168	(16)
(17)		PrecMin	1028	0	0	20	47	40	74	33	44	14	0	0	0	(17)
(18)		PrecStd	314	60	71	108	88	104	134	76	89	76	59	42	41	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	24.0	26.8	27.9	30.6	33.0	34.2	35.7	35.5	34.3	32.3	29.0	24.6		(19)
(20)		MCWB	17.0	19.2	20.3	22.4	23.6	25.6	25.5	25.6	25.3	23.4	20.6	18.5		(20)
(21)		DB	22.0	24.8	26.1	28.9	31.4	32.9	34.5	34.2	33.0	30.2	27.0	22.2		(21)
(22)		MCWB	16.0	17.9	19.3	21.5	23.5	25.3	25.6	25.5	24.9	22.1	19.6	16.4		(22)
(23)		DB	19.8	22.7	24.4	27.4	30.1	31.8	33.5	33.2	31.9	28.9	25.2	20.2		(23)
(24)		MCWB	14.6	17.2	18.5	21.3	23.1	25.0	25.5	25.4	24.5	21.2	18.5	14.9		(24)
(25)		DB	17.5	20.4	22.4	25.9	28.6	30.6	32.4	32.0	30.6	27.5	23.3	18.1		(25)
(26)		MCWB	13.5	16.1	17.9	20.9	23.0	24.9	25.4	25.3	24.0	20.5	17.3	13.7		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	18.5	20.5	21.7	24.0	26.3	26.9	27.1	27.2	26.4	24.7	22.6	20.5		(27)
(28)		MCDB	22.1	25.3	26.2	28.0	30.3	31.3	32.3	31.7	31.6	29.0	26.9	23.0		(28)
(29)		WB	17.2	19.1	20.7	23.1	25.4	26.2	26.6	26.6	25.8	23.8	21.3	18.2		(29)
(30)		MCDB	20.4	22.5	24.2	26.6	29.0	30.3	31.7	31.3	30.8	27.8	24.7	20.7		(30)
(31)		WB	15.6	18.0	19.8	22.5	24.7	25.9	26.1	26.1	25.3	23.1	20.3	16.2		(31)
(32)		MCDB	19.2	21.3	22.8	25.7	27.9	29.7	31.2	31.0	29.8	26.5	23.3	18.8		(32)
(33)		WB	13.9	16.8	18.8	21.7	24.1	25.5	25.7	25.7	24.8	22.2	19.1	14.5		(33)
(34)		MCDB	16.8	20.1	21.4	24.7	26.9	29.0	30.4	30.3	28.9	25.7	21.9	17.3		(34)
(35)	Mean Daily Temperature Range	MDBR	8.2	8.0	7.8	7.5	7.4	7.0	8.5	8.2	8.5	9.3	9.5	9.2		(35)
(36)		5% DB	13.1	12.3	11.7	10.4	10.5	9.3	10.6	10.7	10.6	12.1	13.0	13.4		(36)
(37)		MCWBR	7.1	6.0	5.3	4.0	3.6	2.7	2.9	3.1	3.2	4.2	5.6	6.9		(37)
(38)		5% WB	10.6	10.1	8.7	7.7	7.5	7.6	9.0	9.1	9.1	8.7	9.3	9.5		(38)
(39)	Clear-Sky Solar Irradiance	taub	0.594	0.654	0.769	0.753	0.623	0.585	0.558	0.618	0.633	0.651	0.571	0.553		(40)
(41)		taud	1.696	1.624	1.457	1.528	1.815	1.917	1.987	1.814	1.759	1.668	1.803	1.802		(41)
(42)		Ebn at Noon	647	646	600	628	715	737	757	711	686	639	664	662		(42)
(43)		Edh at Noon	214	246	305	290	217	195	181	215	222	232	191	186		(43)
(44)	All-Sky Solar Radiation	RadAvg	2.59	2.76	2.96	3.35	3.86	4.17	5.28	4.88	4.37	3.92	3.10	2.83		(44)
(45)		RadStd	0.48	0.52	0.47	0.56	0.59	0.51	0.47	0.43	0.36	0.61	0.45	0.53		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+0.39	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	+0.28	N/A	N/A	+0.41	N/A	N/A	N/A	N/A	+82	+69

Nomenclature: See separate page