

MEI XIAN, China

WMO: 591170

Lat: 24.2811N

Lon: 116.0703E

Elev: 384

StdP: 14.49

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	39.1	41.6	22.7	17.3	51.0	28.7	22.9	51.9	11.7	53.8	10.3	53.1	3.2	290	0.294

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	96.1	78.2	94.7	78.0	93.2	77.8	80.8	90.6	80.1	89.3	79.5	88.3	4.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.3	149.3	84.1	77.9	147.0	83.7	77.3	144.1	83.2	44.8	90.8	44.1	89.9	43.5	88.6	83.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.4	8.9	7.5	34.8	99.2	2.8	1.2	32.8	100.1	31.2	100.8	29.7	101.5	27.7	102.4
			32.0	81.9	3.4	1.1	29.6	82.7	27.6	83.4	25.7	84.0	23.3	84.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	72.4	56.1	59.7	65.0	72.6	78.5	82.5	85.0	84.3	81.8	76.0	67.7	58.5
	DBStd	11.58	7.03	8.65	7.21	6.02	4.53	3.52	2.90	3.02	3.74	4.70	6.14	6.33
	HDD50	47	22	16	2	0	0	0	0	0	0	0	0	7
	HDD65	842	286	189	93	14	0	0	0	0	1	41	218	
	CDD50	8212	212	288	466	679	882	974	1084	1063	953	806	533	272
	CDD65	3531	10	40	93	243	417	524	619	598	503	343	124	17
	CDH74	34355	44	212	504	1577	3567	5557	7463	6812	5229	2653	677	60
	CDH80	13656	2	30	98	458	1272	2208	3484	2986	2133	849	132	4
Wind	WSAvg	3.2	3.1	3.2	3.2	3.1	3.2	3.3	3.6	3.4	3.3	3.2	3.1	3.2
Precipitation	PrecAvg	59.4	1.9	3.3	5.5	7.1	9.0	8.8	5.1	7.6	5.6	2.5	1.8	1.1
	PrecMax	94.8	7.4	17.0	19.9	16.9	18.8	20.3	10.7	20.5	17.7	10.4	6.3	5.2
	PrecMin	43.3	0.0	0.0	0.1	0.6	1.9	2.3	1.2	1.7	0.3	0.0	0.0	0.0
	PrecStd	11.0	2.2	3.4	4.0	3.8	3.5	3.8	2.5	4.0	4.2	2.4	1.9	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.6	83.9	86.3	90.6	94.4	96.1	98.4	97.8	95.5	92.5	86.7	79.5
		MCWB	65.3	68.2	70.6	73.4	76.7	78.5	78.2	78.2	77.1	74.9	71.4	67.9
	2%	DB	74.3	79.7	82.7	87.7	91.6	94.1	96.4	95.8	93.7	89.2	83.9	75.2
		MCWB	63.2	66.0	68.9	72.6	75.6	78.0	78.1	78.5	76.9	73.3	69.9	64.4
	5%	DB	70.9	76.3	79.7	85.2	89.5	92.3	94.8	94.1	91.9	87.2	80.8	71.9
		MCWB	61.0	64.9	67.3	72.0	74.9	77.8	78.2	78.4	76.7	72.0	67.8	62.3
	10%	DB	67.4	72.6	76.3	82.4	87.0	90.0	92.8	92.1	89.9	85.0	77.9	68.9
		MCWB	59.3	63.3	66.4	71.1	74.6	77.6	78.3	78.4	76.2	70.9	66.2	60.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.2	70.2	72.8	76.5	80.0	81.3	81.7	81.7	80.5	77.7	73.7	70.9
		MCDB	75.3	80.9	81.8	84.9	88.6	90.5	92.5	92.0	91.1	86.6	82.3	76.4
	2%	WB	65.1	68.3	71.1	75.0	78.5	80.2	80.7	80.7	79.4	76.4	72.1	67.3
		MCDB	71.6	76.5	79.2	83.0	86.8	88.9	90.5	90.8	88.8	84.4	79.7	72.7
	5%	WB	62.9	66.5	69.7	73.9	77.5	79.5	80.0	79.9	78.6	75.3	70.7	64.7
		MCDB	69.2	73.3	76.8	81.4	85.0	87.6	89.2	89.3	87.1	82.4	77.6	70.0
	10%	WB	60.6	64.5	68.0	72.9	76.6	78.8	79.3	79.2	77.8	74.1	69.1	62.0
		MCDB	66.0	71.6	74.4	79.9	83.4	86.4	88.1	87.7	85.5	81.2	75.5	67.0
Mean Daily Temperature Range	5% DB	MDBR	15.3	14.4	14.0	13.5	13.2	12.6	14.3	13.9	14.3	15.3	16.1	15.9
		MCDBR	20.1	20.5	19.8	18.1	18.1	16.6	17.6	17.5	17.1	17.5	19.3	19.5
		MCWBR	9.8	8.6	7.6	5.7	5.2	3.9	3.7	4.1	4.1	4.7	7.0	9.4
	5% WB	MCDBR	16.8	17.0	15.9	14.9	14.0	13.4	15.1	15.2	14.8	14.0	15.1	15.5
		MCWBR	8.9	8.3	7.4	5.8	5.1	4.4	4.4	4.6	4.4	4.7	6.5	8.5
Clear-Sky Solar Irradiance	taub	0.582	0.653	0.779	0.767	0.627	0.584	0.560	0.626	0.650	0.660	0.565	0.548	
	taud	1.743	1.647	1.459	1.521	1.822	1.931	1.992	1.806	1.735	1.667	1.843	1.842	
	Ebn at Noon	210	206	189	197	226	234	239	224	214	201	214	214	
	Edh at Noon	65	77	97	93	69	61	57	69	72	74	59	57	
All-Sky Solar Radiation	RadAvg	926	949	1012	1099	1256	1340	1659	1551	1447	1303	1056	971	
	RadStd	140	167	148	190	199	178	149	145	114	170	130	152	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	+0.47	N/A	N/A	+0.74	N/A	N/A	N/A	N/A	N/A	+99

Nomenclature: See separate page