

MEI XIAN, China

WMO: 591170

Lat: 24.2811N

Lon: 116.0703E

Elev: 117

StdP: 99.93

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.9	5.3	-5.2	2.5	10.5	-1.9	3.3	11.1	5.2	12.1	4.6	11.7	1.4	290	0.294

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.0	35.6	25.7	34.8	25.6	34.0	25.4	27.1	32.6	26.7	31.9	26.4	31.3	2.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.7	21.3	29.0	25.5	21.0	28.7	25.2	20.6	28.4	86.4	32.6	84.8	32.2	83.2	31.5	28.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.6	4.0	3.4	1.6	37.4	1.5	0.7	0.5	37.8	-0.4	38.2	-1.3	38.6	-2.4	39.1		
			0.0	27.7	1.9	0.6	-1.3	28.2	-2.4	28.6	-3.5	28.9	-4.9	29.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.4	13.4	15.4	18.3	22.6	25.8	28.0	29.4	29.1	27.7	24.5	19.9	14.7
	DBStd	6.43	3.90	4.81	4.01	3.35	2.52	1.96	1.61	1.68	2.08	2.61	3.41	3.52
	HDD10.0	26	12	9	1	0	0	0	0	0	0	0	0	4
	HDD18.3	468	159	105	52	8	0	0	0	0	0	1	23	121
	CDD10.0	4562	118	160	259	377	490	541	602	591	529	448	296	151
	CDD18.3	1962	6	22	52	135	232	291	344	332	279	191	69	9
	CDH23.3	19086	24	118	280	876	1982	3087	4146	3784	2905	1474	376	33
CDH26.7	7587	1	17	54	254	707	1227	1936	1659	1185	472	73	2	
Wind	WSAvg	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.6	1.5	1.5	1.4	1.4	1.4
Precipitation	PrecAvg	1509	47	83	139	181	229	223	130	194	141	64	45	28
	PrecMax	2407	188	432	506	429	478	515	271	520	450	265	159	131
	PrecMin	1100	0	1	2	16	47	59	31	42	8	0	0	0
	PrecStd	279	55	87	101	97	89	96	63	102	107	60	47	33
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.9	28.8	30.1	32.5	34.6	35.6	36.9	36.6	35.3	33.6	30.4	26.4
		MCWB	18.5	20.1	21.4	23.0	24.8	25.8	25.7	25.7	25.1	23.9	21.9	20.0
	2%	DB	23.5	26.5	28.2	30.9	33.1	34.5	35.8	35.5	34.3	31.8	28.8	24.0
		MCWB	17.3	18.9	20.5	22.5	24.2	25.6	25.6	25.9	25.0	22.9	21.1	18.0
	5%	DB	21.6	24.6	26.5	29.6	31.9	33.5	34.9	34.5	33.3	30.6	27.1	22.2
		MCWB	16.1	18.3	19.6	22.2	23.9	25.4	25.7	25.8	24.8	22.2	19.9	16.9
	10%	DB	19.7	22.6	24.6	28.0	30.6	32.2	33.8	33.4	32.2	29.4	25.5	20.5
		MCWB	15.2	17.4	19.1	21.7	23.7	25.4	25.7	25.8	24.5	21.6	19.0	15.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.6	21.2	22.7	24.7	26.7	27.4	27.6	27.6	27.0	25.4	23.2	21.6
		MCDB	24.1	27.1	27.7	29.4	31.4	32.5	33.6	33.3	32.8	30.3	28.0	24.7
	2%	WB	18.4	20.2	21.7	23.9	25.8	26.8	27.1	27.1	26.4	24.7	22.3	19.6
		MCDB	22.0	24.7	26.2	28.3	30.5	31.6	32.5	32.7	31.6	29.1	26.5	22.6
	5%	WB	17.1	19.2	20.9	23.3	25.3	26.4	26.6	26.6	25.9	24.1	21.5	18.2
		MCDB	20.7	22.9	24.9	27.5	29.4	30.9	31.8	31.8	30.6	28.0	25.3	21.1
	10%	WB	15.9	18.0	20.0	22.7	24.8	26.0	26.3	26.2	25.4	23.4	20.6	16.7
		MCDB	18.9	22.0	23.6	26.6	28.6	30.2	31.1	31.0	29.7	27.3	24.1	19.4
Mean Daily Temperature Range		MDBR	8.5	8.0	7.8	7.5	7.4	7.0	8.0	7.7	7.9	8.5	8.9	8.8
	5% DB	MCDBR	11.1	11.4	11.0	10.0	10.0	9.2	9.8	9.7	9.5	9.7	10.7	10.8
		MCWBR	5.4	4.8	4.2	3.2	2.9	2.2	2.1	2.3	2.3	2.6	3.9	5.2
	5% WB	MCDBR	9.3	9.5	8.8	8.3	7.8	7.5	8.4	8.5	8.2	7.8	8.4	8.6
		MCWBR	4.9	4.6	4.1	3.2	2.8	2.4	2.5	2.6	2.5	2.6	3.6	4.7
Clear-Sky Solar Irradiance	taub	0.582	0.653	0.779	0.767	0.627	0.584	0.560	0.626	0.650	0.660	0.565	0.548	
	taud	1.743	1.647	1.459	1.521	1.822	1.931	1.992	1.806	1.735	1.667	1.843	1.842	
	Ebn at Noon	663	650	596	620	712	738	755	707	676	635	674	674	
	Edh at Noon	206	242	306	292	216	192	180	217	228	234	185	180	
All-Sky Solar Radiation	RadAvg	2.92	2.99	3.19	3.46	3.96	4.22	5.23	4.89	4.56	4.11	3.33	3.06	
	RadStd	0.44	0.53	0.47	0.60	0.63	0.56	0.47	0.46	0.36	0.54	0.41	0.48	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	+0.26	N/A	N/A	+0.41	N/A	N/A	N/A	N/A	N/A	+55

Nomenclature: See separate page