

GUIPING, China

WMO: 592540

Lat: 23.3956N

Lon: 110.0841E

Elev: 144

StdP: 14.62

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	42.1	44.3	29.2	23.3	53.6	33.3	28.0	52.0	12.0	59.5	9.3	59.3	3.0	40	0.283

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.9	95.3	80.0	93.9	79.8	92.4	79.5	82.1	90.2	81.5	89.4	80.9	88.6	4.5	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.1	157.3	85.3	79.5	153.8	84.9	78.9	150.9	84.5	46.2	90.7	45.5	89.7	44.8	88.9	86.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.0	8.6	7.2	39.3	98.8	2.3	1.9	37.7	100.2	36.3	101.3	35.0	102.3	33.4	103.7
			36.9	83.4	2.3	1.1	35.3	84.2	33.9	84.9	32.6	85.5	30.9	86.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	72.8	56.0	59.1	64.2	73.0	79.5	83.0	84.9	84.9	82.4	77.0	68.6	59.7	(6)
(7)		DBStd	11.76	7.25	8.66	7.09	6.41	4.42	3.46	3.38	3.10	3.82	4.76	5.96	5.97	(7)
(8)		HDD50	43	24	14	1	0	0	0	0	0	0	0	0	4	(8)
(9)		HDD65	832	291	206	105	14	0	0	0	0	0	1	31	184	(9)
(10)		CDD50	8349	210	268	440	689	916	990	1081	1083	971	837	559	305	(10)
(11)		CDD65	3663	12	40	79	253	451	540	616	618	522	372	140	20	(11)
(12)		CDH74	35769	19	155	277	1580	4053	5837	7332	7373	5574	2865	657	47	(12)
(13)		CDH80	13741	0	28	33	394	1351	2231	3256	3251	2203	878	114	2	(13)
(14)	Wind	WSAvg	3.1	2.9	2.9	2.8	3.0	3.2	3.4	3.7	3.5	3.2	3.0	3.0	2.9	(14)
(15)	Precipitation	PrecAvg	65.7	2.2	3.2	3.9	8.1	11.0	9.7	7.8	8.1	4.2	3.3	2.6	1.6	(15)
(16)		PrecMax	97.8	6.4	11.5	8.6	20.8	20.8	23.5	18.1	22.5	13.2	10.9	8.4	6.9	(16)
(17)		PrecMin	40.7	0.2	0.3	0.4	3.3	2.4	2.5	3.0	1.3	0.6	0.1	0.0	0.0	(17)
(18)		PrecStd	12.8	1.7	2.5	2.0	4.4	4.2	4.9	4.3	4.8	2.6	2.5	2.3	1.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.7	84.3	83.6	90.2	94.1	95.5	97.4	96.9	95.3	91.8	86.3	78.3	(19)
(20)			MCWB	66.6	72.1	73.0	77.8	80.1	80.6	80.2	79.9	79.2	75.8	73.4	67.4	(20)
(21)		2%	DB	72.6	78.3	79.9	87.2	91.5	93.4	95.4	95.0	93.2	89.3	83.3	74.8	(21)
(22)			MCWB	64.2	68.5	71.3	76.1	78.8	80.3	80.2	79.8	78.7	74.9	70.1	65.8	(22)
(23)		5%	DB	69.7	74.7	76.9	84.7	89.3	91.5	93.6	93.5	91.5	87.2	80.6	71.9	(23)
(24)			MCWB	62.5	67.0	70.1	74.9	77.7	80.0	80.0	79.7	78.4	73.8	68.8	62.6	(24)
(25)		10%	DB	67.0	71.3	74.2	81.9	86.9	89.4	91.7	91.7	89.6	85.1	77.9	69.1	(25)
(26)			MCWB	61.3	65.4	68.8	74.2	77.2	79.6	79.8	79.7	77.8	72.8	67.7	60.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.6	72.4	75.1	79.4	81.8	82.8	83.0	82.9	81.9	79.6	75.6	72.3	(27)
(28)			MCDWB	73.6	81.3	80.1	87.5	90.1	91.2	92.1	90.5	88.6	86.9	81.7	75.9	(28)
(29)		2%	WB	66.4	70.2	73.5	77.7	80.6	81.8	81.8	81.9	80.9	78.0	74.1	68.3	(29)
(30)			MCDWB	70.4	76.7	78.0	84.8	88.3	89.6	90.7	89.7	88.5	84.7	79.8	71.6	(30)
(31)		5%	WB	64.5	68.2	71.6	76.5	79.6	81.0	81.1	81.1	80.1	76.7	72.6	65.4	(31)
(32)			MCDWB	68.7	73.2	75.1	82.6	86.5	88.3	89.4	88.8	87.6	83.4	78.0	69.6	(32)
(33)		10%	WB	62.1	66.1	69.6	75.3	78.7	80.3	80.5	80.6	79.3	75.4	70.8	62.6	(33)
(34)			MCDWB	66.2	70.4	73.4	80.5	84.8	87.0	88.4	88.2	86.4	81.9	75.8	67.6	(34)
(35)	Mean Daily Temperature Range	MDBR	9.7	9.6	9.0	9.6	10.9	10.5	11.5	11.9	12.1	12.7	12.6	11.8	(35)	
(36)		5% DB	MCDBR	14.8	15.8	14.0	14.4	14.8	13.7	14.6	14.7	14.5	14.8	16.0	15.7	(36)
(37)			MCWBR	7.1	6.8	6.4	5.6	4.9	4.1	3.8	3.7	3.9	4.2	5.8	7.2	(37)
(38)		5% WB	MCDBR	11.7	13.1	11.1	12.0	12.1	11.7	12.8	13.0	12.8	12.3	11.7	11.3	(38)
(39)			MCWBR	6.4	6.8	6.9	5.9	5.1	4.4	4.3	4.3	4.3	4.4	5.5	6.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.648	0.693	0.842	0.804	0.622	0.579	0.553	0.630	0.676	0.742	0.625	0.640	(40)	
(41)		taud	1.620	1.580	1.364	1.466	1.839	1.963	2.027	1.808	1.684	1.524	1.711	1.661	(41)	
(42)		Ebn at Noon	195	198	178	190	227	235	241	224	209	184	199	190	(42)	
(43)		Edh at Noon	75	82	107	98	67	59	55	69	76	86	68	69	(43)	
(44)	All-Sky Solar Radiation	RadAvg	686	739	806	1028	1273	1326	1541	1539	1424	1270	991	814	(44)	
(45)		RadStd	171	137	122	135	119	186	156	106	102	104	157	167	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+0.83	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	N/A	+0.56	N/A	N/A	N/A	N/A	N/A	+97

Nomenclature: See separate page