

WUZHOU, China

WMO: 592650

Lat: 23.4783N

Lon: 111.3037E

Elev: 394

StdP: 14.49

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	39.0	41.4	26.6	20.8	51.0	30.7	25.2	48.3	12.2	49.7	11.2	49.3	4.6	40	0.302

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.2	94.6	79.9	93.3	79.5	91.9	79.3	82.0	90.2	81.4	89.3	80.7	88.4	4.4	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.0	158.2	85.6	79.3	154.5	85.0	78.8	151.6	84.6	46.4	90.7	45.6	89.8	44.9	88.8	85.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.2	9.5	7.8	35.8	97.5	2.6	1.2	33.9	98.3	32.4	99.0	30.9	99.6	29.0	100.5
			33.3	83.4	2.2	1.0	31.7	84.1	30.4	84.7	29.1	85.3	27.5	86.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	71.6	54.8	58.2	63.5	72.3	78.6	82.2	84.0	83.7	81.1	75.5	66.8	57.7	(6)
(7)		DBStd	12.01	8.04	9.33	8.04	6.79	4.47	3.30	2.89	2.85	3.77	4.77	6.36	6.53	(7)
(8)		HDD50	79	40	25	3	0	0	0	0	0	0	0	1	10	(8)
(9)		HDD65	1002	329	227	129	21	0	0	0	0	2	53	241	(9)	
(10)		CDD50	7966	189	256	423	669	886	967	1053	1046	932	789	506	250	(10)
(11)		CDD65	3412	13	38	83	239	421	517	588	581	482	326	108	16	(11)
(12)		CDH74	31953	35	189	379	1569	3556	5279	6632	6439	4809	2417	590	59	(12)
(13)		CDH80	12093	1	27	56	419	1226	2054	2861	2732	1872	744	100	1	(13)
(14)	Wind	WSAvg	3.8	4.0	4.0	4.0	3.8	3.6	3.8	3.6	3.8	3.9	3.8	4.0	(14)	
(15)	Precipitation	PrecAvg	58.5	2.0	2.7	3.2	8.7	10.3	8.2	6.5	7.6	3.9	2.6	1.6	1.1	(15)
(16)		PrecMax	75.1	8.8	10.6	8.7	20.4	16.0	27.9	14.8	17.8	10.8	8.9	6.9	3.6	(16)
(17)		PrecMin	40.7	0.1	0.1	0.4	4.0	1.3	2.1	1.9	2.3	0.4	0.1	0.0	0.0	(17)
(18)		PrecStd	8.8	2.0	2.6	1.9	3.9	3.5	5.5	3.4	4.0	2.6	2.0	1.7	1.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.7	83.6	85.1	90.5	93.6	95.1	96.4	96.1	94.3	91.0	86.0	78.8	(19)
(20)		MCWB	66.5	71.8	73.1	77.2	79.0	80.2	80.4	80.3	79.5	75.9	73.3	68.4	(20)	
(21)		2%	DB	74.1	79.1	81.2	87.2	90.9	93.2	94.8	94.3	92.4	88.5	82.8	75.6	(21)
(22)		MCWB	65.0	68.3	71.7	76.0	78.3	79.9	79.9	79.8	78.8	74.7	70.3	65.8	(22)	
(23)		5%	DB	70.8	75.9	78.2	84.7	88.9	91.5	93.1	92.8	90.8	86.6	80.4	71.8	(23)
(24)		MCWB	62.2	66.8	69.7	74.8	77.4	79.6	79.8	79.5	78.2	73.4	68.6	62.4	(24)	
(25)		10%	DB	67.3	72.5	75.3	82.2	86.7	89.6	91.3	91.1	88.9	84.5	77.5	68.5	(25)
(26)		MCWB	60.3	65.2	68.4	74.0	76.7	79.4	79.7	79.4	77.5	72.2	67.0	60.0	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.4	72.6	75.3	79.0	81.8	82.7	82.8	82.9	81.9	79.1	75.5	71.8	(27)
(28)		MCDWB	74.9	81.3	82.2	87.1	89.4	90.6	91.5	91.2	89.7	86.8	82.6	76.2	(28)	
(29)		2%	WB	66.3	70.1	73.2	77.4	80.3	81.6	81.8	81.8	80.8	77.3	73.7	68.1	(29)
(30)		MCDWB	72.3	77.2	79.4	84.7	87.6	89.5	90.3	90.1	88.5	84.5	79.7	72.8	(30)	
(31)		5%	WB	63.8	68.1	71.4	76.2	79.1	80.8	81.1	81.0	79.9	76.2	72.0	64.8	(31)
(32)		MCDWB	69.3	74.2	76.3	82.8	86.0	88.4	89.1	88.8	87.1	82.8	77.7	69.5	(32)	
(33)		10%	WB	61.4	65.8	69.5	74.9	78.1	80.0	80.4	80.4	79.1	74.9	69.8	61.8	(33)
(34)		MCDWB	66.6	71.6	74.1	80.7	84.4	87.0	88.0	87.7	85.7	80.9	74.9	67.5	(34)	
(35)	Mean Daily Temperature Range	MDBR	12.3	12.3	11.5	11.8	13.0	12.3	13.2	13.5	13.6	14.5	14.9	14.3	(35)	
(36)		5% DB	MCDBR	17.6	18.0	16.1	15.9	16.4	15.5	15.9	16.0	15.9	16.9	18.0	18.4	(36)
(37)		MCWBR	9.3	8.5	7.9	7.0	5.8	4.7	4.2	4.5	4.7	5.6	7.6	9.5	(37)	
(38)		5% WB	MCDBR	15.2	16.3	14.2	14.0	14.1	13.7	14.3	14.4	14.0	13.9	14.9	14.4	(38)
(39)		MCWBR	8.6	8.9	8.7	7.4	6.2	5.4	5.2	5.3	5.1	5.8	7.9	9.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.635	0.687	0.831	0.799	0.625	0.578	0.552	0.623	0.678	0.721	0.606	0.611	(40)	
(41)		taud	1.639	1.586	1.377	1.469	1.827	1.961	2.024	1.819	1.677	1.549	1.746	1.706	(41)	
(42)		Ebn at Noon	198	199	180	191	226	235	242	225	209	188	204	197	(42)	
(43)		Edh at Noon	73	82	106	98	68	59	56	68	77	84	65	66	(43)	
(44)	All-Sky Solar Radiation	RadAvg	744	787	829	1015	1245	1343	1572	1537	1422	1288	1019	865	(44)	
(45)		RadStd	165	134	120	149	128	188	147	105	101	111	150	170	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+110	(46)
(47)	Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page