

GAOYAO, China

WMO: 592780

Lat: 22.9904N

Lon: 112.4792E

Elev: 137

StdP: 14.62

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	43.5	45.7	26.0	20.1	54.4	30.2	24.5	54.3	16.4	52.1	14.7	52.8	6.3	20	0.311

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	95.2	79.5	93.7	79.3	92.2	79.1	82.5	89.6	81.7	88.5	81.0	87.6	5.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.9	161.3	85.2	80.1	156.8	84.6	79.4	153.1	84.1	46.6	89.9	45.7	88.7	44.9	87.7	85.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.3	13.0	11.2	41.1	98.5	2.5	1.1	39.3	99.3	37.8	99.9	36.4	100.5	34.5	101.3		
(5)			36.6	83.0	2.8	1.4	34.6	83.9	32.9	84.8	31.4	85.5	29.3	86.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	73.5	57.8	60.7	65.8	73.5	79.8	83.3	84.8	82.6	77.7	69.5	61.0	(6)	
(7)		DBStd	11.07	6.67	8.24	6.89	6.07	4.15	3.28	3.06	2.94	3.54	4.09	5.80	5.75	(7)
(8)		HDD50	24	12	10	0	0	0	0	0	0	0	0	0	2	(8)
(9)		HDD65	669	239	167	78	10	0	0	0	0	0	0	25	150	(9)
(10)		CDD50	8607	254	309	490	704	925	1000	1080	1079	978	858	586	344	(10)
(11)		CDD65	3777	16	46	102	265	460	550	615	614	528	393	161	27	(11)
(12)		CDH74	37344	21	140	361	1622	4224	6171	7514	7433	5866	3197	737	58	(12)
(13)		CDH80	13963	0	11	34	374	1342	2398	3307	3258	2272	856	110	1	(13)
(14)	Wind	WSAvg	4.8	5.0	5.0	4.7	4.6	4.5	4.4	4.7	4.8	5.0	4.9	4.8	5.1	(14)
(15)	Precipitation	PrecAvg	64.8	1.6	2.3	3.1	7.2	10.4	9.5	8.3	10.4	6.3	2.8	1.7	0.9	(15)
(16)		PrecMax	84.6	8.5	10.6	12.0	16.1	23.5	17.2	15.3	21.3	20.5	9.3	7.3	4.1	(16)
(17)		PrecMin	43.8	0.0	0.2	0.4	0.5	2.8	4.0	3.4	1.9	0.5	0.0	0.0	0.0	(17)
(18)		PrecStd	9.9	2.0	2.6	2.3	3.3	3.7	3.3	3.3	4.9	4.5	2.6	1.9	1.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.8	81.8	83.3	89.5	93.4	95.4	97.7	97.1	94.8	90.8	86.2	78.9	(19)
(20)			MCWB	66.4	71.1	72.1	76.5	80.0	79.9	79.8	79.4	78.6	76.2	72.9	69.7	(20)
(21)		2%	DB	73.6	78.2	80.4	86.9	90.7	93.5	95.3	95.0	92.8	88.2	83.1	75.4	(21)
(22)			MCWB	64.9	68.8	71.4	75.9	78.2	79.9	79.7	79.1	78.2	74.7	71.3	66.5	(22)
(23)		5%	DB	70.8	75.2	77.9	84.4	88.8	91.7	93.5	93.3	91.1	86.4	80.7	72.7	(23)
(24)			MCWB	63.3	67.3	70.4	74.8	77.8	79.6	79.6	79.0	78.0	73.3	69.4	64.2	(24)
(25)		10%	DB	68.1	72.4	75.5	82.0	86.8	89.7	91.5	91.4	89.2	84.6	78.4	70.0	(25)
(26)			MCWB	62.1	65.9	69.3	74.1	77.0	79.5	79.5	79.1	77.2	72.5	67.9	61.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.7	72.6	75.3	79.6	82.3	83.5	83.3	83.4	82.2	79.7	75.7	72.6	(27)
(28)			MCD B	73.4	78.9	79.7	85.6	88.6	90.2	91.1	90.9	88.6	85.1	81.7	76.1	(28)
(29)		2%	WB	66.9	71.0	73.6	77.9	80.5	82.2	82.2	82.2	81.0	78.0	74.3	69.7	(29)
(30)			MCD B	71.5	76.0	78.0	83.5	87.0	88.9	89.6	89.4	87.3	83.6	79.7	74.0	(30)
(31)		5%	WB	65.1	69.1	72.2	76.6	79.4	81.3	81.4	81.3	80.1	76.9	72.9	66.7	(31)
(32)			MCD B	69.6	73.5	76.3	81.7	85.6	87.6	88.5	88.1	86.2	82.4	78.0	70.5	(32)
(33)		10%	WB	62.9	66.9	70.5	75.4	78.5	80.4	80.7	80.5	79.2	75.8	71.1	63.6	(33)
(34)			MCD B	67.0	71.2	74.2	80.4	84.4	86.5	87.4	87.0	85.1	81.5	76.2	68.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.4	10.0	9.5	9.4	10.4	10.4	11.0	11.3	10.9	11.2	11.8	11.6	(35)
(36)			MCD BR	14.2	14.3	13.0	13.3	13.8	13.7	14.4	14.5	13.5	13.1	14.5	14.4	(36)
(37)			MCWBR	6.6	6.0	5.4	4.9	4.5	3.5	3.4	3.7	3.5	4.0	5.0	6.3	(37)
(38)		5% WB	MCD BR	11.5	12.2	10.8	11.6	11.9	12.1	12.2	12.5	12.1	11.0	11.3	10.7	(38)
(39)			MCWBR	6.4	6.6	6.1	5.3	4.9	4.3	4.2	4.3	3.9	4.1	5.0	6.6	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.624	0.676	0.813	0.784	0.621	0.574	0.553	0.629	0.681	0.724	0.611	0.601	(40)
(41)		taud		1.688	1.625	1.424	1.504	1.846	1.982	2.033	1.816	1.687	1.562	1.769	1.756	(41)
(42)		Ebn at Noon		202	203	184	194	227	237	241	224	208	189	204	202	(42)
(43)		Edh at Noon		70	79	101	95	67	58	55	68	76	83	64	63	(43)
(44)	All-Sky Solar Radiation	RadAvg		839	850	884	1007	1246	1344	1532	1495	1401	1286	1053	938	(44)
(45)		RadStd		153	134	128	172	140	198	167	114	98	123	149	166	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	-2.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (14 neighbors)	N/A	N/A	N/A	+0.36	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page