

GAOYAO, China

WMO: 592780

Lat: 22.9904N

Lon: 112.4792E

Elev: 42

StdP: 100.82

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.4	7.6	-3.3	2.9	12.4	-1.0	3.5	12.4	7.3	11.1	6.6	11.6	2.8	20	0.311

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.1	35.1	26.4	34.3	26.3	33.5	26.2	28.1	32.0	27.6	31.4	27.2	30.9	2.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	23.0	29.5	26.7	22.4	29.2	26.3	21.9	29.0	90.5	32.1	88.4	31.5	86.6	31.0	29.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.9	5.8	5.0	DB	5.0	36.9	1.4	0.6	4.0	37.4	3.2	37.7	2.4	38.1	1.4	38.5	(4)
(5)			WB	2.6	28.3	1.6	0.8	1.4	28.9	0.5	29.3	-0.4	29.7	-1.5	30.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.1	14.3	15.9	18.8	23.0	26.6	28.5	29.4	29.3	28.1	25.4	20.8	16.1
	DBStd	6.15	3.71	4.58	3.83	3.37	2.31	1.82	1.70	1.63	1.97	2.27	3.22	3.19
	HDD10.0	13	7	6	0	0	0	0	0	0	0	0	0	1
	HDD18.3	372	133	93	43	6	0	0	0	0	0	0	14	83
	CDD10.0	4782	141	172	272	391	514	556	600	599	543	477	326	191
	CDD18.3	2098	9	26	57	147	256	306	342	341	293	218	89	15
	CDH23.3	20747	12	78	201	901	2347	3428	4174	4129	3259	1776	409	32
CDH26.7	7757	0	6	19	208	746	1332	1837	1810	1262	476	61	1	
Wind	WSAvg	2.1	2.2	2.2	2.1	2.0	2.0	2.0	2.1	2.1	2.2	2.2	2.2	2.3
Precipitation	PrecAvg	1645	41	59	78	182	263	241	212	264	160	71	44	24
	PrecMax	2150	217	270	306	409	596	438	389	541	520	235	186	103
	PrecMin	1113	0	6	10	12	71	101	86	49	13	0	0	0
	PrecStd	252	52	65	59	84	94	84	85	125	114	66	49	25
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.9	27.7	28.5	31.9	34.1	35.2	36.5	36.1	34.9	32.6	30.1	26.1
		MCWB	19.1	21.7	22.3	24.7	26.7	26.6	26.6	26.4	25.9	24.5	22.7	21.0
	2%	DB	23.1	25.7	26.9	30.5	32.6	34.2	35.1	35.0	33.8	31.2	28.4	24.1
		MCWB	18.3	20.4	21.9	24.4	25.7	26.6	26.5	26.2	25.6	23.7	21.8	19.2
	5%	DB	21.5	24.0	25.5	29.1	31.6	33.2	34.2	34.0	32.8	30.2	27.1	22.6
		MCWB	17.4	19.6	21.3	23.8	25.4	26.4	26.4	26.1	25.5	22.9	20.8	17.9
	10%	DB	20.1	22.4	24.2	27.8	30.4	32.1	33.1	33.0	31.8	29.2	25.8	21.1
		MCWB	16.7	18.8	20.7	23.4	25.0	26.4	26.4	26.2	25.1	22.5	20.0	16.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.4	22.6	24.1	26.4	28.0	28.6	28.5	28.6	27.9	26.5	24.3	22.5
		MCDB	23.0	26.1	26.5	29.8	31.4	32.3	32.8	32.7	31.5	29.5	27.6	24.5
	2%	WB	19.4	21.7	23.1	25.5	26.9	27.9	27.9	27.9	27.2	25.6	23.5	20.9
		MCDB	21.9	24.4	25.6	28.6	30.6	31.6	32.0	31.9	30.7	28.7	26.5	23.3
	5%	WB	18.4	20.6	22.3	24.8	26.3	27.4	27.4	27.4	26.7	24.9	22.7	19.3
		MCDB	20.9	23.1	24.6	27.6	29.8	30.9	31.4	31.2	30.1	28.0	25.5	21.4
	10%	WB	17.2	19.4	21.4	24.1	25.8	26.9	27.0	27.0	26.2	24.3	21.7	17.6
		MCDB	19.5	21.8	23.5	26.9	29.1	30.3	30.8	30.6	29.5	27.5	24.6	20.4
Mean Daily Temperature Range	5% DB	MDBR	5.8	5.5	5.3	5.2	5.8	5.8	6.1	6.3	6.0	6.2	6.5	6.4
		MCDBR	7.9	8.0	7.2	7.4	7.7	7.6	8.0	8.1	7.5	7.3	8.0	8.0
		MCWBR	3.7	3.3	3.0	2.7	2.5	2.0	1.9	2.1	1.9	2.2	2.8	3.5
	5% WB	MCDBR	6.4	6.8	6.0	6.4	6.6	6.7	6.8	7.0	6.7	6.1	6.3	6.0
		MCWBR	3.6	3.6	3.4	2.9	2.7	2.4	2.3	2.4	2.2	2.3	2.8	3.7
Clear-Sky Solar Irradiance	taub	0.624	0.676	0.813	0.784	0.621	0.574	0.553	0.629	0.681	0.724	0.611	0.601	
	taud	1.688	1.625	1.424	1.504	1.846	1.982	2.033	1.816	1.687	1.562	1.769	1.756	
	Ebn at Noon	637	640	579	611	717	746	761	706	657	595	644	636	
	Edh at Noon	221	250	318	298	211	182	173	215	241	262	202	200	
All-Sky Solar Radiation	RadAvg	2.65	2.68	2.79	3.17	3.93	4.24	4.83	4.71	4.42	4.05	3.32	2.96	
	RadStd	0.48	0.42	0.40	0.54	0.44	0.62	0.53	0.36	0.31	0.39	0.47	0.52	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	-1.36	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (14 neighbors)	N/A	N/A	N/A	+0.20	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page