

HEYUAN, China

WMO: 592930

Lat: 23.7935N

Lon: 114.7309E

Elev: 200

StdP: 14.59

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	39.8	42.0	18.4	14.0	51.4	24.2	18.5	51.2	19.9	47.8	17.9	48.5	6.6	40	0.304

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.7	95.3	78.7	93.9	78.5	92.4	78.2	81.8	89.0	81.0	88.4	80.3	87.7	5.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.2	158.0	84.7	79.2	152.6	84.1	78.4	148.7	83.6	45.9	89.2	45.0	88.6	44.2	88.1	92.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
15.3	12.2	10.0	DB	36.8	98.8	2.8	1.5	34.8	99.9	33.2	100.8	31.7	101.6	29.7	102.7
			WB	32.1	82.8	3.1	2.5	29.8	84.6	28.0	86.0	26.2	87.4	23.9	89.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	72.4	56.3	59.6	64.8	72.7	78.6	82.2	84.6	84.3	82.0	76.5	68.1	59.0	(6)
	DBStd	11.57	7.53	8.92	7.45	6.03	4.49	3.64	2.94	3.10	3.70	4.56	6.37	6.50	(7)
	HDD50	57	26	20	2	0	0	0	0	0	0	0	1	8	(8)
	HDD65	838	283	193	99	14	0	0	0	0	0	1	41	207	(9)
	CDD50	8249	222	288	461	680	885	967	1072	1062	961	821	543	287	(10)
	CDD65	3554	14	42	92	243	420	517	607	597	511	357	133	21	(11)
	CDH74	34260	48	174	424	1480	3628	5456	7176	6912	5381	2795	706	80	(12)
	CDH80	12926	1	12	53	335	1181	2048	3158	2993	2138	867	136	4	(13)
(14) Wind	WSAvg	4.2	4.8	4.5	4.2	3.9	3.8	3.9	3.9	3.8	4.2	4.4	4.6	4.8	(14)
(15) Precipitation	PrecAvg	75.9	2.4	2.9	5.6	8.7	11.1	15.1	9.0	9.8	6.1	1.7	1.7	1.9	(15)
	PrecMax	108.1	16.3	9.1	21.9	21.5	26.9	39.1	19.0	20.5	16.6	7.2	7.2	7.1	(16)
	PrecMin	50.2	0.0	0.0	1.7	1.4	3.0	5.7	2.0	2.7	2.1	0.0	0.0	0.0	(17)
	PrecStd	16.1	3.0	2.4	4.2	4.8	5.5	7.8	5.2	5.6	3.2	1.8	1.9	2.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.5	81.8	84.4	89.4	93.8	95.3	97.6	97.3	95.2	92.5	87.2	80.0	(19)
		MCWB	66.2	67.6	70.8	73.7	77.7	79.0	78.9	79.0	78.1	75.9	72.3	68.8	(20)
	2%	DB	74.8	78.9	81.4	86.1	90.8	93.3	95.4	95.2	93.3	89.1	83.8	76.3	(21)
		MCWB	63.7	66.3	68.8	73.1	76.2	78.7	78.8	77.6	74.2	70.4	65.1		(22)
	5%	DB	71.5	76.0	78.8	83.9	88.6	91.4	93.7	93.5	91.7	87.0	81.0	72.8	(23)
		MCWB	61.1	65.2	67.7	72.3	75.7	78.3	78.8	78.6	77.2	72.5	68.3	62.7	(24)
	10%	DB	68.1	72.8	76.0	81.5	86.4	89.3	91.8	91.6	89.7	85.0	78.2	69.5	(25)
		MCWB	60.0	64.4	67.2	71.9	75.2	78.2	78.7	78.4	76.3	71.3	66.4	59.6	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.1	71.1	73.5	77.8	81.5	82.6	82.7	82.8	81.6	78.5	74.7	71.9	(27)
		MCDB	74.5	77.9	79.5	83.2	87.9	88.7	89.7	90.2	88.8	86.3	82.8	76.6	(28)
	2%	WB	65.8	69.3	72.0	76.0	79.4	81.2	81.7	81.6	80.2	77.2	73.1	68.3	(29)
		MCDB	71.9	75.1	77.6	81.6	85.8	88.0	89.1	89.2	87.8	84.5	80.1	73.7	(30)
	5%	WB	63.4	67.5	70.6	74.8	78.3	80.2	80.8	80.8	79.3	76.1	71.5	65.0	(31)
		MCDB	69.6	73.3	76.2	80.6	84.6	87.1	88.7	88.3	86.5	83.0	78.1	70.4	(32)
	10%	WB	61.1	65.4	68.9	73.7	77.4	79.6	80.0	80.0	78.5	74.8	69.5	61.7	(33)
		MCDB	67.3	71.6	74.4	79.0	83.3	86.0	87.6	87.2	85.4	81.5	75.5	67.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	13.9	13.1	12.4	11.4	11.6	10.9	12.7	12.7	13.0	13.8	14.5	14.2	(35)
		MCDBR	19.2	18.2	17.1	15.1	15.5	14.7	15.9	16.1	15.7	16.0	17.7	18.4	(36)
	5% WB	MCWBR	9.3	7.7	6.9	5.1	4.6	3.6	3.5	3.8	4.0	4.7	6.7	8.6	(37)
		MCWBR	15.9	14.1	13.1	11.6	11.9	12.0	13.5	13.6	13.7	13.2	13.7	14.3	(38)
(40) Clear-Sky Solar Irradiance	taub		0.586	0.652	0.786	0.774	0.626	0.593	0.568	0.629	0.657	0.676	0.574	0.554	(40)
		taud	1.741	1.657	1.451	1.514	1.829	1.912	1.974	1.805	1.726	1.640	1.829	1.834	(41)
	Ebn at Noon		210	207	188	195	226	232	238	224	213	199	213	213	(42)
		Edh at Noon	66	76	98	94	68	62	58	69	73	76	60	58	(43)
(44) All-Sky Solar Radiation	RadAvg		913	916	960	1023	1220	1278	1590	1514	1418	1298	1061	971	(44)
	RadStd		149	158	140	183	203	184	145	137	100	160	135	151	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (14 neighbors)	N/A	N/A	N/A	+0.58	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page