

XINYI, China

WMO: 594560

Lat: 22.3469N

Lon: 110.9250E

Elev: 142

StdP: 99.63

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.6	7.9	-3.5	2.9	13.7	-0.8	3.6	13.2	7.3	10.4	6.6	11.2	3.0	20	0.292

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.9	34.7	25.9	34.0	25.8	33.2	25.7	27.6	31.2	27.2	30.8	26.9	30.5	2.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.9	22.9	28.8	26.5	22.3	28.6	26.1	21.8	28.5	89.3	31.3	87.5	30.9	86.0	30.5	29.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max					
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
6.0	5.1	4.4	DB	5.0	36.2	1.7	0.8	3.8	36.8	2.9	37.2	1.9	37.6	0.7	38.2	
			WB	2.2	28.3	1.5	0.7	1.1	28.7	0.2	29.1	-0.6	29.5	-1.7	30.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.7	15.7	17.2	20.3	24.1	27.0	28.3	28.9	28.8	27.9	25.8	21.8	17.5
	DBStd	5.58	4.15	4.86	3.83	3.16	2.00	1.48	1.62	1.46	1.73	2.18	3.15	3.47
	HDD10.0	11	6	4	0	0	0	0	0	0	0	0	0	1
	HDD18.3	272	103	73	26	3	0	0	0	0	0	0	9	58
	CDD10.0	4994	181	207	320	424	528	551	587	584	538	488	354	233
	CDD18.3	2214	20	43	88	178	269	301	328	326	288	230	113	31
	CDH23.3	20581	67	176	421	1266	2527	3218	3738	3572	2940	1886	645	127
Wind	WSAvg	1.9	2.1	2.1	1.9	1.8	1.7	1.6	1.6	1.6	1.8	2.0	2.0	2.1
	PrecAvg	1781	40	63	68	217	306	317	215	274	147	74	37	22
	PrecMax	2718	192	323	223	513	662	935	658	587	336	386	141	80
	PrecMin	1058	0	2	6	47	69	80	37	44	21	0	0	0
	PrecStd	371	46	77	50	128	141	193	124	138	89	77	43	23
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.8	29.4	30.3	32.7	34.0	35.0	35.8	35.6	34.7	33.2	31.0	27.7
		MCWB	19.4	21.3	23.2	25.2	25.6	25.9	26.1	26.0	25.3	23.8	22.1	20.0
	2%	DB	25.3	26.9	28.5	31.5	33.0	33.9	34.8	34.5	33.7	32.1	29.6	26.3
		MCWB	18.9	20.0	22.3	24.4	25.3	26.2	26.1	25.9	25.2	23.5	21.3	19.4
	5%	DB	23.8	25.5	26.9	30.2	32.1	33.0	33.8	33.6	32.8	31.1	28.4	24.7
		MCWB	18.1	19.8	21.5	24.1	25.2	26.2	26.1	25.9	25.1	23.0	20.7	18.3
	10%	DB	22.2	24.1	25.6	28.8	31.0	31.9	32.7	32.5	31.8	30.1	27.1	23.2
		MCWB	17.2	19.4	21.1	23.7	25.0	26.1	26.2	26.0	24.7	22.3	20.2	17.3
	0.4%	WB	21.0	22.5	24.1	26.6	27.6	28.0	28.1	28.0	27.3	25.8	24.4	23.3
		MCDB	24.8	26.6	28.1	30.7	31.1	31.1	32.1	32.0	30.8	30.3	27.8	25.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	20.1	21.6	23.3	25.7	26.9	27.5	27.5	27.4	26.7	25.1	23.6	21.4
		MCDB	23.3	25.3	26.9	29.2	30.3	30.7	31.3	31.2	30.4	29.2	26.9	24.2
	5%	WB	19.1	20.9	22.7	25.1	26.5	27.1	27.1	27.0	26.3	24.6	23.0	20.1
		MCDB	22.7	24.1	25.9	28.4	29.8	30.5	30.8	30.7	29.8	28.4	26.3	22.7
	10%	WB	18.2	20.1	22.0	24.4	26.0	26.7	26.7	26.6	25.9	24.1	22.2	18.6
		MCDB	21.5	23.1	24.8	27.6	29.3	30.0	30.3	30.1	29.2	27.6	25.3	22.2
Mean Daily Temperature Range	5% DB	MDBR	7.5	7.0	6.6	6.4	6.8	6.4	6.9	7.0	7.2	7.8	8.1	8.0
		MCDBR	9.9	9.4	8.4	8.0	8.4	8.1	8.6	8.7	8.6	8.9	9.7	10.0
		MCWBR	4.3	3.7	3.3	2.6	2.5	2.1	2.0	2.1	2.2	2.5	3.3	4.3
	5% WB	MCDBR	8.1	7.3	6.7	6.9	7.1	6.5	7.3	7.4	7.4	7.6	7.4	7.9
		MCWBR	4.1	3.5	3.3	3.2	2.8	2.5	2.3	2.5	2.4	2.4	3.3	4.6
Clear-Sky Solar Irradiance	taub		0.624	0.675	0.838	0.803	0.607	0.566	0.546	0.626	0.679	0.750	0.610	0.609
	taud		1.668	1.607	1.371	1.464	1.876	1.999	2.041	1.814	1.677	1.505	1.745	1.719
	Ebn at Noon		640	642	565	600	727	751	766	709	660	580	647	632
	Edh at Noon		226	255	336	311	204	179	172	216	244	279	208	209
	RadAvg		2.62	2.74	2.89	3.45	4.24	4.40	4.88	4.82	4.52	4.17	3.45	2.94
All-Sky Solar Radiation	RadStd		0.52	0.43	0.40	0.48	0.38	0.61	0.52	0.33	0.29	0.29	0.46	0.51

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page