

SHENZHEN, China

WMO: 594930

Lat: 22.5417N

Lon: 114.0033E

Elev: 13

StdP: 14.69

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 44.9	(c) 47.9	(d) 21.2	(e) 15.9	(f) 55.2	(g) 26.8	(h) 20.8	(i) 55.6	(j) 18.2	(k) 54.2	(l) 16.5	(m) 54.8	(n) 10.0	(o) 20	(p) 0.361

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 9.6	(c) 93.2	(d) 79.5	(e) 91.6	(f) 79.5	(g) 90.1	(h) 79.4	(i) 84.1	(j) 88.2	(k) 83.1	(l) 87.1	(m) 82.2	(n) 86.4	(o) 7.8	(p) 220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
82.8	171.1	86.5	82.3	168.4	86.1	80.9	160.5	85.6	48.5	88.5	47.3	86.9	46.4	87.2	88.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min		Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.1	16.1	14.3		DB	42.1	97.4	3.5	1.9	39.5	98.7	37.5	99.8	35.5	100.9	33.0	102.3
				WB	35.2	85.0	3.3	1.7	32.8	86.2	30.9	87.2	29.0	88.1	26.6	89.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	74.9	61.0	62.9	67.9	74.7	80.3	83.6	85.1	84.8	83.3	79.3	72.1	63.8
	DBStd	9.98	6.51	7.58	6.12	5.13	3.70	2.82	2.51	2.72	3.08	3.64	5.43	5.92
	HDD50	11	5	5	0	0	0	0	0	0	0	0	0	1
	HDD65	425	156	117	43	6	0	0	0	0	0	0	11	92
	CDD50	9120	345	368	554	741	940	1009	1087	1077	999	909	662	429
	CDD65	4057	30	59	132	297	475	559	622	612	549	444	223	55
	CDH74	40428	33	105	361	1713	4565	6660	7889	7660	6378	3885	1074	105
CDH80	14870	1	5	23	278	1337	2633	3538	3356	2495	1049	152	3	
Wind	WSAvg	7.1	6.9	6.7	6.7	7.0	7.3	7.9	7.8	6.9	6.7	6.9	7.0	7.2
Precipitation	PrecAvg	71.1	1.1	1.8	2.9	6.5	9.5	11.9	11.8	12.3	7.4	2.9	1.3	1.1
	PrecMax	117.6	4.1	9.0	21.5	14.8	28.4	30.2	23.3	34.6	19.3	24.2	6.1	7.0
	PrecMin	37.3	0.0	0.0	0.0	0.1	0.3	0.0	0.1	2.0	0.3	0.0	0.0	0.0
	PrecStd	19.6	1.1	2.5	4.3	4.0	7.9	6.4	6.5	6.9	5.1	4.9	1.7	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.4	80.3	82.6	86.8	91.4	93.1	95.2	95.3	93.6	91.2	86.3	79.9
		MCWB	67.9	70.3	73.0	76.4	78.4	78.9	80.9	79.7	78.1	76.1	72.0	69.2
	2%	DB	74.1	77.1	79.9	84.6	89.0	90.9	92.8	93.1	91.7	88.2	83.8	77.0
		MCWB	65.7	68.8	72.1	75.8	78.4	79.8	80.4	79.8	78.0	74.9	71.8	67.2
	5%	DB	71.7	74.9	77.4	82.9	87.5	89.6	91.2	91.4	89.9	86.5	81.7	74.5
		MCWB	63.8	67.8	70.8	75.3	78.3	80.1	80.3	80.1	77.7	74.1	70.8	65.5
	10%	DB	69.5	72.1	75.6	81.2	85.9	88.1	89.7	89.7	88.6	85.1	79.5	71.9
		MCWB	62.6	66.0	69.6	74.8	78.1	80.4	80.3	80.0	77.7	73.5	69.6	63.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.5	72.9	76.3	80.7	83.1	84.9	85.4	85.3	83.4	80.8	76.8	72.8
		MCDB	74.8	77.5	79.5	82.9	86.5	88.6	89.8	89.5	87.6	85.7	81.4	76.7
	2%	WB	67.7	71.0	73.9	78.5	81.6	83.5	84.0	83.7	81.8	79.2	74.9	70.2
		MCDB	72.2	75.4	77.8	82.0	85.2	87.1	88.2	88.1	86.6	84.2	80.4	74.3
	5%	WB	65.8	69.1	72.3	77.2	80.5	82.6	82.8	82.7	80.8	78.1	73.5	67.8
		MCDB	70.2	73.4	76.5	81.0	84.5	86.0	87.1	87.1	86.2	83.3	79.1	72.8
	10%	WB	63.8	67.1	70.8	75.9	79.5	81.7	81.8	81.6	79.8	76.7	72.1	65.3
		MCDB	68.3	71.4	74.9	80.1	83.8	85.7	86.6	86.6	85.4	82.5	77.8	70.8
Mean Daily Temperature Range	5% DB	MDBR	12.1	11.4	11.1	10.3	10.0	8.9	9.6	10.1	10.7	11.3	12.3	12.5
		MCDBR	14.4	14.1	13.0	11.7	11.4	10.2	11.2	12.0	12.1	12.3	13.2	14.5
		MCWBR	8.1	7.8	7.4	6.4	6.0	5.2	5.2	5.7	5.6	6.0	6.3	7.7
	5% WB	MCDBR	12.9	12.7	11.6	10.4	9.6	8.9	9.7	10.7	10.6	10.6	11.1	12.2
MCWBR		8.0	7.8	7.3	6.9	6.0	5.8	6.1	6.4	5.8	5.8	6.7	7.7	
Clear-Sky Solar Irradiance	taub		0.592	0.644	0.775	0.753	0.594	0.559	0.546	0.613	0.648	0.693	0.586	0.575
	taud		1.783	1.712	1.502	1.580	1.945	2.050	2.082	1.884	1.786	1.650	1.858	1.841
	Ebn at Noon		212	211	192	200	234	240	243	228	216	197	212	210
	Edh at Noon		64	73	94	88	61	54	52	64	69	76	59	58
All-Sky Solar Radiation	RadAvg		976	989	1052	1153	1393	1434	1680	1577	1484	1385	1129	1026
	RadStd		159	155	144	185	187	213	178	140	106	140	130	153

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (13 neighbors)		N/A	N/A	N/A	+0.45	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page